



 Ø150 COND. W.R.T.B.
 Ø100 WVP. No. 4 TERMINALS AT ROOF LEVEL

 Ø150 COND.
 Ø125 BY PASS

 New removable louvre screen to provide access for major component replacement to AHU02

—3 New double glazed roof to meet building regulations

25Ø LTHW F&R to reheat coil.

New MER external

25Ø LTHW F&R to reheat coil.

65Ø CHW F&R to cooling coi

AHU02 Chilled Water pump – enclosure containing header, valves & pump for cooling coil.

AHU02 Chilled Water pump enclosure containing header, valves & pump for cooling coil.

New Chilled Water and Low Temperature Hot Water to distribute under grillage and into pump enclosures.

New 65Ø CHW F&R 40Ø LTHW F&R 32Ø LTHW F&R to-Frost Coil

AHU02 Control Panel ——

spacelab

Unlocking space.
Empowering people.



This drawing is copyright. Do not scale off dimensions.
All dimensions are to be checked on site by contractor.
Contractor to report any dimensional discrepancies, errors or omissions prior to commencing in site.

Drawing number

1539-P-123-Pr. Roof Plan

18 Wenlock Road, London N1*7*TA | spacelab.co.uk

Revision



New CHW & LTHW Pipework connections to existing

