

Application No:	Consultees Name:	Consultees Addr:	Received:	Comment:	Response:
2017/4375/P	Sanya Polescuk on behalf of Belsize Residents Association	8a Belsize Court Garages NW35AJ	06/09/2017 08:49:54	OBJ	The proposal for the flat roof dormer states slate as a finishing external material. It is impossible to use slate for flat roofs. The size dormer cheeks is unlikely to allow for suitable slate cladding. The dormer should be finished in lead as a traditionally used material suitable for dormers. The proportion of the dormer window is unsuitable for horizontally sliding sashes and should instead be a casement window or two, narrower horizontal sliding sashes.
