

21 August 2017

Our reference: 125815

Daniel Monk
Unit 17, The Artworks Creekside
3 Creekside, London SE8 4SA

Dear Daniel,

TISH Restaurant – 196-198 Haverstock Hill, Belsize Park, London NW3 2AG

External Plant – Planning Application

Further to our recent meetings please find attached information relating to the proposed replacement of the existing external plant located at the rear of 196-198 Haverstock Hill.


Acoustic Attenuation to Mechanical Services

24 hour Noise Level Survey report has been commissioned and completed by Emtec Products. Please refer to the attached Emtec Products report, reference QF9140/PF6025/RP1 dated 7 August 2017. We confirm the design of the mechanical ventilation services and all external plant will be provided with the appropriate acoustic attenuation, as detailed in Emtec Products quotation reference QF9140/A1/MGR/CW dated 17 August 2017, to limit the plant operating noise levels to that indicated within the 24 hour Noise Level Survey report.

Air Filtration of the Kitchen Extract

The main kitchen extract will be replaced with new plant in the existing location. The new plant will include the installation of Electrostatic Precipitator (ESP) and carbon filters to comply with DEFRA standards. Please refer to the details provided by Purified Air.

Yours Sincerely,



Matt Jeeves

Director

Watts Group Limited

D: 020 7280 8075

E: matt.jeeves@watts.co.uk

Watts London 1 Great Tower Street, London, EC3R 5AA
T: 020 7280 8000 E: london@watts.co.uk

Watts Group Limited is registered in England and Wales

Registered Office 1 Great Tower Street, London, EC3R 5AA

Registration number 5728557. VAT number 205 9609 61. Regulated by RICS.

Directors Nick Winks (Chairman – Non-executive), Ian Ford (Managing Director), Anthony Williams (Company Secretary)
Trevor Rushton (Technical Director), Fiona Keddie (Non-executive).

watts.co.uk

