

SAFETY, HEALTH AND ENVIRONMENTAL INFORMATION:

IN ADDITION TO THE HAZARDS/RISKS NORMALLY ASSOCIATED WITH THE TYPE OF WORK DETAILED ON THIS DRAWING, NOTE THE FOLLOWING:

SIGNIFICANT RESIDUAL RISKS:

THESE STATEMENTS RESULT FROM THE DESIGN RISK ASSESSMENTS CARRIED OUT BY THE DESIGNER. THE SAFETY, HEALTH AND ENVIRONMENTAL INFORMATION IS INTENDED TO BE CONSISTENT WITH, BUT NOT REPLACE, THE HEALTH AND SAFETY INFORMATION ISSUED AS PART OF THE DOCUMENTATION PREPARED BY THE CDM-C. RISKS SHOWN ARE SIGNIFICANT RISKS ONLY I.E. THOSE WHICH AN EXPERIENCED CONTRACTOR MAY NOT REASONABLY ANTICIPATE.

CONSTRUCTION:

NONE KNOWN

MAINTENANCE:

NONE KNOWN

- 1. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL MECHANICAL, ELECTRICAL AND PUBLIC HEALTH SERVICES DRAWINGS FOR THIS CONTRACT.
- ALL EN-SUITES WC'S, BATHROOM/SHOWER ROOMS TO BE PROVIDED WITH ELECTRIC UNDERFLOOR HEATING AND WALL MOUNTED DIGITAL TEMPERATURE CONTROLLERS.
- 3. WET UNDERFLOOR HEATING SYSTEM TO BE COMATIBLE WITH PROPOSED FLOOR
- 4. FOR RISER DETAILS PLEASE REFER TO 9000 SERIES DRAWINGS.
- 5. WET AND ELECTRICAL UNDERFLOOR HEATING CIRCUITS IN EACH ROOM TO BE COORDINATED WITH L/L FURNITURE. UNDERFLOOR HEATING CIRCUIT NOT TO BE INSTALLED BELOW FIXED FURNITURE ELEMENTS.

WALL MOUNTED THERMOSTAT/CONTROLLER FOR ELECTRIC UFH T WALL MOUNTED THERMOSTAT/CONTROLLER FOR WET UFH

INDICATES AREA COVERED BY ELECTRIC UFH INDICATES AREA COVERED BY WET SYSTEM UFH

C1 | 17/03/2017 | CONTRACT ISSUE T4 22/02/2017 LATEST BACKGROUND INCORPORATED T3 19/09/2016 TENDER ISSUE T2 | 19/08/2016 | TENDER ISSUE T1 27/06/2016 TENDER ISSUE P1 06/05/2016 PRELIMINARY ISSUE Rev Date Description Status CONTRACT

Architect MODULOR STUDIO

GUILFORD LIMITED

MECSERVE

83 Blackfriars Road London SE1 8HA T: 020 3141 5800

W: www.mecserve.com

Project 66-67 GUILFORD STREET

LONDON

FIRST FLOOR UNDERFLOOR HEATING SERVICES LAYOUT

Checked APRIL 2016 1:50 @ A1 KJ MH

Drawing No C6123/3402 C1