

GAIL'S BAKERY
21 SWAINS LANE
HIGHGATE
LONDON N6 6QX

Plant Noise

Assessment

REPORT 8175/PNA
Prepared: 18 October 2017
Revision Number: 3

Gail's Ltd.
75 Salusbury Road
London
NW6 6NH

Plant Noise Assessment



GAIL'S BAKERY
21 SWAINS LANE HIGHGATE
LONDON N6 6QX

REPORT 8175/PNA
Prepared: 18 October 2017

Revision	Comment	Date	Prepared By	Approved By
0	First issue of report	17 August 2017	David Johnston	Paul Taylor
1	Criteria updated	30 August 2017	David Johnston	Paul Taylor
2	New plant selected	10 October 2017	David Johnston	Paul Taylor
3	Additional plant assessed	18 October 2017	David Johnston	Paul Taylor

Terms of contract:

RBA Acoustics Ltd has prepared this report in accordance with our Scope of Work 8175/DJ dated 21 July 2017. RBA Acoustics Ltd shall not be responsible for any use of the report or its contents for any purpose other than that for which it was provided. Should the Client require the distribution of the report to other parties for information, the full report should be copied. No professional liability or warranty shall be extended to other parties by RBA Acoustics Ltd without written agreement from RBA Acoustics Ltd.

The recommendations within this report relate to acoustics performance only and will need to be integrated within the overall design by the lead designer to incorporate all other design disciplines such as fire, structural integrity, setting-out, etc. Similarly, any sketches appended to this report illustrate acoustic principles only and again will need to be developed in to full working drawings by the lead designer to incorporate all other design disciplines.

In line with our Environmental Policy, up to two hard copies of the report will be provided upon request. Additional copies of the report, or further hard copies of revised reports, would be subject to an administrative cost of £20.00 (+VAT) per copy.



LONDON
44 Borough Road
London SE1 0AJ
T. +44 (0) 20 7620 1950

MANCHESTER
Lowry House, 17 Marble Street
Manchester, M2 3AW
T. +44 (0) 161 661 4504

Contents

1.0 INTRODUCTION..... 1

2.0 CRITERIA 1

3.0 ASSESSMENT..... 2

4.0 CONCLUSION 4

1.0 INTRODUCTION

RBA Acoustics have been commissioned to assess the potential impact of noise from items of fixed mechanical plant serving Gail's Bakery at 21 Swain's Lane, Highgate, London N6 6QX. The bakery is to be served by a kitchen extract canopy which will be ducted to the rear of the premises and terminate above a flat roof at first floor level.

A noise survey was carried out at the site by Sharps Redmore Acoustic Consultants prior to the bakery beginning trading. Since then other neighbouring commercial premises have been granted planning permission for items of mechanical plant and have begun trading. RBA Acoustics have been commissioned to assess the impact of the proposed plant serving Gail's in accordance with the London Borough of Camden's noise policy.

Revision 3 of this report includes the assessment of the existing ventilation fan and toilet extract fan.

2.0 CRITERIA

2.1 Local Authority Requirements

The London Borough of Camden's planning requirements in terms of noise are outlined in the Camden Local Plan (June 2017). For industrial and commercial noise sources the guidance states that a *"Level of 10dB below background (15dB if tonal components are present) should be considered as the design criterion"*. For smaller items of plant (e.g. condensers and extract ventilation) a specification of NR35dB or below as measured 1 meter from the façade of affected premises is also required.

2.2 Previous Reports

A noise assessment was originally carried out at the site by Sharps Redmore Acoustic Consultants in support of the planning application (report ref R1-15.7.15-Swains Lane-1515401-GJK, dated 15 July 2015).

The representative background sound level ($L_{A90,15\text{minute}}$) as measured by Sharps Redmore is 44dBA, measured on a Sunday morning when noise levels can reasonably be expected to be at their lowest within the proposed operational hours.

2.3 Summary

In line with the above requirements we would propose items of mechanical services be designed so that noise emissions from the plant do not exceed the following noise rating level when assessed at the nearest noise sensitive location:

- Operational Hours (07:00 – 20:00) 34 dBA
NR35 dB

3.0 ASSESSMENT

3.1 Plant

Proposed Plant

1No. SEL355/2 Kitchen Extract Fan

Existing Plant

1No. Toilet Extract Fan

1No. Roof-mounted Ventilation Fan

3.2 Position of Units

The kitchen extract fan is to be located within a brick outbuilding to the rear of the premises. The ductwork terminates at first floor level above the flat roof over the plant area. The toilet extract fan is ducted to outside by the rear door of the premises. The ventilation fan is roof-mounted within a cowed unit above the brick outhouse. The equipment positions are indicated on the attached Site Plan 8175/SP1.

3.3 Noise Levels

Information regarding the noise levels of the proposed plant has been provided by the manufacturer of the unit. The octave band sound power levels of the unit are detailed as follows:

Table 8175/T1 – Manufacturer's Noise Levels

Unit	Parameter	Sound Level (dB) at Octave Band Centre Frequency (Hz)						
		125	250	500	1k	2k	4k	8k
SEL355/2 Inlet	In-duct Lw	63	73	73	75	73	70	65
SEL355/2 Outlet	In-duct Lw	70	79	79	80	76	71	65
SEL355/2 Breakout	Lw	61	64	58	58	55	54	46

Review of the octave band data concludes that there are no tonal characteristics associated with the proposed plant.

3.4 Location of Nearest Residential Windows

The closest residential windows to the kitchen extract and ventilation plant belong to the first floor flat of 21 Swain's Lane, above Gail's, overlooking the plant area at a distance of approximately 4-5 meters. The toilet extract fan is closest to windows above the neighbouring property to the east.

3.5 Calculation of Noise Levels from Proposed Plant at Nearest Residential Window

Our calculation method for predicting noise levels from the proposed equipment at the nearest residential window, based on the information stated above, is summarised below. The fan is mounted internally so the structure of the building provides a high level of attenuation to the breakout noise level, which is therefore within the criteria. The duct-borne element has been assessed according to the following:

- Source Term SWL
- Duct Losses
- Distance Attenuation
- Directivity
- Reflections

The results of the calculations indicate a maximum noise level of 59dBA at the nearest affected residential windows. Noise from the proposed kitchen extract plant to the rear of the property is above the target criteria. We therefore recommend mitigation is included in the design and installation.

3.6 Mitigation

We recommend that an attenuator with the following minimum insertion losses be installed within the ductwork on the outlet (atmospheric) side:

Table 8175/T2 – Attenuator Minimum Insertion Losses

Minimum Insertion Loss [dB] at Octave Band Centre Frequency (Hz)							
63	125	250	500	1k	2k	4k	8k
5	10	16	25	34	34	29	22

The above specification could typically be achieved by a 900mm attenuator with 30% free area.

Adoption of an attenuator capable of achieving the above insertion losses would ensure that noise levels to the rear of the property are within the criteria required by the London Borough of Camden. The resultant predicted noise level at the nearest residential window would be 32dBA which equates to NR 27.

3.7 Existing Plant

To assess the impact of the existing plant RBA Acoustics attended site on Wednesday 26 July 2017 to measure noise from plant in operation. Due to the presence and operation of plant items serving nearby commercial premises and residences it was not possible to measure the specific sound level at the nearest noise-sensitive receptor (NSR). Therefore measurements were made of the plant in operation at 1m, and at positions representative of the nearest noise-sensitive receptors.

The toilet extract fan is fitted with an attenuator and was measured at the termination point whilst operating on full duty. It was subjectively inaudible at the termination point, making negligible change to the prevailing background noise level. Once distance losses and directionality are taken into account it is very unlikely that this item of plant will result in disturbance at the nearest assessment point; the lack of change in measured level indicating positively that the toilet extract fan is operating at 10dB below the background noise level.

The ventilation fan was also measured running on setting 2 (normal) and setting 1.

The noise climate in the absence of Gail's plant operating was dominated by plant from neighbouring commercial enterprises, plant serving residential flats, aircraft fly-bys and the surrounding road network. Therefore the real level of the operating plant could be slightly below that measured.

The noise levels measured are provided in Table 8175/T3:

Table 8175/T3 – Existing Plant – Measured Noise Levels

Unit	Parameter	Sound Level (dB) at Octave Band Centre Frequency (Hz)						
		125	250	500	1k	2k	4k	8k
Ventilation Fan (Setting 2)	L _p at 1m	54	47	41	39	32	30	25

The ventilation fan is within a cowl and approximately 5m from the nearest residential window resulting in a level of 31dBA at the nearest residential window. Both existing units therefore satisfy the London Borough of Camden noise criteria at the nearest noise-sensitive receptors. Subjectively the impact of the existing plant was negligible at the nearest noise-sensitive receptor.

4.0 CONCLUSION

Measurements of the background noise levels have been undertaken at Gail's Bakery, 21 Swain's Lane, Highgate, London N6 6QX. The noise levels of the proposed kitchen extract plant have been assessed in relation to the existing background noise climate, Local Authority criteria and the relevant standards. The kitchen extract is predicted to operate within reasonable limits and can be demonstrated as unlikely to cause complaint provided the mitigation measures suggested herein are installed. The existing plant is operating at a low noise level which, were it to be assessed as a new installation, would be demonstrated as operating within Local Authority Criteria.

Appendix A - Acoustic Terminology

dB	Decibel - Used as a measurement of sound pressure level. It is the logarithmic ratio of the noise being assessed to a standard reference level.
dB(A)	The human ear is more susceptible to mid-frequency noise than the high and low frequencies. To take account of this when measuring noise, the 'A' weighting scale is used so that the measured noise corresponds roughly to the overall level of noise that is discerned by the average human. It is also possible to calculate the 'A' weighted noise level by applying certain corrections to an un-weighted spectrum. The measured or calculated 'A' weighted noise level is known as the dB(A) level. Because of being a logarithmic scale noise levels in dB(A) do not have a linear relationship to each other. For similar noises, a change in noise level of 10dB(A) represents a doubling or halving of subjective loudness. A change of 3dB(A) is just perceptible.
L_{eq}	L_{eq} is defined as a notional steady sound level which, over a stated period of time, would contain the same amount of acoustical energy as the actual, fluctuating sound measured over that period (1 hour).
L_{Aeq}	The level of notional steady sound which, over a stated period of time, would have the same A-weighted acoustic energy as the A-weighted fluctuating noise measured over that period.
L_{An} (e.g. L_{A10} , L_{A90})	If a non-steady noise is to be described it is necessary to know both its level and the degree of fluctuation. The L_n indices are used for this purpose, and the term refers to the level exceeded for n% of the time, hence L_{10} is the level exceeded for 10% of the time and as such can be regarded as the 'average maximum level'. Similarly, L_{90} is the average minimum level and is often used to describe the background noise.
$L_{max,T}$	The instantaneous maximum sound pressure level which occurred during the measurement period, T. It is commonly used to measure the effect of very short duration bursts of noise, such as for example sudden bangs, shouts, car horns, emergency sirens etc. which audibly stand out from the general level of, say, traffic noise, but because of their very short duration, maybe only a very small fraction of a second, may not have any effect on the L_{eq} value.
Specific Sound Level	Equivalent continuous A-weighted sound pressure level produced by the specific sound source at the assessment location over a given reference time interval.
Rating level	Specific sound level plus any adjustment for the characteristic features of the sound.

Appendix B – Calculation


Unit	Octave-band Noise Levels								
	125	250	500	1000	2000	4000	8000		
Kitchen Extract at Termination Point (LW)	59	73	76	79	74	68	62		
Silencer	-10	-16	-25	-34	-34	-29	-22		
Directivity	-1	0	-1	-1	-6	-9	-9		
Reflections	3	3	3	3	3	3	3		
Sound Power to Sound Pressure Level	-11	-11	-11	-11	-11	-11	-11		
Distance Loss (4m)	-12	-12	-12	-12	-12	-12	-12	Overall (dBA)	NR
Noise Level at Receiver (Proposed Plant)	28	37	30	24	14	10	11	32	27
Noise Level at Receiver (Existing Plant)	40	33	27	25	18	16	11	31	25
Total Noise Level at Receiver	40	39	32	27	19	17	14	34	29

Appendix C – CDM Considerations

The following hazards pertinent to our design input have been identified and control measures suggested:

Hazard	Risk Of	At Risk	Rating			Control Measures	Controlled		
			L	S	R		L	S	R
Attenuators/ Acoustic Lagging/ Acoustic Screens	Strain of neck, limbs or back.	Contractors	3	4	12	Provide sufficient manpower/ lifting gear	1	4	4
Attenuators/ Acoustic Lagging/ Acoustic Screens	Skin and respiratory irritation	Contractors	4	3	12	Wear gloves and mask	1	3	3

L: Likelihood
S: Severity
R: Rating



Gail's Bakery, 21 Swains Lane, Highgate, London N6 6QX

Site Plan showing plant and assessment positions

Figure 8175/SP1

18 October 2017

Not to Scale

RBA ACOUSTICS

W. www.rba-acoustics.co.uk

E. info@rba-acoustics.co.uk

London:

44 Borough Road

London SE1 0AJ

T. +44 (0) 20 7620 1950

Manchester:

Lowry House, 17 Marble Street

Manchester M2 3AW

T. +44 (0) 16 1661 4504

