

Gentet, Matthias

From: BCTAdmin@thameswater.co.uk
Sent: 07 November 2017 15:13
To: Planning
Subject: 3rd Party Planning Application - 2017/4345/P - FURTHER INFO OCT27/17

London Borough of Camden
Camden Town Hall
OCT27/17
Argyle Street
Euston Road
London
WC1H 8EQ

Our DTS Ref: 42136
Your Ref: 2017/4345/P - FURTHER INFO

7 November 2017

Dear Sir/Madam

Re: 137 , 137 TORRIANO AVENUE, LONDON, N7

Waste Comments

Thames Water have reviewed the documentation provided and cannot agree to the discharging of Condition 6.

Water Comments

Supplementary Comments

The supplied plan indicates site drainage. It does not indicate surface water attenuation proposals to reduce the peak discharge rate of surface water entering the sewer system. Due to the size of the development we do not require details surface water discharge calculations but rudimentary attenuation assets.

Yours faithfully
Development Planning Department

Development Planning,
Thames Water,
Maple Lodge STW,
Denham Way,
Rickmansworth,
WD3 9SQ
Tel:020 3577 9998
Email: devcon.team@thameswater.co.uk

This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to
devcon.team@thameswater.co.uk