



Daylight and Sunlight

**29 New End, London**

Prepared by: Daniel Maddox

Reference: 4632

Date: 12/10/2017



DATE / REF

12/10/2017

DM/4632

ADDRESS

THE WHITEHOUSE  
BELVEDERE ROAD  
LONDON SE1 8GA

CONTACT

TEL 020 7202 1400

FAX 020 7202 1401

MAIL@GIA.UK.COM

WWW.GIA.UK.COM

## By Email


Mr G. Jefferys Esq  
KSR Architects LLP  
14 Greenland Street  
London  
NW1 0ND

Dear Gordon,

## Re: 29 New End, London - Daylight & Sunlight Comparison

GIA have been asked to undertake a detailed technical analysis of the comparison between the consented and proposed schemes for the 29 New End Site. The new application is for minor changes to the detail of the upper floors, with a negligible change to the actual mass of the building.

Images of the consented and proposed schemes can be seen in appendix two of this letter, with a view of the proposed scheme below.



## Comparison of Daylight and Sunlight Results.

### Vertical Sky Component - VSC

Of the 268 windows assessed for VSC, 157 would experience no change or improvements to their light when comparing the two schemes. 108 would experience less than 1% actual VSC change which is negligible and would be un-noticeable to the occupants of these properties. The remaining three windows would experience between 1.1% and 1.6% actual change, which is negligible in itself, but all would also retain a VSC level of over 30%+ which is not only a pass by BRE standards it is exceptionally high given the urban location of the site.

### *No Sky Line – NSL*

Of the 119 rooms assessed for NSL, 101 would experience no change or improvements to their light when comparing the two schemes. 17 would experience nothing more than a 3% alteration which is negligible and likely unnoticeable by an occupant. The remaining room would experience a 5.5% reduction in NSL, however it would retain a view of the sky to over 83% of the room area which is considered to be an exceptional level of daylight given the urban location of the site.

### *Sunlight – Annual Probable Sunlight Hours (APSH)*

Of the 44 rooms assessed for APSH, only six would experience minor alterations as a result of the proposed scheme, these six rooms would all still retain significantly in excess of the BRE recommended 25% annual APSH and 5% winter APSH.

### **Conclusion**

As can be seen from the above summary and the Daylight and Sunlight results contained within appendix 3, the difference between the consented scheme and the revised proposal are negligible when considering the impact on the amenity of the adjacent neighbours.

The revised scheme therefore causes no perceptible change to the daylight and sunlight amenity of the adjacent units when compared with the current consented scheme.

Hopefully the above is clear, but if you have any questions please feel free to contact me.

Kind regards,

Yours sincerely  
For and on behalf of GIA




Daniel Maddox  
**Associate Partner**  
[daniel.maddox@gia.uk.com](mailto:daniel.maddox@gia.uk.com)

Encl. Appendix 01 – Drawings  
Appendix 02 – Results

# Appendix 01

*Drawings*

*Consented*



SOURCES OF INFORMATION

KSR ARCHITECTS  
 IR13-4632  
 IR14-4632  
 IR15-4632  
 IR18-4632  
 RECEIVED 27/03/12

IR28-4632  
 15031 NEW END\_R16 - 3D VIEW.DWG

ALL INFORMATION DISPLAYED IS SUBJECT TO A COMPLETE VERIFIABLE SITE SURVEY BEING UNDERTAKEN. GIA TAKES NO RESPONSIBILITY ON THE ACCURACY OR RELIABILITY OF THE DISPLAYED DATA SINCE A VERIFIED SITE SURVEY WAS NOT MADE AVAILABLE PRIOR TO THE GENERATION OF SUCH INFORMATION.

 SITE BOUNDARY

NOTES:  
 CONSENTED SCHEME SHOWN IN CYAN

N.B. DO NOT SCALE OFF THIS DRAWING

PROJECT:  
**NEW END, HAMPSTEAD  
 LONDON NW3**


DRAWING NAME:  
 PLAN VIEW  
 CONSENTED SCHEME IR18  
 RECEIVED 27.03.2012

DWN BY	SCALE	CHK BY	STATUS	DATE
BG	1:400 @A3	AH	-	AUG 17
PROJ No.	REL No.	IS No.	DWG No.	REV No.
4632	19	01	04	-

**gia**  
 LONDON • MANCHESTER

The Whitehouse  
 Belvedere Road  
 London SE1 8GA  
 t 020 7202 1400  
 f 020 7202 1401  
 mail@gia.uk.com  
 www.gia.uk.com

 PLAN VIEW  
 SCALE 1:400 @A3



SOURCES OF INFORMATION

KSR ARCHITECTS  
 IR13-4632  
 IR14-4632  
 IR15-4632  
 IR18-4632  
 RECEIVED 27/03/12

IR28-4632  
 15031 NEW\_END\_R16 - 3D VIEW.DWG

ALL INFORMATION DISPLAYED IS SUBJECT TO A COMPLETE VERIFIABLE SITE SURVEY BEING UNDERTAKEN. GIA TAKES NO RESPONSIBILITY ON THE ACCURACY OR RELIABILITY OF THE DISPLAYED DATA. SINCE A VERIFIED SITE SURVEY WAS NOT MADE AVAILABLE PRIOR TO THE GENERATION OF SUCH INFORMATION.

NOTES:  
 CONSENTED SCHEME SHOWN IN CYAN

N.B. DO NOT SCALE OFF THIS DRAWING

PROJECT:  
**NEW END, HAMPSTEAD  
 LONDON NW3**

DRAWING NAME:  
 3D VIEW  
 CONSENTED SCHEME IR18  
 RECEIVED 27.03.2012


DWN BY	SCALE	CHK BY	STATUS	DATE
BG	NTS @A3	AH	-	AUG 17
PROJ No.	REL No.	IS No.	DWG No.	REV No.
4632	19	01	05	-



The Whitehouse  
 Belvedere Road  
 London SE1 8GA  
 t 020 7202 1400  
 f 020 7202 1401  
 mail@gia.uk.com  
 www.gia.uk.com

LONDON • MANCHESTER

3D VIEW  
 NTS @A3



SOURCES OF INFORMATION

KSR ARCHITECTS  
 IR13-4632  
 IR14-4632  
 IR15-4632  
 IR18-4632  
 RECEIVED 27/03/12

IR28-4632  
 15031 NEW\_END\_R16 - 3D VIEW.DWG

ALL INFORMATION DISPLAYED IS SUBJECT TO A COMPLETE VERIFIABLE SITE SURVEY BEING UNDERTAKEN. GIA TAKES NO RESPONSIBILITY ON THE ACCURACY OR RELIABILITY OF THE DISPLAYED DATA. SINCE A VERIFIED SITE SURVEY WAS NOT MADE AVAILABLE PRIOR TO THE GENERATION OF SUCH INFORMATION.

NOTES:  
 CONSENTED SCHEME SHOWN IN CYAN

N.B. DO NOT SCALE OFF THIS DRAWING  
 PROJECT:  
**NEW END, HAMPSTEAD  
 LONDON NW3**

DRAWING NAME:  
 3D VIEW  
 CONSENTED SCHEME IR18  
 RECEIVED 27.03.2012

DWN BY	SCALE	CHK BY	STATUS	DATE
BG	NTS @A3	AH	-	AUG 17
PROJ No.	REL No.	IS No.	DWG No.	REV No.
4632	19	01	06	-


**gia**  
 LONDON • MANCHESTER

The Whitehouse  
 Belvedere Road  
 London SE1 8GA  
 t 020 7202 1400  
 f 020 7202 1401  
 mail@gia.uk.com  
 www.gia.uk.com

3D VIEW  
 NTS @A3



*Proposed*



SOURCES OF INFORMATION

KSR ARCHITECTS  
 IR13-4632  
 IR14-4632  
 IR15-4632  
 IR18-4632  
 RECEIVED 27/03/12

IR28-4632  
 15031 NEW END\_R16 - 3D VIEW.DWG

ALL INFORMATION DISPLAYED IS SUBJECT TO A COMPLETE VERIFIABLE SITE SURVEY BEING UNDERTAKEN. GIA TAKES NO RESPONSIBILITY ON THE ACCURACY OR RELIABILITY OF THE DISPLAYED DATA SINCE A VERIFIED SITE SURVEY WAS NOT MADE AVAILABLE PRIOR TO THE GENERATION OF SUCH INFORMATION.

 SITE BOUNDARY

NOTES:  
 PROPOSED SCHEME SHOWN IN BLUE

N.B. DO NOT SCALE OFF THIS DRAWING

PROJECT:  
**NEW END, HAMPSTEAD  
 LONDON NW3**

DRAWING NAME:  
 PLAN VIEW  
 PROPOSED SCHEME IR28

DWN BY	SCALE	CHK BY	STATUS	DATE
BG	1:400 @A3	AH	-	AUG 17
PROJ No.	REL No.	IS No.	DWG No.	REV No.
4632	19	01	07	-



The Whitehouse  
 Belvedere Road  
 London SE1 8GA  
 t 020 7202 1400  
 f 020 7202 1401  
 mail@gia.uk.com  
 www.gia.uk.com

LONDON • MANCHESTER

 PLAN VIEW  
 SCALE 1:400 @A3



SOURCES OF INFORMATION

KSR ARCHITECTS  
 IR13-4632  
 IR14-4632  
 IR15-4632  
 IR18-4632  
 RECEIVED 27/03/12

IR28-4632  
 15031 NEW\_END\_R16 - 3D VIEW.DWG

ALL INFORMATION DISPLAYED IS SUBJECT TO A COMPLETE VERIFIABLE SITE SURVEY BEING UNDERTAKEN. GIA TAKES NO RESPONSIBILITY ON THE ACCURACY OR RELIABILITY OF THE DISPLAYED DATA. SINCE A VERIFIED SITE SURVEY WAS NOT MADE AVAILABLE PRIOR TO THE GENERATION OF SUCH INFORMATION.

NOTES:  
 PROPOSED SCHEME SHOWN IN BLUE

N.B. DO NOT SCALE OFF THIS DRAWING


PROJECT:  
**NEW END, HAMPSTEAD  
 LONDON NW3**

DRAWING NAME:  
 3D VIEW  
 PROPOSED SCHEME IR28

DWN BY	SCALE	CHK BY	STATUS	DATE
BG	NTS @A3	AH	-	AUG 17
PROJ No.	REL No.	IS No.	DWG No.	REV No.
4632	19	01	08	-

**gia**  
 The Whitehouse  
 Belvedere Road  
 London SE1 8GA  
 t 020 7202 1400  
 f 020 7202 1401  
 mail@gia.uk.com  
 www.gia.uk.com  
 LONDON • MANCHESTER

3D VIEW  
 NTS @A3



SOURCES OF INFORMATION

KSR ARCHITECTS  
 IR13-4632  
 IR14-4632  
 IR15-4632  
 IR18-4632  
 RECEIVED 27/03/12

IR28-4632  
 15031 NEW END\_R16 - 3D VIEW.DWG

ALL INFORMATION DISPLAYED IS SUBJECT TO A COMPLETE VERIFIABLE SITE SURVEY BEING UNDERTAKEN. GIA TAKES NO RESPONSIBILITY ON THE ACCURACY OR RELIABILITY OF THE DISPLAYED DATA. SINCE A VERIFIED SITE SURVEY WAS NOT MADE AVAILABLE PRIOR TO THE GENERATION OF SUCH INFORMATION.

NOTES:  
 PROPOSED SCHEME SHOWN IN BLUE

N.B. DO NOT SCALE OFF THIS DRAWING

PROJECT:  
**NEW END, HAMPSTEAD  
 LONDON NW3**

DRAWING NAME:  
 3D VIEW  
 PROPOSED SCHEME IR28

DWN BY	SCALE	CHK BY	STATUS	DATE
BG	NTS @A3	AH	-	AUG 17
PROJ No.	REL No.	IS No.	DWG No.	REV No.
4632	19	01	09	-



The Whitehouse  
 Belvedere Road  
 London SE1 8GA  
 t 020 7202 1400  
 f 020 7202 1401  
 mail@gia.uk.com  
 www.gia.uk.com

LONDON • MANCHESTER

3D VIEW  
 NTS @A3

# Appendix 02

*Daylight and Sunlight  
Results*

*Vertical Sky Component (VSC)*

**VERTICAL SKY COMPONENT**

FLOOR	ROOM	ROOM USE	WINDOW	CONSENTED	PROPOSED	LOSS	%
<b>11 HAMPSTEAD SQUARE</b>							
299	R1	ASSUMED	W1	22.6	22.6	0.0	0.00
			W2	26.9	26.9	0.0	0.00
			W3	27.1	27.1	0.0	0.00
			W4	29.2	29.2	0.0	0.00
			W5	28.0	27.9	0.1	0.36
			W6	20.8	20.6	0.2	0.96
	R2	ASSUMED	W7	24.6	24.6	0.0	0.00
			W8	26.4	26.2	0.2	0.76
			W9	25.1	24.9	0.2	0.80
			W10	24.4	24.2	0.2	0.82
			W11	21.9	21.8	0.1	0.46
			W12	16.0	16.0	0.0	0.00
	R3	UNKNOWN	W13	21.7	21.6	0.1	0.46
	R4	UNKNOWN	W14	13.2	13.2	0.0	0.00
300	R1	UNKNOWN	W1	32.5	32.5	0.0	0.00
			W2	32.3	32.2	0.1	0.31
			W3	24.8	24.6	0.2	0.81
			W16	25.1	25.1	0.0	0.00
			W17	30.0	30.0	0.0	0.00
			W18	29.9	29.9	0.0	0.00
	R2	UNKNOWN	W4	27.4	27.4	0.0	0.00
			W5	31.0	30.8	0.2	0.65
			W6	30.8	30.5	0.3	0.97
			W7	31.3	31.0	0.3	0.96
			W8	31.1	30.9	0.2	0.64
			W9	21.4	21.4	0.0	0.00
301	R1	UNKNOWN	W1	34.7	34.7	0.0	0.00
			W2	35.2	35.1	0.1	0.28
			W3	28.6	28.3	0.3	1.05
	R2	UNKNOWN	W4	30.8	30.8	0.0	0.00
			W5	34.4	34.2	0.2	0.58
			W6	34.0	33.6	0.4	1.18
			W7	34.1	33.8	0.3	0.88
			W8	33.7	33.5	0.2	0.59
			W9	24.6	24.6	0.0	0.00
302	R1	UNKNOWN	W1	35.9	35.7	0.2	0.56
			W3	37.5	37.3	0.2	0.53
	R2	UNKNOWN	W2	35.5	35.4	0.1	0.28
310	R1	UNKNOWN	W1	30.6	30.5	0.1	0.33
<b>11 HAMPSTEAD SQUARE (CONT.)</b>							
311 (CONT.)	R2	UNKNOWN	W2	17.9	18.0	-0.1	-0.56
311	R1	UNKNOWN	W1	32.7	32.5	0.2	0.61
	R2	UNKNOWN	W2	19.0	19.0	0.0	0.00
<b>10 HAMPSTEAD SQUARE</b>							
299	R1	UNKNOWN	W1	22.2	22.1	0.1	0.45
			W2	21.8	21.7	0.1	0.46
	R2	ASSUMED	W3	18.9	18.8	0.1	0.53
			W4	20.8	20.8	0.0	0.00
			W5	20.5	20.5	0.0	0.00
			W6	23.0	23.0	0.0	0.00
			W7	33.2	33.2	0.0	0.00
			W8	31.5	31.5	0.0	0.00
300	R3	UNKNOWN	W10	24.0	23.9	0.1	0.42
			W11	27.9	27.8	0.1	0.36
			W12	26.0	26.0	0.0	0.00
			W13	27.1	27.1	0.0	0.00
			W14	35.0	35.0	0.0	0.00
301	R3	UNKNOWN	W10	26.8	26.6	0.2	0.75
			W11	31.3	31.2	0.1	0.32
			W12	30.4	30.4	0.0	0.00
			W13	30.6	30.6	0.0	0.00
			W14	36.3	36.3	0.0	0.00
			W15	33.9	33.9	0.0	0.00

<sup>1</sup> KITCHEN SMALLER THAN 13M<sup>2</sup>

**VERTICAL SKY COMPONENT**

FLOOR	ROOM	ROOM USE	WINDOW	CONSENTED	PROPOSED	LOSS	%
302	R3	UNKNOWN	W3	35.0	34.9	0.1	0.29
	R4	UNKNOWN	W4	34.8	34.6	0.2	0.57
			W5	37.5	37.5	0.0	0.00
310	R3	UNKNOWN	W3	30.0	29.9	0.1	0.33
			W4	29.5	29.4	0.1	0.34
311	R3	UNKNOWN	W3	32.0	31.9	0.1	0.31
			W4	31.5	31.4	0.1	0.32

**CHRIST CHURCH- HAMPSTEAD SQUARE**

400	R1	UNKNOWN	W1	32.4	32.4	0.0	0.00
			W2	30.7	30.6	0.1	0.33
			W3	32.2	32.1	0.1	0.31
			W4	32.9	32.8	0.1	0.30
			W5	33.3	33.2	0.1	0.30
			W6	33.6	33.5	0.1	0.30
			W7	34.8	34.8	0.0	0.00
			W8	33.3	33.2	0.1	0.30
			W9	33.3	33.2	0.1	0.30
			W10	35.6	35.6	0.0	0.00

**CHRIST CHURCH PRIMARY SCHOOL- CHRISTCHURCH HILL**

500	R1	UNKNOWN	W1	27.3	27.2	0.1	0.37
501	R1	UNKNOWN	W1	16.4	16.4	0.0	0.00
			W3	20.9	20.9	0.0	0.00
			W4	16.9	16.8	0.1	0.59
			W5	32.1	32.0	0.1	0.31
502	R1	UNKNOWN	W1	19.7	19.6	0.1	0.51
			W2	21.0	20.9	0.1	0.48
			W3	35.7	35.6	0.1	0.28

**CHRIST CHURCH COTTAGE- CHRISTCHURCH PASSAGE**

599	R1	UNKNOWN	W1	22.3	22.2	0.1	0.45
600	R1	UNKNOWN	W1	25.0	24.8	0.2	0.80
			W2	24.6	24.5	0.1	0.41
			W4	22.3	22.2	0.1	0.45
	R3	KITCHEN <sup>1</sup>	W5	26.5	26.3	0.2	0.75
			W6	22.8	22.6	0.2	0.88
			W4	22.3	22.2	0.1	0.45
601	R1	UNKNOWN	W1	34.3	34.3	0.0	0.00
			W2	26.9	26.8	0.1	0.37
			W3	26.6	26.5	0.1	0.38
	R2	UNKNOWN	W4	26.0	25.9	0.1	0.38
	R3	BEDROOM	W5	23.9	23.7	0.2	0.84

**1-9 CARNEGIE HOUSE- CHRISTCHURCH PASSAGE**

700	R1	UNKNOWN	W6	22.7	22.6	0.1	0.44
			W7	23.5	23.5	0.0	0.00
			W8	26.9	27.0	-0.1	-0.37
700	R2	UNKNOWN	W5	21.8	21.8	0.0	0.00

**1-9 CARNEGIE HOUSE- CHRISTCHURCH PASSAGE (CONT.)**

700 (CONT.)	R3	UNKNOWN	W4	20.0	19.9	0.1	0.50
	R4	UNKNOWN	W2	19.2	19.2	0.0	0.00
			W3	19.8	19.7	0.1	0.51
	R5	UNKNOWN	W1	15.5	15.4	0.1	0.65
701	R1	UNKNOWN	W12	27.1	27.1	0.0	0.00
			W13	30.8	30.8	0.0	0.00
			W11	26.4	26.4	0.0	0.00
	R3	UNKNOWN	W10	25.5	25.5	0.0	0.00
	R4	UNKNOWN	W8	14.5	14.4	0.1	0.69
			W9	22.6	22.5	0.1	0.44
			W6	21.8	21.7	0.1	0.46
	R5	UNKNOWN	W7	21.3	21.2	0.1	0.47
			W4	20.4	20.2	0.2	0.98
	R6	UNKNOWN	W5	16.2	16.1	0.1	0.62
			W2	11.4	11.2	0.2	1.75
			W3	20.4	20.2	0.2	0.98
			W3	20.4	20.2	0.2	0.98

<sup>1</sup> KITCHEN SMALLER THAN 13M<sup>2</sup>



**VERTICAL SKY COMPONENT**

FLOOR	ROOM	ROOM USE	WINDOW	CONSENTED	PROPOSED	LOSS	%
	R8	UNKNOWN	W1	18.7	18.5	0.2	1.07
702	R1	UNKNOWN	W12	29.8	29.8	0.0	0.00
			W13	34.4	34.4	0.0	0.00
	R2	UNKNOWN	W11	29.1	29.1	0.0	0.00
	R3	UNKNOWN	W10	28.5	28.4	0.1	0.35
	R4	UNKNOWN	W8	26.5	26.4	0.1	0.38
			W9	27.7	27.6	0.1	0.36
	R5	UNKNOWN	W6	25.6	25.5	0.1	0.39
			W7	26.3	26.2	0.1	0.38
	R6	UNKNOWN	W4	24.7	24.5	0.2	0.81
			W5	24.6	24.4	0.2	0.81
	R7	UNKNOWN	W2	23.6	23.4	0.2	0.85
			W3	24.4	24.2	0.2	0.82
	R8	UNKNOWN	W1	23.7	23.5	0.2	0.84
703	R1	UNKNOWN	W12	32.4	32.3	0.1	0.31
			W13	37.6	37.6	0.0	0.00
	R2	UNKNOWN	W11	31.8	31.7	0.1	0.31
	R3	UNKNOWN	W10	31.2	31.1	0.1	0.32
	R4	UNKNOWN	W8	30.0	29.9	0.1	0.33
			W9	30.6	30.5	0.1	0.33
	R5	UNKNOWN	W6	28.9	28.7	0.2	0.69
			W7	29.4	29.2	0.2	0.68
	R6	UNKNOWN	W4	28.0	27.8	0.2	0.71
			W5	28.3	28.1	0.2	0.71
<b>1-9 CARNEGIE HOUSE- CHRISTCHURCH PASSAGE (CONT.)</b>							
703 (CONT.)	R7	UNKNOWN	W2	27.7	27.4	0.3	1.08
			W3	27.8	27.5	0.3	1.08
	R8	UNKNOWN	W1	27.6	27.3	0.3	1.09
<b>10-14 NEW END</b>							
800	R1	UNKNOWN	W1	10.6	10.6	0.0	0.00
			W2	9.2	9.2	0.0	0.00
	R2	UNKNOWN	W3	8.0	8.0	0.0	0.00
			W4	8.4	8.4	0.0	0.00
	R3	UNKNOWN	W5	8.4	8.4	0.0	0.00
			W6	9.8	9.8	0.0	0.00
801	R1	UNKNOWN	W1	23.6	23.6	0.0	0.00
			W2	24.3	24.3	0.0	0.00
	R2	UNKNOWN	W3	25.2	25.3	-0.1	-0.40
			W4	25.3	25.4	-0.1	-0.40
	R3	UNKNOWN	W5	25.6	25.6	0.0	0.00
			W6	25.6	25.6	0.0	0.00
	R4	UNKNOWN	W7	10.0	10.0	0.0	0.00
			W8	9.9	9.9	0.0	0.00
	R5	UNKNOWN	W9	10.0	10.1	-0.1	-1.00
			W10	10.0	10.0	0.0	0.00
	R6	UNKNOWN	W11	9.8	9.8	0.0	0.00
			W12	9.8	9.8	0.0	0.00
802	R1	UNKNOWN	W1	27.6	27.6	0.0	0.00
			W2	28.5	28.5	0.0	0.00
			W3	28.8	28.8	0.0	0.00
	R2	UNKNOWN	W4	29.1	29.1	0.0	0.00
			W5	29.1	29.2	-0.1	-0.34
			W6	29.2	29.2	0.0	0.00
	R3	UNKNOWN	W7	29.2	29.2	0.0	0.00
			W8	29.1	29.2	-0.1	-0.34
			W9	29.0	29.0	0.0	0.00
803	R1	UNKNOWN	W1	31.7	31.7	0.0	0.00
			W2	32.2	32.2	0.0	0.00
			W3	32.3	32.2	0.1	0.31
	R2	UNKNOWN	W4	32.3	32.3	0.0	0.00
			W5	32.3	32.3	0.0	0.00
			W6	32.2	32.2	0.0	0.00

<sup>1</sup> KITCHEN SMALLER THAN 13M<sup>2</sup>

**VERTICAL SKY COMPONENT**

FLOOR	ROOM	ROOM USE	WINDOW	CONSENTED	PROPOSED	LOSS	%
<b>10-14 NEW END (CONT.)</b>							
804 (CONT.)	R3	UNKNOWN	W7	32.1	32.1	0.0	0.00
			W8	32.0	32.0	0.0	0.00
			W9	31.8	31.8	0.0	0.00
804	R1	UNKNOWN	W1	35.7	35.6	0.1	0.28
			W2	35.6	35.5	0.1	0.28
			W3	35.4	35.4	0.0	0.00
	R2	UNKNOWN	W4	35.3	35.2	0.1	0.28
			W5	35.1	35.1	0.0	0.00
			W6	35.0	34.9	0.1	0.29
	R3	UNKNOWN	W7	34.8	34.7	0.1	0.29
			W8	34.6	34.5	0.1	0.29
			W9	34.3	34.3	0.0	0.00
<b>7-9 NEW END</b>							
900	R1	UNKNOWN	W1	8.8	8.8	0.0	0.00
	R2	UNKNOWN	W2	2.8	2.8	0.0	0.00
	R3	UNKNOWN	W3	6.4	6.4	0.0	0.00
901	R1	UNKNOWN	W1	25.6	25.7	-0.1	-0.39
	R2	UNKNOWN	W2	25.9	26.0	-0.1	-0.39
	R3	UNKNOWN	W3	21.4	21.5	-0.1	-0.47
	R4	UNKNOWN	W4	24.9	25.0	-0.1	-0.40
	R5	UNKNOWN	W5	23.6	23.7	-0.1	-0.42
	R6	UNKNOWN	W6	24.9	24.9	0.0	0.00
			W10	15.0	15.0	0.0	0.00
	R7	UNKNOWN	W7	21.2	21.2	0.0	0.00
	R8	UNKNOWN	W8	25.9	25.9	0.0	0.00
R9	UNKNOWN	W9	24.9	24.9	0.0	0.00	
902	R1	UNKNOWN	W1	28.5	28.5	0.0	0.00
	R2	UNKNOWN	W2	28.4	28.4	0.0	0.00
			W3	24.1	24.1	0.0	0.00
			W4	28.9	29.0	-0.1	-0.35
	R3	UNKNOWN	W5	29.1	29.2	-0.1	-0.34
			W11	17.8	17.8	0.0	0.00
			W6	29.2	29.2	0.0	0.00
	R4	UNKNOWN	W7	29.2	29.2	0.0	0.00
			W12	17.7	17.7	0.0	0.00
			W8	24.5	24.5	0.0	0.00
	R5	UNKNOWN	W9	28.9	28.9	0.0	0.00
			W10	29.1	29.1	0.0	0.00
R6	UNKNOWN	W10	29.1	29.1	0.0	0.00	
903	R1	UNKNOWN	W1	30.7	30.7	0.0	0.00
<b>7-9 NEW END (CONT.)</b>							
903 (CONT.)	R2	UNKNOWN	W2	29.8	29.9	-0.1	-0.34
			W3	24.1	24.1	0.0	0.00
			W4	29.9	30.0	-0.1	-0.33
	R3	UNKNOWN	W5	30.0	30.0	0.0	0.00
			W11	18.3	18.4	-0.1	-0.55
			W6	30.0	30.0	0.0	0.00
	R4	UNKNOWN	W7	30.2	30.3	-0.1	-0.33
			W12	18.6	18.6	0.0	0.00
			W8	24.5	24.4	0.1	0.41
	R5	UNKNOWN	W9	30.3	30.3	0.0	0.00
			W10	30.8	30.8	0.0	0.00
	910	R1	UNKNOWN	W1	23.8	23.9	-0.1
W2				26.8	26.9	-0.1	-0.37
R3		UNKNOWN	W3	25.0	25.0	0.0	0.00
			W4	24.7	24.7	0.0	0.00
911	R1	UNKNOWN	W1	27.3	27.4	-0.1	-0.37
			W2	29.1	29.2	-0.1	-0.34
			W3	29.3	29.3	0.0	0.00
	R3	UNKNOWN	W4	29.7	29.7	0.0	0.00
			W5	29.8	29.8	0.0	0.00
			W6	29.5	29.5	0.0	0.00

<sup>1</sup> KITCHEN SMALLER THAN 13M<sup>2</sup>

**VERTICAL SKY COMPONENT**

FLOOR	ROOM	ROOM USE	WINDOW	CONSENTED	PROPOSED	LOSS	%
<b>NEW END THEATRE- 27 NEW END</b>							
100	R1	UNKNOWN	W1	19.7	19.7	0.0	0.00
			W2	23.6	23.7	-0.1	-0.42
101	R1	UNKNOWN	W1	25.1	25.2	-0.1	-0.40
			W2	61.7	61.7	0.0	0.00
<b>LAWN HOUSE- HAMPSTEAD SQUARE</b>							
200	R1	KD	W1	23.5	23.6	-0.1	-0.43
			W2	14.5	15.3	-0.8	-5.52
			W3	19.6	19.6	0.0	0.00
			W4	22.1	22.1	0.0	0.00
	R2	UNKNOWN	W5	30.1	30.2	-0.1	-0.33
			W6	29.8	29.9	-0.1	-0.34
201	R2	DINING	W1	29.4	29.4	0.0	0.00
			W2	27.6	27.6	0.0	0.00
<b>LAWN HOUSE- HAMPSTEAD SQUARE (CONT.)</b>							
202 (CONT.)	R3	OFFICE	W4	27.3	27.3	0.0	0.00
			W5	33.2	33.2	0.0	0.00
			W6	18.2	17.7	0.5	2.75
202	R2	BEDROOM	W1	28.5	27.5	1.0	3.51
			W2	32.6	32.6	0.0	0.00
			W3	32.5	32.5	0.0	0.00
	R3	BEDROOM	W5	35.6	35.6	0.0	0.00
			W6	37.5	37.5	0.0	0.00
			W7	22.6	22.6	0.0	0.00
			W8	22.6	22.6	0.0	0.00
203	R1	ASSUMED	W4	36.8	36.8	0.0	0.00
			W5	38.4	38.4	0.0	0.00
			W6	31.7	31.6	0.1	0.32
	R2	ASSUMED	W3	34.9	34.8	0.1	0.29
			W1	35.0	35.0	0.0	0.00
	R3	ASSUMED	W2	34.9	34.9	0.0	0.00
			W7	32.9	31.5	1.4	4.26
			W8	33.4	32.2	1.2	3.59
210	R1	ASSUMED	W1	37.9	37.7	0.2	0.53
			W2	31.7	30.1	1.6	5.05

<sup>1</sup> KITCHEN SMALLER THAN 13M<sup>2</sup>

*No Skyline (NSL)*

NO SKY LINE						
FLOOR	ROOM	ROOM USE	CONSENTED	PROPOSED	LOSS	%
<b>11 HAMPSTEAD SQUARE</b>						
299	R1	ASSUMED	99.9	99.9	0.0	0.00
	R2	ASSUMED	99.7	99.7	0.0	0.00
	R3	UNKNOWN	89.8	89.8	0.0	0.00
	R4	UNKNOWN	94.9	94.9	0.0	0.00
300	R1	UNKNOWN	99.9	99.9	0.0	0.00
	R2	UNKNOWN	99.7	99.7	0.0	0.00
301	R1	UNKNOWN	99.3	99.3	0.0	0.00
	R2	UNKNOWN	99.7	99.7	0.0	0.00
302	R1	UNKNOWN	99.4	99.4	0.0	0.00
	R2	UNKNOWN	97.4	97.4	0.0	0.00
310	R1	UNKNOWN	98.0	98.0	0.0	0.00
	R2	UNKNOWN	95.1	95.1	0.0	0.00
311	R1	UNKNOWN	98.7	98.7	0.0	0.00
	R2	UNKNOWN	95.9	95.9	0.0	0.00
<b>10 HAMPSTEAD SQUARE</b>						
299	R1	UNKNOWN	98.1	98.1	0.0	0.00
	R2	ASSUMED	99.8	99.8	0.0	0.00
300	R3	UNKNOWN	99.8	99.8	0.0	0.00
301	R3	UNKNOWN	99.8	99.8	0.0	0.00
302	R3	UNKNOWN	97.3	97.3	0.0	0.00
	R4	UNKNOWN	99.2	99.2	0.0	0.00
310	R3	UNKNOWN	98.1	98.1	0.0	0.00
311	R3	UNKNOWN	98.9	98.9	0.0	0.00
<b>CHRIST CHURCH- HAMPSTEAD SQUARE</b>						
400	R1	UNKNOWN	99.7	99.7	0.0	0.00
<b>CHRIST CHURCH PRIMARY SCHOOL- CHRISTCHURCH HILL</b>						
500	R1	UNKNOWN	97.9	97.9	0.0	0.00
501	R1	UNKNOWN	99.5	99.5	0.0	0.00
502	R1	UNKNOWN	97.1	97.1	0.0	0.00
<b>CHRIST CHURCH COTTAGE- CHRISTCHURCH PASSAGE</b>						
599	R1	UNKNOWN	69.4	69.1	0.3	0.43
600	R1	UNKNOWN	96.3	96.3	0.0	0.00
	R3	KITCHEN <sup>1</sup>	97.5	97.5	0.0	0.00
601	R1	UNKNOWN	98.8	98.8	0.0	0.00
	R2	UNKNOWN	97.8	97.8	0.0	0.00
	R3	BEDROOM	84.5	84.1	0.4	0.47
<b>1-9 CARNEGIE HOUSE- CHRISTCHURCH PASSAGE</b>						
700	R1	UNKNOWN	95.3	95.3	0.0	0.00
	R2	UNKNOWN	49.9	49.6	0.3	0.60
	R3	UNKNOWN	59.2	58.5	0.7	1.18
	R4	UNKNOWN	65.9	64.8	1.1	1.67
	R5	UNKNOWN	32.0	32.0	0.0	0.00
701	R1	UNKNOWN	95.7	95.6	0.1	0.10
	R2	UNKNOWN	77.9	78.8	-0.9	-1.16
	R3	UNKNOWN	81.1	81.6	-0.5	-0.62
	R4	UNKNOWN	85.2	85.2	0.0	0.00
	R5	UNKNOWN	82.4	82.4	0.0	0.00
	R6	UNKNOWN	86.1	86.2	-0.1	-0.12
	R7	UNKNOWN	76.4	77.0	-0.6	-0.79

<sup>1</sup> KITCHEN SMALLER THAN 13M<sup>2</sup>

NO SKY LINE						
FLOOR	ROOM	ROOM USE	CONSENTED	PROPOSED	LOSS	%
<b>1-9 CARNEGIE HOUSE- CHRISTCHURCH PASSAGE (CONT.)</b>						
702 (CONT.)	R8	UNKNOWN	54.1	53.7	0.4	0.74
702	R1	UNKNOWN	96.2	96.2	0.0	0.00
	R2	UNKNOWN	84.9	85.4	-0.5	-0.59
	R3	UNKNOWN	80.0	80.6	-0.6	-0.75
	R4	UNKNOWN	94.0	94.3	-0.3	-0.32
	R5	UNKNOWN	87.1	87.2	-0.1	-0.11
	R6	UNKNOWN	89.5	89.8	-0.3	-0.34
	R7	UNKNOWN	84.2	84.3	-0.1	-0.12
	R8	UNKNOWN	67.0	65.0	2.0	2.99
703	R1	UNKNOWN	97.5	97.0	0.5	0.51
	R2	UNKNOWN	93.8	93.4	0.4	0.43
	R3	UNKNOWN	95.0	95.1	-0.1	-0.11
	R4	UNKNOWN	96.3	95.9	0.4	0.42
	R5	UNKNOWN	96.0	94.8	1.2	1.25
	R6	UNKNOWN	96.6	95.5	1.1	1.14
	R7	UNKNOWN	95.7	94.1	1.6	1.67
	R8	UNKNOWN	87.9	83.1	4.8	5.46
<b>10-14 NEW END</b>						
800	R1	UNKNOWN	74.1	74.1	0.0	0.00
	R2	UNKNOWN	83.3	83.4	-0.1	-0.12
	R3	UNKNOWN	98.0	98.0	0.0	0.00
801	R1	UNKNOWN	95.5	95.5	0.0	0.00
	R2	UNKNOWN	98.4	98.4	0.0	0.00
	R3	UNKNOWN	97.9	97.9	0.0	0.00
	R4	UNKNOWN	58.3	58.3	0.0	0.00
	R5	UNKNOWN	63.0	63.0	0.0	0.00
	R6	UNKNOWN	59.1	59.3	-0.2	-0.34
802	R1	UNKNOWN	97.9	97.9	0.0	0.00
	R2	UNKNOWN	98.2	98.2	0.0	0.00
	R3	UNKNOWN	98.2	98.2	0.0	0.00
803	R1	UNKNOWN	98.6	98.6	0.0	0.00
	R2	UNKNOWN	99.1	99.1	0.0	0.00
	R3	UNKNOWN	99.2	99.2	0.0	0.00
804	R1	UNKNOWN	99.4	99.4	0.0	0.00
	R2	UNKNOWN	99.6	99.6	0.0	0.00
	R3	UNKNOWN	99.7	99.7	0.0	0.00
<b>7-9 NEW END</b>						
900	R1	UNKNOWN	88.1	88.4	-0.3	-0.34
	R2	UNKNOWN	54.5	54.6	-0.1	-0.18
	R3	UNKNOWN	62.2	62.3	-0.1	-0.16
901	R1	UNKNOWN	89.8	90.3	-0.5	-0.56
	R2	UNKNOWN	80.3	80.9	-0.6	-0.75
	R3	UNKNOWN	89.9	90.5	-0.6	-0.67
	R4	UNKNOWN	88.9	89.5	-0.6	-0.67
	R5	UNKNOWN	83.6	84.5	-0.9	-1.08
	R6	UNKNOWN	90.1	90.4	-0.3	-0.33
	R7	UNKNOWN	97.0	97.0	0.0	0.00
	R8	UNKNOWN	89.2	89.2	0.0	0.00
	R9	UNKNOWN	98.1	98.1	0.0	0.00
902	R1	UNKNOWN	97.8	97.8	0.0	0.00
	R2	UNKNOWN	97.7	97.7	0.0	0.00
	R3	UNKNOWN	97.3	97.3	0.0	0.00
	R4	UNKNOWN	97.4	97.4	0.0	0.00
	R5	UNKNOWN	97.7	97.7	0.0	0.00
	R6	UNKNOWN	97.8	97.8	0.0	0.00
903	R1	UNKNOWN	74.6	74.8	-0.2	-0.27
	R2	UNKNOWN	98.5	98.5	0.0	0.00
	R3	UNKNOWN	98.2	98.2	0.0	0.00
	R4	UNKNOWN	98.1	98.2	-0.1	-0.10
	R5	UNKNOWN	98.4	98.4	0.0	0.00

<sup>1</sup> KITCHEN SMALLER THAN 13M<sup>2</sup>

NO SKY LINE						
FLOOR	ROOM	ROOM USE	CONSENTED	PROPOSED	LOSS	%
7-9 NEW END (CONT.)						
910 (CONT.)	R6	UNKNOWN	98.6	98.6	0.0	0.00
910	R1	UNKNOWN	87.0	87.0	0.0	0.00
	R3	UNKNOWN	97.2	97.2	0.0	0.00
911	R1	UNKNOWN	97.3	97.3	0.0	0.00
	R3	UNKNOWN	97.3	97.3	0.0	0.00
NEW END THEATRE- 27 NEW END						
100	R1	UNKNOWN	49.1	49.1	0.0	0.00
101	R1	UNKNOWN	93.8	93.9	-0.1	-0.11
LAWN HOUSE- HAMPSTEAD SQUARE						
200	R1	KD	98.0	98.2	-0.2	-0.20
	R2	UNKNOWN	99.9	99.9	0.0	0.00
201	R2	DINING	98.6	98.6	0.0	0.00
	R3	OFFICE	95.0	94.9	0.1	0.11
202	R2	BEDROOM	99.0	99.0	0.0	0.00
	R3	BEDROOM	99.0	99.0	0.0	0.00
203	R1	ASSUMED	99.2	99.2	0.0	0.00
	R2	ASSUMED	99.0	99.0	0.0	0.00
	R3	ASSUMED	99.9	99.8	0.1	0.10
210	R1	ASSUMED	99.5	97.6	1.9	1.91

<sup>1</sup> KITCHEN SMALLER THAN 13M<sup>2</sup>

*Annual Probable Sunlight Hours (APSH)*



ANNUAL PROBABLE SUNLIGHT HOURS								
FLOOR	ROOM	ROOM USE	CONSENTED		PROPOSED		TOTAL % LOSS	WINTER % LOSS
			TOTAL	WINTER	TOTAL	WINTER		
<b>11 HAMPSTEAD SQUARE</b>								
299	R1	ASSUMED	74	18	74	18	0	0
	R2	ASSUMED	77	16	77	16	0	0
	R3	UNKNOWN	34	7	34	7	0	0
	R4	UNKNOWN	13	0	13	0	0	0
300	R1	UNKNOWN	81	24	80	23	1.23	4.17
	R2	UNKNOWN	87	24	87	24	0	0
301	R1	UNKNOWN	87	28	87	28	0	0
	R2	UNKNOWN	92	29	92	29	0	0
302	R1	UNKNOWN	92	29	92	29	0	0
	R2	UNKNOWN	49	15	49	15	0	0
310	R1	UNKNOWN	48	14	48	14	0	0
	R2	UNKNOWN	20	2	20	2	0	0
311	R1	UNKNOWN	48	14	48	14	0	0
	R2	UNKNOWN	21	2	21	2	0	0
<b>10 HAMPSTEAD SQUARE</b>								
299	R1	UNKNOWN	37	9	35	7	5.41	22.22
	R2	ASSUMED	47	13	46	12	2.13	7.69
300	R3	UNKNOWN	50	15	50	15	0	0
<b>10 HAMPSTEAD SQUARE (CONT.)</b>								
301	R3	UNKNOWN	55	15	55	15	0	0
302	R3	UNKNOWN	49	15	49	15	0	0
	R4	UNKNOWN	56	15	56	15	0	0
310	R3	UNKNOWN	47	15	47	15	0	0
311	R3	UNKNOWN	49	15	49	15	0	0
<b>CHRIST CHURCH- HAMPSTEAD SQUARE</b>								
400	R1	UNKNOWN	100	30	100	30	0	0
<b>CHRIST CHURCH PRIMARY SCHOOL- CHRISTCHURCH HILL</b>								
500	R1	UNKNOWN	63	16	63	16	0	0
501	R1	UNKNOWN	78	23	78	23	0	0
502	R1	UNKNOWN	83	28	83	28	0	0

<sup>1</sup> KITCHEN SMALLER THAN 13M<sup>2</sup>

ANNUAL PROBABLE SUNLIGHT HOURS								
FLOOR	ROOM	ROOM USE	CONSENTED		PROPOSED		TOTAL % LOSS	WINTER % LOSS
			TOTAL	WINTER	TOTAL	WINTER		
<b>CHRIST CHURCH COTTAGE- CHRISTCHURCH PASSAGE</b>								
599	R1	UNKNOWN	41	11	41	11	0	0
600	R1	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
			N/A	N/A	N/A	N/A	N/A	N/A
	R3	KITCHEN <sup>1</sup>	59	20	57	20	3.39	0
601	R1	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
			N/A	N/A	N/A	N/A	N/A	N/A
			N/A	N/A	N/A	N/A	N/A	N/A
	R2	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
	R3	BEDROOM	N/A	N/A	N/A	N/A	N/A	N/A
<b>1-9 CARNEGIE HOUSE- CHRISTCHURCH PASSAGE</b>								
700	R1	UNKNOWN	75	18	75	18	0	0
	R2	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
			N/A	N/A	N/A	N/A	N/A	N/A
			N/A	N/A	N/A	N/A	N/A	N/A
			N/A	N/A	N/A	N/A	N/A	N/A
			N/A	N/A	N/A	N/A	N/A	N/A
	R3	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
	R4	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
	R5	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
701	R1	UNKNOWN	78	21	78	21	0	0
	R2	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
<b>1-9 CARNEGIE HOUSE- CHRISTCHURCH PASSAGE (CONT.)</b>								
701 (CONT.)	R3	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
	R4	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
	R5	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
			N/A	N/A	N/A	N/A	N/A	N/A
	R6	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
	R7	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
	R8	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
702	R1	UNKNOWN	84	27	84	27	0	0
	R2	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
			N/A	N/A	N/A	N/A	N/A	N/A
			N/A	N/A	N/A	N/A	N/A	N/A
			N/A	N/A	N/A	N/A	N/A	N/A
			N/A	N/A	N/A	N/A	N/A	N/A
			N/A	N/A	N/A	N/A	N/A	N/A
			N/A	N/A	N/A	N/A	N/A	N/A
			N/A	N/A	N/A	N/A	N/A	N/A
	R3	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
	R4	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
	R5	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
	R6	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
	R7	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
	R8	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
703	R1	UNKNOWN	86	29	86	29	0	0
	R2	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
			N/A	N/A	N/A	N/A	N/A	N/A
			N/A	N/A	N/A	N/A	N/A	N/A
			N/A	N/A	N/A	N/A	N/A	N/A
			N/A	N/A	N/A	N/A	N/A	N/A
			N/A	N/A	N/A	N/A	N/A	N/A
			N/A	N/A	N/A	N/A	N/A	N/A
			N/A	N/A	N/A	N/A	N/A	N/A
	R3	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
	R4	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
	R5	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
	R6	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
	R7	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
	R8	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
<b>10-14 NEW END</b>								
800	R1	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
			N/A	N/A	N/A	N/A	N/A	N/A
	R2	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
			N/A	N/A	N/A	N/A	N/A	N/A
	R3	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
801	R1	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
			N/A	N/A	N/A	N/A	N/A	N/A
			N/A	N/A	N/A	N/A	N/A	N/A
	R2	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
	R3	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
	R4	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
	R5	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
			N/A	N/A	N/A	N/A	N/A	N/A
	R6	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
802	R1	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
			N/A	N/A	N/A	N/A	N/A	N/A
			N/A	N/A	N/A	N/A	N/A	N/A
	R2	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
	R3	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
				N/A	N/A	N/A	N/A	N/A
<b>10-14 NEW END (CONT.)</b>								
803	R1	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
			N/A	N/A	N/A	N/A	N/A	N/A
	R2	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
			N/A	N/A	N/A	N/A	N/A	N/A
	R3	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
			N/A	N/A	N/A	N/A	N/A	N/A

<sup>1</sup> KITCHEN SMALLER THAN 13M<sup>2</sup>

ANNUAL PROBABLE SUNLIGHT HOURS								
FLOOR	ROOM	ROOM USE	CONSENTED		PROPOSED		TOTAL % LOSS	WINTER % LOSS
			TOTAL	WINTER	TOTAL	WINTER		
804	R1	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
			N/A	N/A	N/A	N/A	N/A	N/A
	R2	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
			N/A	N/A	N/A	N/A	N/A	N/A
	R3	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
			N/A	N/A	N/A	N/A	N/A	N/A
<b>7-9 NEW END</b>								
900	R1	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
	R2	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
	R3	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
901	R1	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
	R2	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
	R3	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
	R4	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
	R5	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
	R6	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
	R7	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
	R8	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
R9	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A	
902	R1	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
	R2	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
	R3	UNKNOWN	13	0	13	0	0	0
	R4	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
R5	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A	
R6	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A	
903	R1	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
	R2	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
	R3	UNKNOWN	12	0	12	0	0	0
	R4	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
R5	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A	
R6	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A	
910	R1	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
	R3	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
911	R1	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
<b>7-9 NEW END (CONT.)</b>								
911 (CONT.)	R3	UNKNOWN	N/A	N/A	N/A	N/A	N/A	N/A
<b>NEW END THEATRE- 27 NEW END</b>								
100	R1	UNKNOWN	62	5	62	5	0	0
101	R1	UNKNOWN	76	14	76	14	0	0
<b>LAWN HOUSE- HAMPSTEAD SQUARE</b>								
200	R1	KD	62	21	62	21	0	0
	R2	UNKNOWN	65	21	65	21	0	0
201	R2	DINING	N/A	N/A	N/A	N/A	N/A	N/A
	R3	OFFICE	73	23	73	24	0	-4.35
202	R2	BEDROOM	46	10	44	9	4.35	10
	R3	BEDROOM	82	25	82	25	0	0
203	R1	ASSUMED	88	28	88	28	0	0
	R2	ASSUMED	N/A	N/A	N/A	N/A	N/A	N/A
	R3	ASSUMED	54	14	52	13	3.7	7.14
210	R1	ASSUMED	90	27	89	27	1.11	0

<sup>1</sup> KITCHEN SMALLER THAN 13M<sup>2</sup>

ADDRESS

THE WHITEHOUSE  
BELVEDERE ROAD  
LONDON SE1 8GA

CONTACT

TEL 020 7202 1400  
FAX 020 7202 1401  
MAIL@GIA.UK.COM

WWW.GIA.UK.COM