

Proposed External Drainage Design

- Drainage channel to be excavated 123mm wide by a minimum 150mm deep. Channel to be laid to falls 1:40.
- Layout to be as per the annotated photo below.
- Supply and install Aco Heel Guard Grating.
- New drainage channel to be connected to the existing drainage.

