



**LEGEND**

- NORMAL CONDITION
- MOTORISED SMOKE FIRE DAMPER
- FIRE DAMPER
- VOLUME CONTROL DAMPER
- ATTENUATOR
- INSULATED DUCTWORK
- ACCESS DOORS

- NOTES:**
- Access Door Notes
- For ductwork less than 600mm x 300mm or 450 mm diameter, access openings shall be 450mm x250mm every 15m.
  - For ductwork in excess of 600mm x 300mm or 450 mm diameter access openings shall be 450mm x 350mm every 15m.
  - For small ducts access openings shall be 300 x 150mm every 15m. Access doors shall also be provided on one side of square bends with turning vanes/ and volume control dampers.

REV	DATE	BY	CKD	DESCRIPTION
E	30/11/16	JG	NMcP	LOW LOAD COMMISSIONING BYPASS ADDED
D	18/11/16	JG	JR	UPDATED FOR WBS COMMENTS, ROUTE AMENDED FOR CO-ORDINATION
C	31/08/16	JG	DC	GF BIN STORES ADDED. BASEMENT DIS WC ADDED
B	27/05/16	JG	DC	WBS COMMENTS DUCT SIZES INCREASED
A	13/01/16	DC	NMcP	FIRST ISSUE

**kanegroup** Building Services  
 11 Burrenreagh Road  
 Castlewellan | Co. Down | BT31 9HH  
 tel 028 4377 8484 | fax 028 4377 8116  
 info@KANEGROUPBS.COM  
 WWW.KANEGROUPBS.COM

PROJECT TITLE			
HERBAL HOUSE			
DRAWING TITLE			
TOILET VENTILATION SCHEMATIC			
DRAWN	DATE	CHECKED	DATE
DC	13/01/16	NMcP	13/01/16
DRAWING STATUS			SCALE @A1
CONSTRUCTION			NTS
JOB NO	DRAWING NO	REV	
C-0665	SCH-2013	E	