

Tom Horne
DP9
100 Pall Mall
London
SW1Y 5NQ

Application Ref: **2016/6069/P**
Please ask for: **David Peres Da Costa**
Telephone: 020 7974 **5262**

21 November 2017

Dear Sir/Madam

DECISION

Town and Country Planning Act 1990 (as amended)

Full Planning Permission Granted Subject to a Section 106 Legal Agreement

Address:

**1 Triton Square & St Anne's Church Laxton Place
London
NW1 3DX**

Proposal:

Erection of 3 storey extension at roof (6th floor) level of 1 Triton Square to provide additional office floorspace (Class B1) with relocated plant above, creation of roof terraces at 6th floor level, reconfiguration of ground floor including infill of Triton Square Mall including flexible retail (A1, A3 and A4), affordable workspace (B1) and reprovision of gym (D2); erection of part 6, part 9 storeys residential building to provide 22 flats (10 x 3-bed, 11 x 2-bed and 1 x 1-bed) (Class C3) following demolition of St Anne's Church (Class D1); hard and soft landscaping including garden at junction of Longford Street and Triton Square; reconfigured vehicle and pedestrian accesses; and other ancillary works.

Drawing Nos: Supporting documents: Developers Statement (British Land) October 2016; Design and Access Statement (Vol. 1, 1TS, Arup Associates; and Vol. 2, SA, Matthew Lloyd Architects) October 2016; Housing Study (Arup Associates) October 2016; Townscape, Heritage & Visual Impact Assessment (Tavernor Consultancy) October 2016; Heritage Statement (KM Heritage) October 2016; Landscape Masterplan (5th Studio and Andy Sturgeon Design) October 2016; Planning Statement (DP9) March 2017; Statement of Community Involvement (HardHat) October 2016; Transport Assessment (Arup) October 2016; Energy Statement (Arup and Thornton Reynolds) October 2016; Sustainability



Statement (Arup and Eight Associates) October 2016; Daylight & Sunlight Study (GIA) October 2016; Overshadowing Study (GIA) October 2016; Internal Daylight Study (GIA) October 2016; Air Quality Assessment (Arup) October 2016; Arboricultural Assessment (Thomson Ecology) October 2016; Surface Water Drainage Proforma (Arup) dated December 2016; Construction Management Plan (Lendlease) dated October 2016; Socio-Economic Assessment (Quod) dated October 2016; Financial Viability Assessment (DS2) dated October 2016; Crime Impact Assessment (QCIC) dated 20/12/2016; Energy and Sustainability Consultation Response (Arup) dated 10 January 2017; BRUKL Output (refurbishment) 04 Jan 2017; BRUKL Output (extension) 04 Jan 2017; Noise Assessment (Arup) dated December 2016; Air Quality Assessment Addendum (Arup) dated 9 December 2016; Independent Viability Review (BPS) dated 16th January 2016; Equalities Statement (Quod) dated January 2017; Letter from DP9 dated 30 January 2017; Letter from GIA dated 06/01/2017; Letter from GIA dated 28/02/2017; St Anne's Design Note: Overlooking (Matthew Lloyd Architects) January 2017; Summary of St Anne's Church (SAC) Information (DP9) dated February 2017; Letter from Gerald Eve dated 13 March 2017; Effect on St Mary Magdalene Church (KM Heritage)

Existing drawings (1TS): 246868-A_A_XX_ : XX_DR_AX_91040; XX_DR_AX_91020; B1_DR_AX_10010; GF_DR_AX_10020; 01_DR_AX_10030; ZZ_DR_AX_10041; 05_DR_AX_10070; 06_DR_AX_10080; 07_DR_AX_10090; XX_DR_AX_10510; XX_DR_AX_10520; XX_DR_AX_10530; XX_DR_AX_10540; XX_DR_AX_10610

Proposed drawings (1TS): 246868-A_A_XX_ : XX_DR_AX_91030 P01; B1_DR_AX_30010 P01; GF_DR_AX_30020 P01; 01_DR_AX_30030 P01; ZZ_DR_AX_30041 P01; 06_DR_AX_30080 P01; ZZ_DR_AX_30091 P01; 09_DR_AX_30110 P01; 10_DR_AX_30120 P01; 246868-A_A_XX_XX_DR_AX_ : 30510 P01; 30520 P01; 30530 P01; 30540 P01; 30610 P01; 30620 P01; 36701 P01; 36702 P01; 36703 P01; 36704 P01;

Existing drawings (SAC): SA: 100; 101; 102; 150; 151;152

Proposed drawings (SAC) SA: 200; 201; 202; 206; 207; 209; 250: 251; 252; 253; 254; 255;

The Council has considered your application and decided to grant permission subject to the following condition(s):

Condition(s) and Reason(s):

- 1 The development hereby permitted must be begun not later than the end of three years from the date of this permission.

Reason: In order to comply with the provisions of Section 91 of the Town and Country Planning Act 1990 (as amended).

- 2 All new external work shall be carried out in materials that resemble, as closely as possible, in colour and texture those of the existing building, unless otherwise specified in the approved application.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policy D1 of the London Borough of Camden Local Plan 2017.

- 3 The development hereby permitted shall be carried out in accordance with the following approved plans:

Existing drawings (1TS): 246868-A_A_XX_: XX_DR_AX_91040; XX_DR_AX_91020; B1_DR_AX_10010; GF_DR_AX_10020; 01_DR_AX_10030; ZZ_DR_AX_10041; 05_DR_AX_10070; 06_DR_AX_10080; 07_DR_AX_10090; XX_DR_AX_10510; XX_DR_AX_10520; XX_DR_AX_10530; XX_DR_AX_10540; XX_DR_AX_10610

Proposed drawings (1TS): 246868-A_A_XX_ : XX_DR_AX_91030 P01; B1_DR_AX_30010 P01; GF_DR_AX_30020 P01; 01_DR_AX_30030 P01; ZZ_DR_AX_30041 P01; 06_DR_AX_30080 P01; ZZ_DR_AX_30091 P01; 09_DR_AX_30110 P01; 10_DR_AX_30120 P01; 246868-A_A_XX_XX_DR_AX_: 30510 P01; 30520 P01; 30530 P01; 30540 P01; 30610 P01; 30620 P01; 36701 P01; 36702 P01; 36703 P01; 36704 P01;

Existing drawings (SAC): SA: 100; 101; 102; 150; 151;152

Proposed drawings (SAC) SA: 200; 201; 202; 206; 207; 209; 250: 251; 252; 253; 254; 255;

Supporting documents: Developers Statement (British Land) October 2016; Design and Access Statement (Vol. 1, 1TS, Arup Associates; and Vol. 2, SA, Matthew Lloyd Architects) October 2016; Housing Study (Arup Associates) October 2016; Townscape, Heritage & Visual Impact Assessment (Tavernor Consultancy) October 2016; Heritage Statement (KM Heritage) October 2016; Landscape Masterplan (5th Studio and Andy Sturgeon Design) October 2016; Planning Statement (DP9) March 2017; Statement of Community Involvement (HardHat) October 2016; Transport Assessment (Arup) October 2016; Energy Statement (Arup and Thornton Reynolds) October 2016; Sustainability Statement (Arup and Eight Associates) October 2016; Daylight & Sunlight Study (GIA) October 2016; Overshadowing Study (GIA) October 2016; Internal Daylight Study (GIA) October 2016; Air Quality Assessment (Arup) October 2016; Arboricultural Assessment (Thomson Ecology) October 2016; Surface Water Drainage Proforma (Arup) dated December 2016; Construction Management Plan (Lendlease) dated October 2016; Socio-Economic Assessment (Quod) dated October 2016; Financial Viability Assessment (DS2) dated October 2016; Crime Impact Assessment (QCIC) dated 20/12/2016; Energy and Sustainability Consultation Response (Arup) dated 10 January 2017; BRUKL Output (refurbishment) 04 Jan 2017; BRUKL Output (extension) 04 Jan 2017; Noise Assessment (Arup) dated December 2016; Air Quality Assessment Addendum (Arup) dated 9 December 2016; Independent Viability Review (BPS) dated 16th January 2016; Equalities Statement (Quod) dated January 2017; Letter from DP9 dated 30 January 2017; Letter from GIA dated 06/01/2017; Letter from GIA dated 28/02/2017; St Anne's Design Note: Overlooking (Matthew Lloyd Architects) January 2017; Summary of St Anne's Church (SAC) Information (DP9) dated February 2017; Letter from Gerald Eve dated 13 March 2017; Effect on St Mary Magdalene Church (KM Heritage)

Reason: For the avoidance of doubt and in the interest of proper planning.

- 4 No impact piling until a piling method statement, prepared in consultation with Thames Water or the relevant statutory undertaker, detailing the depth and type of piling to be undertaken and the methodology by which such piling will be carried out including measures to prevent and minimise the potential for damage to subsurface water infrastructure, and the programme for the works, has been submitted to and approved in writing by the local planning authority. Any piling must be undertaken in accordance with the terms of the approved piling method statement.

Reason: To safeguard existing below ground public utility infrastructure and controlled waters in accordance with the requirements of policy CC3 of the London Borough of Camden Local Plan 2017.

- 5 No development shall take place until full details of hard and soft landscaping and means of enclosure of all un-built, open areas have been submitted to and approved by the local planning authority in writing. Such details shall include:
- a) planting for biodiversity and habitat features, as outlined in the Sustainability Assessment hereby approved;
 - b) details of any proposed earthworks including grading, mounding and other changes in ground levels;
 - c) details of 6th floor terrace and playspace.
 - d) details of Longford Street landscaping

The relevant part of the works shall not be carried out otherwise than in accordance with the details thus approved.

Reason: To ensure that the development achieves a high quality of landscaping which contributes to the visual amenity and character of the area in accordance with the requirements of policies A2, A3 and D1 of the London Borough of Camden Local Plan 2017.

- 6 All hard and soft landscaping works shall be carried out in accordance with the approved landscape details by not later than the end of the planting season following completion of the development or any phase of the development whichever is the sooner. Any trees or areas of planting which, within a period of 5 years from the completion of the development, die, are removed or become seriously damaged or diseased, shall be replaced as soon as is reasonably possible and, in any case, by not later than the end of the following planting season, with others of similar size and species, unless the local planning authority gives written consent to any variation.

Reason: To ensure that the landscaping is carried out within a reasonable period and to maintain a high quality of visual amenity in the scheme in accordance with the requirements of policies A2, A3 and D1 of the London Borough of Camden Local Plan 2017.

- 7 Prior to the commencement of any works on site, details demonstrating how trees to be retained shall be protected during construction work shall be submitted to and approved by the Council in writing. Such details shall follow guidelines and standards set out in BS5837:2012 "Trees in Relation to Construction". All trees on

the site, or parts of trees growing from adjoining sites, unless shown on the permitted drawings as being removed, shall be retained and protected from damage in accordance with the approved protection details.

Reason: To ensure that the development will not have an adverse effect on existing trees and in order to maintain the character and amenity of the area in accordance with the requirements of policies A2 and A3 of the London Borough of Camden Local Plan 2017.

- 8 Detailed drawings, or samples of materials as appropriate, in respect of the following, shall be submitted to and approved in writing by the local planning authority before the relevant part of the work is begun:
- a) Details including sections at 1:10 of all windows (including jambs, head and cill), ventilation grills, external doors and gates for St Anne's residential block;
 - b) Plan, elevation and section drawings of the new shopfronts at a scale of 1:10;
 - c) Manufacturer's specification details of all facing materials (to be submitted to the Local Planning Authority) and samples of those materials (to be provided on site).
 - d) Plan, elevation and section drawings of interfaces with the adjacent façade types for 1 Triton Square at a scale of 1:10.

The relevant part of the works shall be carried out in accordance with the details thus approved and all approved samples shall be retained on site during the course of the works.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policy D1 of the London Borough of Camden Local Plan 2017.

- 9 A 2m by 2m sample panel of the facing brickwork for the St Anne's residential block demonstrating the proposed colour, texture, face-bond and pointing shall be provided on site and approved in writing by the local planning authority before the relevant parts of the works are commenced and the development shall be carried out in accordance with the approval given. The approved panel shall be retained on site until the work has been completed.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policy D1 of the London Borough of Camden Local Plan 2017.

- 10 Noise levels at a point 1 metre external to sensitive facades shall be at least 5dB(A) less than the existing background measurement (LA90), expressed in dB(A) when all plant/equipment (or any part of it) is in operation unless the plant/equipment hereby permitted will have a noise that has a distinguishable, discrete continuous note (whine, hiss, screech, hum) and/or if there are distinct impulses (bangs, clicks, clatters, thumps), then the noise levels from that piece of plant/equipment at any sensitive façade shall be at least 10dB(A) below the LA90,

expressed in dB(A).

Reason: To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policies A1 and A4 of the London Borough of Camden Local Plan 2017.

- 11 Before the use commences, the 9th floor plant at 1 Triton Square shall be provided with an acoustic screen and the generator at St Anne's residential block shall be provided with sound attenuation; all plant shall have anti-vibration measures, all measures shall be in accordance with the noise report prepared by Arup dated 7 December 2016 hereby approved. All such measures shall thereafter be retained and maintained in accordance with the manufacturers' recommendations.

Reason: To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policies A1 and A4 of the London Borough of Camden Local Plan 2017.

- 12 At least 28 days before development commences:
- (a) a written programme of ground investigation for the presence of soil and groundwater contamination and landfill gas shall be submitted to and approved by the local planning authority in writing; and
 - (b) following the approval detailed in paragraph (a), an investigation shall be carried out in accordance with the approved programme and the results and a written scheme of remediation measures [if necessary] shall be submitted to and approved by the local planning authority in writing.
- The remediation measures shall be implemented strictly in accordance with the approved scheme and a written report detailing the remediation shall be submitted to and approved by the local planning authority in writing prior to occupation.

Reporting and Management of Significant Additional Contamination

Additional significant contamination discovered during development shall be fully assessed and any necessary modifications made to the remediation scheme shall be submitted to the Local Planning Authority for written approval. Before any part of the development hereby permitted is occupied the developer shall provide written confirmation that all works were completed in accordance with the revised remediation scheme.

Reason: To protect future occupiers of the development from the possible presence of ground contamination arising in connection with the previous industrial/storage use of the site in accordance with policies C1, A1, and DM1 of the London Borough of Camden Local Plan 2017.

- 13 Sustainable urban drainage:
- A) Prior to commencement of the development, full details of the sustainable drainage system including:
- o Rainwater harvesting
 - o Landscaping on Longford Place
 - o Brown roofs (on Triton cores) and biodiverse green roof (on St Anne's)

o 280m³ attenuation tank with pumped flow control shall be submitted to and approved in writing by the local planning authority. Such a system should be designed to accommodate all storms up to and including a 1:100 year storm with a 40% provision for climate change, such that flooding does not occur in any part of a building or in any utility plant susceptible to water, and shall demonstrate a maximum run-off rate of 35 l/s. Details shall include a lifetime maintenance plan.

B) Prior to occupation of the development, evidence that the sustainable drainage system has been implemented in accordance with the approved details shall be submitted to the Local Authority and approved in writing. The systems shall thereafter be retained and maintained in accordance with the approved maintenance plan.

Reason: To reduce the rate of surface water run-off from the buildings and limit the impact on the storm-water drainage system in accordance with policies CC1, CC2 and CC3 of the London Borough of Camden Local Plan 2017.

14 Living roof:

Prior to commencement of development full details of biodiverse, substrate-based extensive living roofs shall be submitted to and approved in writing by the local planning authority. The design and planting scheme should reflect the local conditions and species of interest. The details shall include the following: A. detailed maintenance plan, B. details of its construction and the materials used, C. a section at a scale of 1:20 showing substrate depth averaging 130mm with added peaks and troughs to provide variations between 80mm and 150mm and D. full planting details including species showing planting of at least 16 plugs per m². The development shall not be carried out otherwise than in accordance with the details thus approved and shall be fully implemented before the premises are first occupied.

Reason: To ensure that the green roof is suitably designed and maintained in accordance with the requirements of policies CC1, CC2, CC3, CC4, D1, and A3 of the London Borough of Camden Local Plan 2017.

15 Bird and bat boxes:

Details of bird and bat nesting boxes or bricks shall be submitted to and approved in writing by the Local Planning Authority prior to any superstructure works commencing on site. Features should be integrated into the fabric of the buildings, unless otherwise agreed by the Local Planning Authority. Details shall include the exact location, height, aspect, specification and indication of species to be accommodated. Boxes shall be installed in accordance with the approved plans prior to the first occupation of the development and thereafter maintained.

Reason: In order to secure appropriate features to conserve and enhance wildlife habitats and biodiversity measures within the development, in accordance with the requirements of the London Plan 2016 (Consolidated with Alterations Since 2011) and Policies A3 and CC2 of the London Borough of Camden Local Plan 2017.

16 Air Quality Monitoring:

Air quality monitoring shall be implemented on site. No development shall take place until full details of the air quality monitors have been submitted to and approved by the local planning authority in writing. Such details shall include the location, number and specification of the monitors, including evidence of the fact that they have been installed in line with guidance outlined in the GLA's Control of Dust and Emissions during Construction and Demolition Supplementary Planning Guidance and have been in place for 3 months prior to the proposed implementation date. The monitors shall be retained and maintained on site for the duration of the development in accordance with the details thus approved.

Reason: To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policies A1, D1 and CC4 of the London Borough of Camden Local Plan 2017.

17 Mechanical Ventilation:

Prior to commencement of development (excluding demolition and site preparation works), full details of the mechanical ventilation system including air inlet locations shall be submitted to and approved by the local planning authority in writing. Air inlet locations should be located away from busy roads and the boiler stack and as close to roof level as possible, to protect internal air quality. The development shall thereafter be constructed and maintained in accordance with the approved details.

Reason: To protect the amenity of future occupiers and to safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policies G1, A1 and A4 of the London Borough of Camden Local Plan 2017.

18 Air Quality Neutral:

Prior to commencement of development (excluding demolition and site preparation works), full details of the boiler plant and confirmation that the plant meets the Mayor's air quality neutral requirements and meets the NOx emissions limit of 40mg/kWh shall be submitted to and approved by the local planning authority in writing.

Reason: To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policies G1, A1 and A4 of the London Borough of Camden Local Plan 2017.

19 Before the development commences, details of secure and covered cycle storage area for 532 cycles in 1 Triton Square and 49 cycles in the public realm shall be submitted to and approved by the local planning authority. The approved facility shall thereafter be provided in its entirety prior to the first occupation of any of the new units, and permanently retained thereafter.

Reason: To ensure the development provides adequate cycle parking facilities in

accordance with the requirements of policy T1 of the London Borough of Camden Local Plan 2017.

20 Solar PV:

Prior to commencement, detailed plans showing the location and extent of photovoltaic cells to be installed on the building shall have been submitted to and approved by the Local Planning Authority in writing. The measures shall include the installation of a meter to monitor the energy output from the approved renewable energy systems. The cells shall be installed in full accordance with the details approved by the Local Planning Authority and permanently retained and maintained thereafter.

Reason: To ensure the development provides adequate on-site renewable energy facilities in accordance with the requirements of policies G1, CC1 and CC2 of the London Borough of Camden Local Plan 2017.

21 Units 1.2, 1.3, 2.1-2.3, 3.1-3.3, 4.1-4.3, 5.1-5.3, 6.1, 6.2, 7.1, 7.2, 8.1 and 8.2 as indicated in the Design and Access Statement hereby approved shall be designed and constructed in accordance with Building Regulations Part M4 (2), evidence demonstrating compliance should be submitted to and approved by the Local Planning Authority prior to occupation.

Reason: To ensure that the internal layout of the building provides flexibility for the accessibility of future occupiers and their changing needs over time, in accordance with the requirements of policy H6 of the London Borough of Camden Local Plan 2017.

22 Units 0.1 & 1.1, as indicated in the Design and Access Statement hereby approved shall be designed and constructed in accordance with Building Regulations Part M4 (3). Evidence demonstrating compliance should be submitted to and approved by the Local Planning Authority prior to occupation.

Reason: To ensure that the wheelchair units would be capable of providing adequate amenity in accordance with policy H6 of the London Borough of Camden Local Plan 2017.

23 Before the development commences, details of secure and covered cycle storage area for 44 cycles in the St Anne's residential block shall be submitted to and approved by the local planning authority. The approved facility shall thereafter be provided in its entirety prior to the first occupation of any of the new units, and permanently retained thereafter.

Reason: To ensure the development provides adequate cycle parking facilities in accordance with the requirements of policy T1 of the London Borough of Camden Local Plan 2017.

24 No lights, meter boxes, flues, vents or pipes, and no telecommunications equipment, alarm boxes, television aerials, satellite dishes or rooftop 'mansafe' rails shall be fixed or installed on the external face of the buildings, without the prior

approval in writing of the local planning authority.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policy D1 of the London Borough of Camden Local Plan 2017.

- 25 The use of the terrace at first floor level adjoining 1 Laxton Place shall not commence until the screen, as shown on the approved drawings, has been constructed. The screen shall be permanently retained thereafter.

Reason: In order to prevent unreasonable overlooking of neighbouring premises in accordance with the requirements of policy A1 of the London Borough of Camden Local Plan 2017.

- 26 Before the commencement of development of the residential building, details of the location, design and method of waste storage and removal including recycled materials for the proposed residential building, shall be submitted to and approved by the local planning authority in writing. The facility as approved shall be provided prior to the first occupation of any of the new units and permanently retained thereafter.

Reason: To ensure that sufficient provision for the storage and collection of waste has been made in accordance with the requirements of policy CC5, A1 and A4 of the London Borough of Camden Local Plan 2017.

Informative(s):

- 1 You are advised that this proposal will be liable for the Mayor of London's Community Infrastructure Levy (CIL) and the Camden CIL as the additional floorspace exceeds 100sqm GIA or one unit of residential accommodation. Based on the Mayor's CIL and Camden's CIL charging schedules and the information given on the plans the charge is likely to be £907,000 (18,140sqm x £50) for Mayoral CIL and £1,000,025 (15,711sqm x £25 and 2,429sqm x £250) for Camden's CIL.

This amount is an estimate based on the information submitted in your planning application. The liable amount may be revised on the receipt of the CIL Additional Information Requirement Form or other changes in circumstances. Both CIL's will be collected by Camden after the scheme has started and could be subject to surcharges for failure to assume liability or submit a commencement notice PRIOR to commencement and/or for late payment. We will issue a formal liability notice once the liable party has been established. CIL payments will also be subject to indexation in line with the construction costs index.

- 2 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts which cover aspects including fire and emergency escape, access and facilities for people with disabilities and sound insulation between dwellings. You are advised to consult the Council's Building Control Service, Camden Town Hall, Argyle Street WC1H 8EQ, (tel: 020-7974 6941).

- 3 Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You are advised to consult the Council's Noise and Licensing Enforcement Team, Camden Town Hall, Argyle Street, WC1H 8EQ (Tel. No. 020 7974 4444 or on the website <http://www.camden.gov.uk/ccm/content/contacts/council-contacts/environment/contact-the-environmental-health-team.en> or seek prior approval under Section 61 of the Act if you anticipate any difficulty in carrying out construction other than within the hours stated above.
- 4 Your attention is drawn to the fact that there is a separate legal agreement with the Council which relates to the development for which this permission is granted. Information/drawings relating to the discharge of matters covered by the Heads of Terms of the legal agreement should be marked for the attention of the Planning Obligations Officer, Sites Team, Camden Town Hall, Argyle Street, WC1H 8EQ.
- 5 The emerging London Borough of Camden Local Plan is reaching the final stages of its public examination. Consultation on proposed modifications to the Submission Draft Local Plan began on 30 January and ended on 13 March 2017. The modifications have been proposed in response to Inspector's comments during the examination and seek to ensure that the Inspector can find the plan 'sound' subject to the modifications being made to the Plan. The Local Plan at this stage is a material consideration in decision making, but pending publication of the Inspector's report into the examination only has limited weight.
- 6 You are advised that Section 44 of the Deregulation Act 2015 [which amended the Greater London Council (General Powers) Act 1973] only permits short term letting of residential premises in London for up to 90 days per calendar year. The person who provides the accommodation must be liable for council tax in respect of the premises, ensuring that the relaxation applies to residential, and not commercial, premises.
- 7 If a revision to the postal address becomes necessary as a result of this development, application under Part 2 of the London Building Acts (Amendment) Act 1939 should be made to the Camden Contact Centre on Tel: 020 7974 4444 or Environment Department (Street Naming & Numbering) Camden Town Hall, Argyle Street, WC1H 8EQ.
- 8 Guidance on biodiversity enhancements including artificial nesting and roosting sites is available in the Camden Biodiversity Action Plan: Advice Note on Landscaping Schemes and Species Features. Guidance on living roofs is available in the Camden Biodiversity Action Plan: Advice Note on Living Roofs and Walls.
- 9 Active bird nests are protected under Part 1 of the Wildlife and Countryside Act 1981 (as amended) which states that it is an offence to disturb, damage or destroy the nest of any wild bird while that nest be in use or being built. Active nests are


highly likely to be present within the site during peak nesting season, considered by Natural England as between 1 March and 31 July. It should be noted that active nests are afforded legal protection at all times and can be encountered throughout a nesting season which may extend between mid February and October depending on bird species and weather conditions. Nesting habitats which includes trees, shrubs, climbing plants, grounds flora, buildings and other structures may be cleared at any time of year where survey (undertaken by a suitably experienced person) can establish active nests are absent. For further information contact Natural England on 0845 600 3078.

In dealing with the application, the Council has sought to work with the applicant in a positive and proactive way in accordance with paragraphs 186 and 187 of the National Planning Policy Framework.

You can find advice about your rights of appeal at:

<http://www.planningportal.gov.uk/planning/appeals/guidance/guidancecontent>

Yours faithfully

A handwritten signature in black ink that reads "David T. Joyce". The signature is written in a cursive, slightly slanted style.

David Joyce
Director of Regeneration and Planning