

44 Saffron Hill

# Plant Noise Assessment

Report 17/0414/R1

44 Saffron Hill

# Plant Noise Assessment

Report 17/0414/R1

E&A (Saffron Hill) Limited

33 Ely Place  
London  
EC1N 6TD

Revision	Description	Date	Prepared	Approved
0	1 <sup>st</sup> Issue	27 June 2017	Ben Holcombe	Lee Montague
1	Revision 1	11 September 2017	Ben Holcombe	Lee Montague
2	Revision 2	14 September 2017	Ben Holcombe	Lee Montague

This report and associated surveys have been prepared and undertaken for the private and confidential use of our client only. If any third party whatsoever comes into possession of this report, they rely on it at their own risk and Cole Jarman Limited accepts no duty or responsibility (including in negligence) to any such third party.



## Plant Noise Assessment

### Table of Contents

---

1	Introduction	3
2	Site Description	3
3	Noise Survey	4
3.1	Methodology and Equipment	4
3.2	Results and Analysis	4
3.3	Plant Noise Limits	5
4	Plant Noise Assessment	6
4.1	Details	6
4.2	Required Mitigation Measures	7
4.3	Assessment	7
5	Conclusion	8

---

### Attachments

#### Glossary of Acoustic Terms

##### **17/0414/F01**

Figure showing site plan and measurement location

##### **17/0414/TH01**

Time history figure graph of measurement results

##### **17/0414/SPC1**

Acoustic lining specification

##### **17/0414/CS1-10**

Calculation sheets

 End of Section



## Plant Noise Assessment

### 1 Introduction

- 1.1 Planning permission is being sought for the change of use of existing lower ground and part ground floor to office use Class B1 (a), together with minor external alterations at 44 Saffron Hill, London, EC1N 8FH.
- 1.2 Part of this conversion includes installing 2 no. new condenser units at basement level, to be located internally.
- 1.3 Cole Jarman have undertaken a noise survey on site, the methodology and results of which, are published in this report. A plant noise assessment has also been undertaken, with mitigation proposed as necessary in order to meet planning noise limits.

### 2 Site Description

- 2.1 The site and surrounding area can be seen in attached site plan figure 17/0414/F01. The site is in the London borough of Camden.
- 2.2 The building is currently a mix of residential and commercial accommodation with parking at ground and basement level.
- 2.3 The new condenser plant is to be located at basement level on the eastern side of the building. Two new condenser units are to be installed internally, ducting out into the existing plant area which currently has five condenser units already installed, understood to serve the existing residents and commercial properties. Details of the new plant are set out in section 4.1.
- 2.4 The closest noise sensitive receiver to the proposed plant is the existing residential apartment at first floor level of the application building. There is an external terrace / balcony at first floor level which screens the first and upper floor windows from the proposed basement plant location.
- 2.5 The property directly to the east has commercial units at ground and first floor. It has been assumed the 2<sup>nd</sup> floor is residential. The property to the south of (southeast of the site) has a commercial unit on the ground floor and residential on the 1<sup>st</sup> floor, and assumed residential above.
- 2.6 The adjacent plot of land to the north east corner of the building has planning permission for new residential dwellings, however work has not commenced. Given the existing noise climate to that location already comprises plant noise from the other condensers, this potential development should already take account of the existing units; therefore, we do not propose to assess to this hypothetical location; the onus being on that future development to design for the 'existing' noise climate (which is already comprised of plant noise to which it is unlikely the new plant will significantly elevate).



## Plant Noise Assessment

### 3 Noise Survey

#### 3.1 Methodology and Equipment

- 3.1.1 A noise survey was conducted to establish typical background noise levels at the nearest noise sensitive receptors to the proposed plant location. This consisted of unattended measurements from 11h00 on 22<sup>nd</sup> June to 11h00 on 23<sup>rd</sup> June 2017.
- 3.1.2 The timing of the survey was chosen to capture the typical noise climate during the quietest hours of the day and night. The measurement position was on a pole against the ground floor parapet next to the lightwell where the existing plant is positioned, in the southeast corner of the site. This meant the meter was 4 m above ground floor level, approximately 8 m above basement level and representative of 1<sup>st</sup> floor windows. This position is also shown in 17/0414/F01 as MP1.
- 3.1.3 Measurements of the  $L_{Aeq}$ ,  $L_{Amax}$  and  $L_{A90}$  indices were taken over consecutive 15 minute periods (see Glossary of Acoustic Terms for an explanation of the noise units used).
- 3.1.4 Noise measurements were taken using the equipment listed in Table T1 below:

Item	Manufacturer	Type
Sound Level Analyser	Rion	NL-52
Acoustic Calibrator	Rion	NC-74
Weatherproof windshield	Rion	WS-15

T1 Equipment used during noise survey

- 3.1.5 The microphone was fitted with a windshield and was calibrated before and after the survey to ensure a consistent and acceptable level of accuracy was maintained throughout.
- 3.1.6 The weather conditions when setting up the equipment were warm, dry and a light breeze. When picking up the equipment it was again warm and dry with a light breeze.

#### 3.2 Results and Analysis

- 3.1 The results of the noise survey are presented in attached time history graph figure 17/0414/TH01. The noise climate was dominated by noise from the existing plant; with some contribution also from road traffic on from Saffron Hill, distant road traffic and intermittent construction noise. The effect of the existing plant can clearly be seen in the data whereby a drop in noise levels occurred at 2am.
- 3.2.1 The representative background noise levels, established through analysis of the measured levels in accordance with section 8 of BS4142:2014, are shown in the table below:



## Plant Noise Assessment

Location	Representative Background Noise Level, dB	
	Fully Operational (0600-2100)	Setback Mode (2100-0600)
MP1	59	51

T2 Representative background noise levels at the nearest residential properties.

- 3.2.2 These time periods have been chosen based upon the likely operating times noted by the client, rather than the more typical 'daytime' (0700-2300) and 'night' (2300-0700) periods. Although the condensers are not likely to operate over night when not required for this commercial office use, for the purpose of the assessment we have been robust and considered them operating at all times, but at a 'setback' mode as detailed in the manufactures operational handbook for the effective night time period.

### 3.3 Plant Noise Limits

- 3.2 The site falls within the jurisdiction of the London Borough of Camden. As part of the Camden Local Plan (Adopted June 2017), the following noise limits are proposed as part of Appendix 3: Noise Thresholds, linked to policy A4:

*'A relevant standard or guidance document should be referenced when determining values for LOAEL and SOAEL for non-anonymous noise. Where appropriate and within the scope of the document it is expected that British Standard 4142:2014 'Methods for rating and assessing industrial and commercial sound' (BS 4142) will be used. For such cases a 'Rating Level' of 10 dB below background (15 dB if tonal components are present) should be considered as the design criterion).'*

- 3.3.1 Therefore, based upon this guidance of 10dB below background, plant noise levels have been set for the nearest residential receivers and can be seen in the table below:

Location	Noise Emission Limit, dB	
	Fully Operational (0600-2100)	Setback Mode (2100-0600)
AP1 and AP2	49	41

T3 Plant noise emission limits at the nearest residential properties



## Plant Noise Assessment

3.3.2 Plant noise limits have been set at the two nearest residential properties. These are the most sensitive adjacent residential dwellings and so the noise limits will also be met at other nearby dwellings. The assessment positions are described here:

- AP1 – east-facing 1<sup>st</sup> floor residential window above plant pit
- AP2 – west-facing 1<sup>st</sup> floor residential window to southeast of site

## 4 Plant Noise Assessment

### 4.1 Details

4.1.1 Our assessment is based upon information and drawings provided by iceni projects. Noise data for the units were obtained from the manufacturers directly. The plant is to be located in a basement plant room, with louvered panel in the façade to provide airflow. Typically, such units draw air in through a louvre (for supply air) and the exhaust of the unit is then ducted to the façade.

4.1.2 The nearest noise sensitive receivers and their relative location to the plant are described in section 3.3.2 above. In summary they are:

- AP1: 1<sup>st</sup> floor apartment above plant
- AP2: 1<sup>st</sup> floor residence to southeast of site

4.1.3 Our assessment has taken into account distance and screening losses as appropriate. Full calculations can be seen in the attached calculation sheets 17/0414/CS1-10.

4.1.4 The proposed plant items and their associated noise levels are listed in the table below:

Unit	Sound Power Level (L <sub>w</sub> , dB) @							
	Octave Band Centred Frequency (Hz)							
	63	125	250	500	1k	2k	4k	8k
CU1: Daikin REYQ12T	74.5	81.5	81.0	80.5	75.5	70.5	65.5	61.5
CU2: Daikin REYQ20T	88.0	87.0	87.5	87.5	82.5	77.5	73.5	68.5

T4 Plant equipment noise levels

4.1.5 It can be seen that the plant is not tonal; therefore, no acoustic feature correction is necessary. In the calculation the noise from the units has been divided to account for the intake and the discharge separately, hence the differing levels used for these elements in the assessment.

4.1.6 Data obtained from Daikin on the relevant condenser units shows that the setback 'quiet noise mode' is 9 dB lower for the 12T model and 18 dB for 20T model. In both cases the reduction



## Plant Noise Assessment

is greater than the 8 dB difference between the fully operational and setback mode limits. Therefore, the more onerous criterion to meet is fully operational; if this is achieved, the setback mode limit will also be achieved.

- 4.1.7 It should also be noted that the condensers are only planned to be used when fully operational and the cutback mode is precautionary, as per section 3.2.2.

### 4.2 Required Mitigation Measures

- 4.2.1 The louvre that air is drawn into must be acoustically rated and comply with the insertion losses in the table below.
- 4.2.2 Exhaust air from the condensers must be ducted to terminate at the louvre. Silencers meeting the insertion losses in the table below must be placed in the appropriate duct runs.

Unit	Insertion Loss (dB) @ Octave Band Centred Frequency (Hz)							
	63	125	250	500	1k	2k	4k	8k
Acoustically rated louvre	5	7	10	12	14	16	13	12
CU1 – exhaust silencer	3	5	9	13	13	13	8	6
CU2 – exhaust silencer	5	11	19	25	25	25	20	15

#### T5 Required insertion losses

- 4.2.3 The above silencer specifications are expected to be achievable with standard splitter silencers ranging from 600-1200mm long, with free areas of 35-50%. The silencers should be sized to avoid significant pressure drops (ideally less than 40Pa, but a mechanical engineer should be consulted).
- 4.2.4 The performance required of the louvre should be achievable with a unit 300mm deep. This will though likely have a free open area of approximately 25-30% and the louvre should be sized to ensure suitable levels of airflow are provided into the internal plant room.
- 4.2.5 In addition to the silencers and louvre, the plant room walls should also have 6m<sup>2</sup> of absorbent treatment included, ideally close to the condensers. The product selected must be suitable for the environment of a plant room and the attached specification 17/0414/SPC1 should be followed; this details a common solution of tissue faced mineral wool (50mm thick) behind open metal mesh. Alternative options or products for the absorptive lining could be considered subject to technical review.

### 4.3 Assessment

- 4.3.1 With the mitigation measures in place we have assessed the following noise level at the closest receptor positions:





## Plant Noise Assessment

Location	Rating Noise Level, dB(A) <i>(Limit)</i> Fully Operational (0600-2100)
AP1: 1 <sup>st</sup> floor residential above	47 (49)
AP2: 1 <sup>st</sup> floor residential to southeast	49 (49)

T6 Assessed plant noise emission levels at the nearest noise sensitive properties,  $L_{Aeq, T}$

- 4.3.2 It can be seen that the plant noise limits should be achieved during the fully operational 'daytime', and therefore the noise limits outside of these hours will also be met on the assumption that they will either be non-operational or otherwise on a 'setback' duty due to the lower demand.
- 4.3.3 Full assessment calculations are attached as calculation sheets 17/0414/CS1-10 with summaries at positions AP1 and AP2 being the first 2 sheets presented.

## 5 Conclusion

- 5.1 Planning permission is being sought for the change of use of existing lower ground and part ground floor to office use Class B1 (a), together with minor external alterations at 44 Saffron Hill, London, EC1N 8FH. The development will include the installation of mechanical services plant items.
- 5.2 Cole Jarman have conducted an environmental noise survey at a location representative of the nearest noise sensitive properties and plant noise limits have been set considering local planning guidance.
- 5.3 This report has provided details of a plant noise assessment conducted for the site. The assessment has shown that with the proposed mitigation measures in place the noise limits specified should be met by the plant.

■ End of Section



## Plant Noise Assessment

# Glossary of Acoustic Terms

---

### $L_{Aeq}$ :

The notional steady sound level (in dB) which over a stated period of time, would have the same A-weighted acoustic energy as the A-weighted fluctuating noise measurement over that period. Values are sometimes written using the alternative expression dB(A)  $L_{eq}$ .

### $L_{Amax}$ :

The maximum A-weighted sound pressure level recorded over the period stated.  $L_{Amax}$  is sometimes used in assessing environmental noise when occasional loud noises occur, which may have little effect on the  $L_{Aeq}$  noise level. Unless described otherwise,  $L_{Amax}$  is measured using the “fast” sound level meter response.

### $L_{A10}$ & $L_{A90}$ :

If non-steady noise is to be described, it is necessary to know both its level and degree of fluctuation. The  $L_{An}$  indices are used for this purpose. The term refers to the A-weighted level (in dB) exceeded for n% of the time specified.  $L_{A10}$  is the level exceeded for 10% of the time and as such gives an indication of the upper limit of fluctuating noise. Similarly,  $L_{A90}$  gives an indication of the lower levels of fluctuating noise. It is often used to define the background noise.

$L_{A10}$  is commonly used to describe traffic noise. Values of dB  $L_{An}$  are sometimes written using the alternative expression dB(A)  $L_n$ .

### $L_{AX}$ , $L_{AE}$ or SEL

The single event noise exposure level which, when maintained for 1 second, contains the same quantity of sound energy as the actual time varying level of one noise event.  $L_{AX}$  values for contributing noise sources can be considered as individual building blocks in the construction of a calculated value of  $L_{Aeq}$  for the total noise. The  $L_{AX}$  term can sometimes be referred to as Exposure Level ( $L_{AE}$ ) or Single Event Level (SEL).

■ End of Section

Figure 17/0414/F1



Title: Site plan with noise survey measurement position


Project: 44 Saffron Hill

Date: June 2017

Scale: Not to scale



Figure 17/0414/TH01



## Specification 17/0414/SPC1

**Project:** 44 Saffron Hill  
**Subject:** Acoustic Lining  
**Date:** September 2017

### 1 General

This specification defines the applicable requirements for tissue faced, mineral fibre lining to the plant room. The suppliers of the materials shall provide the necessary information and data to verify the required performance.

The supplier shall be responsible for ensuring that all the performance criteria set out herein are met by the product being offered.

### 2 Products

The acoustic lining is to be supplied in the minimum thickness stated and shall be inorganic glass fibre material with a minimum density of 48 kg/m<sup>3</sup>. The material shall be provided with an erosion resistive acoustically transparent coating suitable for airflow velocities up to 15 m/s.

The sound absorption provided by the material (with and/or without the erosion resistive facing) shall meet or exceed the values tabulated below:

Minimum Thickness (mm)	Octave Band Centred Frequency (Hz)					
	125	250	500	1k	2k	4k
50	0.20	0.45	0.70	0.90	0.95	0.95

T1 Absorption Coefficients of Acoustically Absorbent Plant Area Lining

### 3 Execution

- 3.1 Attach to the surface of the plant room walls indicated in report 17/0414/R1.
- 3.2 All available portions of the area designed to receive the acoustic liner shall be completely covered. All joints shall be neatly butted and there shall be no interruptions or gaps.



## Specification


17/0414/SPC1

- 3.3 The erosion resistive face shall be orientated toward the plant room (not the wall).
- 3.4 The acoustic liner shall be secured with mechanical fasteners which shall compress the liner sufficiently to hold it firmly in place.
- 3.5 Liner shall be compressed to assure overlapped and compressed longitudinal corner joints.

 End of Section




**Project Name** 44 Saffron Hill  
**Project Reference** 17/0414  
**Receiver Reference** AP1  
**Description** Apartment above  
**Noise Limit** 49  
**dBA** 47



Reference	Noise Levels (dB)							
	63	125	250	500	1k	2k	4k	8k
CU1 - Discharge	36	47	43	36	25	15	14	10
CU2 - Discharge	48	46	40	32	19	11	10	7
CU1 - Intake	43	50	42	37	25	13	10	5
CU2 - Intake	57	55	49	45	31	21	18	11



<b>Project Name</b>	44 Saffron Hill
<b>Project Reference</b>	17/0414
<b>Receiver Reference</b>	AP2
<b>Description</b>	Apartments Opposite
<b>Noise Limit</b>	49
<b>dBA</b>	49



Reference	Noise Levels (dB)							
	63	125	250	500	1k	2k	4k	8k
CU2 - Discharge	52	50	44	36	28	23	24	23
CU1 - Discharge	40	51	47	40	34	27	28	26
CU1 - Intake	43	50	42	38	31	22	21	18
CU2 - Intake	57	55	49	46	37	30	29	24







17/0414/CS3

		Octave Band Centre Frequency (Hz)							
		63	125	250	500	1k	2k	4k	8k
<b>Point Source Radiation Loss</b>									
Radiation - Quarterspherical									
		-5.0	-5.0	-5.0	-5.0	-5.0	-5.0	-5.0	-5.0
<b>Silencer</b>									
Silencer - louvre									
		-5.0	-7.0	-10.0	-12.0	-14.0	-16.0	-13.0	-12.0
<b>Point Source Distance Loss</b>									
Start Distance (m)		1.0							
End Distance (m)		5.5							
		-14.8	-14.8	-14.8	-14.8	-14.8	-14.8	-14.8	-14.8
<b>Maekawa Screening Loss</b>									
Path Difference (m)		0.0							
		-4.9	-5.0	-5.2	-5.5	-6.2	-7.3	-8.8	-10.9
<b>External Receiver</b>									
External Receiver - AP1									
Sound Pressure, Lp		43.1	49.9	41.7	36.8	25.3	12.6	10.4	5.4





17/0414/CS4

		Octave Band Centre Frequency (Hz)							
		63	125	250	500	1k	2k	4k	8k
<b>Point Source Radiation Loss</b>									
Radiation - Quarterspherical									
		-5.0	-5.0	-5.0	-5.0	-5.0	-5.0	-5.0	-5.0
<b>Silencer</b>									
Silencer - louvre									
		-5.0	-7.0	-10.0	-12.0	-14.0	-16.0	-13.0	-12.0
<b>Point Source Distance Loss</b>									
Start Distance (m)		1.0							
End Distance (m)		5.5							
		-14.8	-14.8	-14.8	-14.8	-14.8	-14.8	-14.8	-14.8
<b>Maekawa Screening Loss</b>									
Path Difference (m)		0.0							
		-4.9	-5.0	-5.2	-5.5	-6.2	-7.3	-8.8	-10.9
<b>External Receiver</b>									
External Receiver - AP1									
Sound Pressure, Lp		57.1	54.9	48.7	44.8	31.3	20.6	18.4	11.4



## Calculation Sheet

17/0414/CS5

CU1 - Discharge to AP2



Octave Band Centre Frequency (Hz)								
	63	125	250	500	1k	2k	4k	8k

### Noise Source

Noise Source - CU1 - Discharge

Noise Levels	72.0	80.0	79.0	78.0	74.0	68.0	64.0	60.0
--------------	------	------	------	------	------	------	------	------

### Bend Loss CJ

Dimension (mm) 600.0

No. of Bends (no.) 2.0

Type - Radiussed Bend - With Vanes

	0.0	0.0	-2.0	-4.0	-6.0	-6.0	-6.0	-6.0
--	-----	-----	------	------	------	------	------	------

### End Reflection

Width/Diameter (m) 0.6

Length (m) 0.6

Rec or Circ - Circular

Free or Flush - Flush

	-8.0	-3.6	0.0	0.0	0.0	0.0	0.0	0.0
--	------	------	-----	-----	-----	-----	-----	-----

### External Grille Directivity

Width (m) 0.6

Height (m) 0.6

Vertical (°) 70.0

Horizontal (°) 45.0

	0.0	0.5	0.5	0.2	0.2	-0.5	-0.5	-0.5
--	-----	-----	-----	-----	-----	------	------	------

### Point Source Radiation Loss

Radiation - Quarterspherical

	-5.0	-5.0	-5.0	-5.0	-5.0	-5.0	-5.0	-5.0
--	------	------	------	------	------	------	------	------





17/0414/CS5

Octave Band Centre Frequency (Hz)								
	63	125	250	500	1k	2k	4k	8k
<b>Silencer</b>								
Silencer - CU1 - silencer								
	-3.0	-5.0	-9.0	-13.0	-13.0	-13.0	-8.0	-6.0
<b>Point Source Distance Loss</b>								
Start Distance (m)	1.0							
End Distance (m)	9.0							
	-19.1	-19.1	-19.1	-19.1	-19.1	-19.1	-19.1	-19.1
<b>Maekawa Screening Loss</b>								
Path Difference (m)	-1.0							
	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
<b>Facade Reflection</b>								
Reflection (dB)	3.0							
	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0
<b>External Receiver</b>								
External Receiver - AP2								
Sound Pressure, Lp	39.9	50.9	47.4	40.2	34.2	27.4	28.4	26.4



## Calculation Sheet

17/0414/CS6

CU2 - Discharge to AP2

		Octave Band Centre Frequency (Hz)							
		63	125	250	500	1k	2k	4k	8k
<b>Noise Source</b>									
Noise Source - CU2 - Discharge									
<b>Noise Levels</b>		86.0	85.0	86.0	86.0	80.0	76.0	72.0	66.0
<b>Bend Loss CJ</b>									
Dimension (mm)	600.0								
No. of Bends (no.)	2.0								
Type - Radiussed Bend - With Vanes									
		0.0	0.0	-2.0	-4.0	-6.0	-6.0	-6.0	-6.0
<b>End Reflection</b>									
Width/Diameter (m)	0.6								
Length (m)	0.6								
Rec or Circ - Circular									
Free or Flush - Flush									
		-8.0	-3.6	0.0	0.0	0.0	0.0	0.0	0.0
<b>External Grille Directivity</b>									
Width (m)	0.6								
Height (m)	0.6								
Vertical (°)	70.0								
Horizontal (°)	45.0								
		0.0	0.5	0.5	0.2	0.2	-0.5	-0.5	-0.5
<b>Point Source Radiation Loss</b>									
Radiation - Quarterspherical									
		-5.0	-5.0	-5.0	-5.0	-5.0	-5.0	-5.0	-5.0



17/0414/CS6

Octave Band Centre Frequency (Hz)								
	63	125	250	500	1k	2k	4k	8k
<b>Silencer</b>								
Silencer - CU2 - silencer								
	-5.0	-11.0	-19.0	-25.0	-25.0	-25.0	-20.0	-15.0
<b>Point Source Distance Loss</b>								
Start Distance (m)	1.0							
End Distance (m)	9.0							
	-19.1	-19.1	-19.1	-19.1	-19.1	-19.1	-19.1	-19.1
<b>Maekawa Screening Loss</b>								
Path Difference (m)	-1.0							
	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
<b>Facade Reflection</b>								
Reflection (dB)	3.0							
	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0
<b>External Receiver</b>								
External Receiver - AP2								
Sound Pressure, Lp	51.9	49.9	44.4	36.2	28.2	23.4	24.4	23.4





## Calculation Sheet

17/0414/CS7

CU1 - Discharge to AP1

		Octave Band Centre Frequency (Hz)							
		63	125	250	500	1k	2k	4k	8k
<b>Noise Source</b>									
Noise Source - CU1 - Discharge									
<b>Noise Levels</b>		<b>72.0</b>	<b>80.0</b>	<b>79.0</b>	<b>78.0</b>	<b>74.0</b>	<b>68.0</b>	<b>64.0</b>	<b>60.0</b>
<b>Bend Loss CJ</b>									
Dimension (mm)	600.0								
No. of Bends (no.)	2.0								
Type - Radiussed Bend - With Vanes									
		0.0	0.0	-2.0	-4.0	-6.0	-6.0	-6.0	-6.0
<b>End Reflection</b>									
Width/Diameter (m)	0.6								
Length (m)	0.6								
Rec or Circ - Circular									
Free or Flush - Flush									
		-8.0	-3.6	0.0	0.0	0.0	0.0	0.0	0.0
<b>External Grille Directivity</b>									
Width (m)	0.6								
Height (m)	0.6								
Vertical (°)	90.0								
Horizontal (°)	0.0								
		0.0	0.2	0.2	0.0	-4.0	-7.0	-7.0	-7.0
<b>Point Source Radiation Loss</b>									
Radiation - Quarterspherical									
		-5.0	-5.0	-5.0	-5.0	-5.0	-5.0	-5.0	-5.0



17/0414/CS7

Octave Band Centre Frequency (Hz)								
	63	125	250	500	1k	2k	4k	8k
<b>Silencer</b>								
Silencer - CU1 - silencer								
	-3.0	-5.0	-9.0	-13.0	-13.0	-13.0	-8.0	-6.0
<b>Point Source Distance Loss</b>								
Start Distance (m)	1.0							
End Distance (m)	5.5							
	-14.8	-14.8	-14.8	-14.8	-14.8	-14.8	-14.8	-14.8
<b>Maekawa Screening Loss</b>								
Path Difference (m)	0.0							
	-4.9	-5.0	-5.2	-5.5	-6.2	-7.3	-8.8	-10.9
<b>External Receiver</b>								
External Receiver - AP1								
Sound Pressure, Lp	36.3	46.9	43.3	35.7	25.0	15.0	14.4	10.3



## Calculation Sheet

17/0414/CS8

CU2 - Discharge to AP1

		Octave Band Centre Frequency (Hz)							
		63	125	250	500	1k	2k	4k	8k
<b>Noise Source</b>									
Noise Source - CU2 - Discharge									
<b>Noise Levels</b>		86.0	85.0	86.0	86.0	80.0	76.0	72.0	66.0
<b>Bend Loss CJ</b>									
Dimension (mm)	600.0								
No. of Bends (no.)	2.0								
Type - Radiussed Bend - With Vanes									
		0.0	0.0	-2.0	-4.0	-6.0	-6.0	-6.0	-6.0
<b>End Reflection</b>									
Width/Diameter (m)	0.6								
Length (m)	0.6								
Rec or Circ - Circular									
Free or Flush - Flush									
		-8.0	-3.6	0.0	0.0	0.0	0.0	0.0	0.0
<b>External Grille Directivity</b>									
Width (m)	0.6								
Height (m)	0.6								
Vertical (°)	90.0								
Horizontal (°)	0.0								
		0.0	0.2	0.2	0.0	-4.0	-7.0	-7.0	-7.0
<b>Point Source Radiation Loss</b>									
Radiation - Quarterspherical									
		-5.0	-5.0	-5.0	-5.0	-5.0	-5.0	-5.0	-5.0



17/0414/CS8

Octave Band Centre Frequency (Hz)								
	63	125	250	500	1k	2k	4k	8k
<b>Silencer</b>								
Silencer - CU2 - silencer								
	-5.0	-11.0	-19.0	-25.0	-25.0	-25.0	-20.0	-15.0
<b>Point Source Distance Loss</b>								
Start Distance (m)	1.0							
End Distance (m)	5.5							
	-14.8	-14.8	-14.8	-14.8	-14.8	-14.8	-14.8	-14.8
<b>Maekawa Screening Loss</b>								
Path Difference (m)	0.0							
	-4.9	-5.0	-5.2	-5.5	-6.2	-7.3	-8.8	-10.9
<b>External Receiver</b>								
External Receiver - AP1								
Sound Pressure, Lp	48.3	45.9	40.3	31.7	19.0	11.0	10.4	7.3





17/0414/CS9

		Octave Band Centre Frequency (Hz)							
		63	125	250	500	1k	2k	4k	8k
<b>Point Source Radiation Loss</b>									
Radiation - Quarterspherical									
		-5.0	-5.0	-5.0	-5.0	-5.0	-5.0	-5.0	-5.0
<b>Silencer</b>									
Silencer - louvre									
		-5.0	-7.0	-10.0	-12.0	-14.0	-16.0	-13.0	-12.0
<b>Point Source Distance Loss</b>									
Start Distance (m)		1.0							
End Distance (m)		9.0							
		-19.1	-19.1	-19.1	-19.1	-19.1	-19.1	-19.1	-19.1
<b>Facade Reflection</b>									
Reflection (dB)		3.0							
		3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0
<b>External Receiver</b>									
External Receiver - AP2									
Sound Pressure, Lp		43.2	50.1	42.1	37.5	31.3	22.1	21.5	18.5



## Calculation Sheet

17/0414/CS10

CU2 - Intake to AP2

		Octave Band Centre Frequency (Hz)							
		63	125	250	500	1k	2k	4k	8k
<b>Noise Source</b>									
Noise Source - CU2 - Intake									
<b>Noise Levels</b>		<b>84.0</b>	<b>83.0</b>	<b>84.0</b>	<b>84.0</b>	<b>78.0</b>	<b>74.0</b>	<b>70.0</b>	<b>64.0</b>
<b>Lw to LpRev (Src In Room)</b>									
Receiver - Plant Room									
		5.0	3.3	-0.7	-2.0	-2.3	-2.5	-2.1	-2.1
<b>End Reflection</b>									
Width/Diameter (m)	0.9								
Length (m)	1.8								
Rec or Circ - Rectangular									
Free or Flush - Flush									
		-2.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0
<b>External Grille Directivity</b>									
Width (m)	0.9								
Height (m)	1.8								
Vertical (°)	70.0								
Horizontal (°)	45.0								
		0.5	0.8	0.8	0.5	0.5	-0.5	-0.5	-0.5
<b>10 Log (X)</b>									
X ()	1.6								
		2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1
<b>Rev to Free Field</b>									
Scenario - Small Room, Refl Surface									
		-6.0	-6.0	-6.0	-6.0	-6.0	-6.0	-6.0	-6.0



17/0414/CS10

Octave Band Centre Frequency (Hz)								
	63	125	250	500	1k	2k	4k	8k
<b>Point Source Radiation Loss</b>								
Radiation - Quarterspherical								
	-5.0	-5.0	-5.0	-5.0	-5.0	-5.0	-5.0	-5.0
<b>Silencer</b>								
Silencer - louvre								
	-5.0	-7.0	-10.0	-12.0	-14.0	-16.0	-13.0	-12.0
<b>Point Source Distance Loss</b>								
Start Distance (m)	1.0							
End Distance (m)	9.0							
	-19.1	-19.1	-19.1	-19.1	-19.1	-19.1	-19.1	-19.1
<b>Facade Reflection</b>								
Reflection (dB)	3.0							
	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0
<b>External Receiver</b>								
External Receiver - AP2								
Sound Pressure, Lp	57.2	55.1	49.1	45.5	37.3	30.1	29.5	24.5



