

[REDACTED]

---

**From:** [REDACTED]  
**Sent:** 22 November 2017 17:31  
**To:** Planning  
**Subject:** 3rd Party Planning Application - 2017/6045/P

London Borough of Camden Our DTS Ref: 27832  
Camden Town Hall Your Ref: 2017/6045/P  
Argyle Street  
Euston Road  
London  
WC1H 8EQ

22 November 2017

Dear Sir/Madam

Re: GONDAR GARDENS RESERVOIR, GONDAR GARDENS, LONDON, NW6 1QF

Waste Comments

Thames Water would advise that with regard to sewerage infrastructure capacity, we would not have any objection to the above planning application.

‘We would expect the developer to demonstrate what measures he will undertake to minimise groundwater discharges into the public sewer. Groundwater discharges typically result from construction site dewatering, deep excavations, basement infiltration, borehole installation, testing and site remediation. Any discharge made without a permit is deemed illegal and may result in prosecution under the provisions of the Water Industry Act 1991. Should the Local Planning Authority be minded to approve the planning application, Thames Water would like the following informative attached to the planning permission: ‘A Groundwater Risk Management Permit from Thames Water will be required for discharging groundwater into a public sewer. Any discharge made without a permit is deemed illegal and may result in prosecution under the provisions of the Water Industry Act 1991. We would expect the developer to demonstrate what measures he will undertake to minimise groundwater discharges into the public sewer. Permit enquiries should be directed to Thames Water’s Risk Management Team by telephoning 02035779483 or by emailing [wwriskmanagement@thameswater.co.uk](mailto:wwriskmanagement@thameswater.co.uk). Application forms should be completed on line via [www.thameswater.co.uk/wastewaterquality](http://www.thameswater.co.uk/wastewaterquality).’

Thames Water recommends the installation of a properly maintained fat trap on all catering establishments. We further recommend, in line with best practice for the disposal of Fats, Oils and Grease, the collection of waste oil by a contractor, particularly to recycle for the production of bio diesel. Failure to implement these recommendations may result in this and other properties suffering blocked drains, sewage flooding and pollution to local watercourses.

Thames Water would recommend that petrol / oil interceptors be fitted in all car parking/washing/repair facilities. Failure to enforce the effective use of petrol / oil interceptors could result in oil-polluted discharges entering local watercourses.

Swimming Pools - Where the proposal includes a swimming pool Thames Water requests that the following conditions are adhered to with regard to the emptying of swimming pools into a public sewer to prevent the risk of flooding or surcharging: - 1.The pool to be emptied overnight and in dry periods. 2.The discharge rate is controlled such that it does not exceed a flow rate of 5 litres/ second into the public sewer network.

Water Comments


The existing water supply infrastructure has insufficient capacity to meet the additional demands for the proposed development. Thames Water therefore recommend the following condition be imposed:  
Development should not be commenced until: Impact studies of the existing water supply infrastructure have been submitted to, and approved in writing by, the local planning authority (in consultation with Thames Water). The studies should determine the magnitude of any new additional capacity required in the system and a suitable connection point. Reason: To ensure that the water supply infrastructure has sufficient capacity to cope with the/this additional demand.

Supplementary Comments

In reviewing the Councils' weekly list for planning applications, Thames Water has identified this application as one of interest to us. Whilst we recognise that there is no statutory requirement for you to consult us, we would respectfully ask to be pro-actively consulted on all similar applications in future, so that the adequate provision of water industry infrastructure can be assessed and considered as part of the decision process.

Yours faithfully  
Development Planning Department

Development Planning,  
Thames Water,  
Maple Lodge STW,  
Denham Way,  
Rickmansworth,  
WD3 9SQ

  
Email: devcon.team@thameswater.co.uk

This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to devcon.team@thameswater.co.uk