



**VINCENT
& RYMILL**

CONSULTING CIVIL & STRUCTURAL ENGINEERS

Lakeside Country Club, Frimley Green, Camberley, Surrey GU16 6PT
Tel: 01252 834242 - Fax: 01252 838989 - Email: frimley@vincenrymill.co.uk

To Whom it May Concern

207 Goldhurst Terrace, London, NW6 3ER

Planning Approval Ref No. 2015/4370/P

With respect to Condition 5 of the above Planning Approval I can confirm the following.

1. Further trial pit excavations have been made to identify the depth of party wall foundations. The findings of the trial pit are as expected, and no amendments are required to the B.I.A.
2. Condition surveys of adjoining properties have been made by the appointed surveyors. The findings of the surveys require no amendments are required to the B.I.A.
3. Investigations have shown that no surface water mitigation measures are required other than those temporary measures during construction to deal with minor perched water in excavations. No amendments are required to the B.I.A.



T. J. Vincent BSc C.eng M.I.Struct. E.