



London Borough of Camden Our DTS Ref: 98409  
Camden Town Hall Your Ref: 2017/6647/P  
Argyle Street  
Euston Road  
London  
WC1H 8EQ

12 December 2017

Dear Sir/Madam

Re: 6, PARSIFAL ROAD, LONDON, NW6 1UH

#### WASTE COMMENT

Thames Water requests that the Applicant should incorporate within their proposal, protection to the property by installing for example, a non-return valve or other suitable device to avoid the risk of backflow at a later date, on the assumption that the sewerage network may surcharge to ground level during storm conditions.

Legal changes under The Water Industry (Scheme for the Adoption of private sewers) Regulations 2011 mean that the sections of pipes you share with your neighbours, or are situated outside of your property boundary which connect to a public sewer are likely to have transferred to Thames Water's ownership. Should your proposed building work fall within 3 metres of these pipes we recommend you email us a scaled ground floor plan of your property showing the proposed work and the complete sewer layout to [developer.services@thameswater.co.uk](mailto:developer.services@thameswater.co.uk) to determine if a building over / near to agreement is required.

‘We would expect the developer to demonstrate what measures he will undertake to minimise groundwater discharges into the public sewer. Groundwater discharges typically result from construction site dewatering, deep excavations, basement infiltration, borehole installation, testing and site remediation. Any discharge made without a permit is deemed illegal and may result in prosecution under the provisions of the Water Industry Act 1991. Should the Local Planning Authority be minded to approve the planning application, Thames Water would like the following informative attached to the planning permission: “A Groundwater Risk Management Permit from Thames Water will be required for discharging groundwater into a public sewer. Any discharge made without a permit is deemed illegal and may result in prosecution under the provisions of the Water Industry Act 1991. We would expect the developer to demonstrate what measures he will undertake to minimise groundwater discharges into the public sewer. Permit enquiries should be directed to Thames Water’s Risk Management Team by telephoning 02035779483 or by emailing [wwriskmanagement@thameswater.co.uk](mailto:wwriskmanagement@thameswater.co.uk). Application forms should be completed on line via [www.thameswater.co.uk/wastewaterquality](http://www.thameswater.co.uk/wastewaterquality).”

Thames Water would advise that with regard to sewerage infrastructure capacity, we would not have any objection to the above planning application.

#### WATER COMMENT

On the basis of information provided, Thames Water would advise that with regard to water infrastructure

capacity, we would not have any objection to the above planning application.

Yours faithfully  
Development Planning Department

Development Planning,  
Thames Water,  
Maple Lodge STW,  
Denham Way,  
Rickmansworth,  
WD3 9SQ  
Tel:020 3577 9998  
Email: [devcon.team@thameswater.co.uk](mailto:devcon.team@thameswater.co.uk)

This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to [devcon.team@thameswater.co.uk](mailto:devcon.team@thameswater.co.uk)