

Oliver Coleman
Rolfe Judd Planning
Old Church Court
Claylands Road
London
SW8 1NZ

Application Ref: **2017/5364/P**
Please ask for: **Tessa Craig**
Telephone: 020 7974 **6750**

21 December 2017

Dear Sir/Madam

DECISION

Town and Country Planning Act 1990 (as amended)

Full Planning Permission Granted

Address:
Shropshire House
2-10 Capper Street
London
WC1E 6JA

Proposal: Installation of five external ducts, rooftop AHU plant, and reconfiguration of access door on western elevation at ground floor.

Drawing Nos: Environmental Noise Survey and Plant Noise Assessment Report 24376/PNA1 Rev2 21 September 2017, Design & access statement (71)001, 1370 (11) 001 Revision A2, 1370 (20) 007 Revision A2, 1370 (22) 007 Revision A2, 1370 (30) 001 Revision A2 and 1370 (32) 001.

The Council has considered your application and decided to grant permission subject to the following condition(s):

Condition(s) and Reason(s):

- 1 The development hereby permitted must be begun not later than the end of three years from the date of this permission.

Reason: In order to comply with the provisions of Section 91 of the Town and



Country Planning Act 1990 (as amended).

- 2 All new external work shall be carried out in materials that resemble, as closely as possible, in colour and texture those of the existing building, unless otherwise specified in the approved application.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policy D1 and D2 of the London Borough of Camden Local Plan 2017.

- 3 The development hereby permitted shall be carried out in accordance with the following approved plans:

Environmental Noise Survey and Plant Noise Assessment Report 24376/PNA1 Rev2 21 September 2017, Design & access statement (71)001, 1370 (11) 001 Revision A2, 1370 (20) 007 Revision A2, 1370 (22) 007 Revision A2, 1370 (30) 001 Revision A2 and 1370 (32) 001.

Reason: For the avoidance of doubt and in the interest of proper planning.

- 4 Noise levels at a point 1 metre external to sensitive facades shall be at least 5dB(A) less than the existing background measurement (LA90), expressed in dB(A) when all plant/equipment (or any part of it) is in operation unless the plant/equipment hereby permitted will have a noise that has a distinguishable, discrete continuous note (whine, hiss, screech, hum) and/or if there are distinct impulses (bangs, clicks, clatters, thumps), then the noise levels from that piece of plant/equipment at any sensitive façade shall be at least 10dB(A) below the LA90, expressed in dB(A).

Reason: To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policies G1, CC1, D1 and A1 of the London Borough of Camden Local Plan 2017.

- 5 Before the operation of the development, acoustic attenuation (as identified in the Environmental Noise Survey and Plant Noise Assessment Report prepared by Hann Tucker Associates) shall be provided for the proposed plant equipment in accordance with the approved details. The approved plant equipment thereafter shall be carried out in accordance with the approved scheme.

Reason: To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policies G1, CC1, D1, A1, and A4 of the London Borough of Camden Local Plan 2017.

Informative(s):

- 1 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts that cover aspects including fire and emergency escape, access and facilities for people with disabilities and sound insulation between dwellings. You are advised to consult the Council's Building Control Service, Camden Town Hall, Judd St, Kings Cross, London NW1 2QS (tel: 020-7974 6941).


- 2 Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You are advised to consult the Council's Noise and Licensing Enforcement Team, Camden Town Hall, Judd St, Kings Cross, London NW1 2QS (Tel. No. 020 7974 4444 or search for 'environmental health' on the Camden website or seek prior approval under Section 61 of the Act if you anticipate any difficulty in carrying out construction other than within the hours stated above.

In dealing with the application, the Council has sought to work with the applicant in a positive and proactive way in accordance with paragraphs 186 and 187 of the National Planning Policy Framework.

You can find advice about your rights of appeal at:

<http://www.planningportal.gov.uk/planning/appeals/guidance/guidancecontent>

Yours faithfully

A handwritten signature in black ink that reads "David T. Joyce". The signature is written in a cursive, slightly slanted style.

David Joyce
Director of Regeneration and Planning