

Mr Ryan von Ruben
Ryan von Ruben Architects
5 Dryden Street
LONDON
WC2E 9NB

Application Ref: **2007/0500/P**

Please ask for: **Paul Wood**

Telephone: 020 7974 **5649**

23 April 2007

Dear Sir/Madam

DECISION

Town and Country Planning Acts 1990 (as amended)

Town and Country Planning (General Development Procedure) Order 1995

Town and Country Planning (Applications) Regulations 1988

Full Planning Permission Granted

Address:

Southbury

144 Loudoun Road

London

NW8 0RY

Proposal:

Alterations to the top floor west elevation including replacement of existing windows and door to balcony by folding timber doors, and alterations to roof including installation of air-conditioning units and an openable roof light serving the top floor flat.

Drawing Nos: Site Location Plan; E-001; E-005; E-010; GA-001; GA-005A; GA-010A; Environmental Noise Assessment by Acoustics Plus Ltd dated February 2007; Toshiba product brochure R410A VRF Air-conditioning system; Glazing vision manufacturer's brochure.

The Council has considered your application and decided to grant permission subject to the following condition(s):

Condition(s) and Reason(s):

- 1 The development hereby permitted must be begun not later than the end of three



years from the date of this permission.

Reason: In order to comply with the provisions of Section 91 of the Town and Country Planning Act 1990 (as amended).

- 2 All new external work shall be carried out in materials that resemble, as closely as possible, in colour and texture those of the existing building, unless otherwise specified in the approved application.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policies S1/ S2 and B1 of the London Borough of Camden Replacement Unitary Development Plan 2006.

- 3 Noise levels at a point 1 metre external to sensitive facades shall be at least 5dB(A) less than the existing background measurement (LA90), expressed in dB(A) when all plant/equipment are in operation unless the plant/equipment hereby permitted will have a noise that has a distinguishable, discrete continuous note (whine, hiss, screech, hum) and/or if there are distinct impulses (bangs, clicks, clatters, thumps), then the noise levels from that piece of plant/equipment at any sensitive façade shall be at least 10dB(A) below the LA90, expressed in dB(A).

Reason: To safeguard the amenities of the adjoining premises in accordance with the requirements of policies SD6, SD7B, SD8 and Appendix 1 of the London Borough of Camden Replacement Unitary Development Plan 2006.

Informative(s):

- 1 Reasons for granting permission.

The proposed development is in general accordance with the policy requirements of the London Borough of Camden Replacement Unitary Development Plan 2006, with particular regard to policies S1, S2, SD6, SD7, SD8, B1 and B3. For a more detailed understanding of the reasons for the granting of this planning permission, please refer to the officers report.

- 2 Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You are advised to consult the Council's Environmental Health Service, Camden Town Hall, Argyle Street, WC1H 8EQ (Tel. No. 020 7974 2090 or by email env.health@camden.gov.uk or on the website www.camden.gov.uk/pollution) or seek prior approval under Section 61 of the Act if you anticipate any difficulty in carrying out construction other than within the hours stated above.
- 3 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts. You are advised to consult the Council's Building Control

Service, Camden Town Hall, Argyle Street WC1H 8EQ, (tel: 020-7974 6941).

Your attention is drawn to the notes attached to this notice which tell you about your Rights of Appeal and other information.

Yours faithfully

A handwritten signature in black ink, appearing to read 'Robert Scarfield'.

Culture and Environment Directorate
(Duly authorised by the Council to sign this document)

It's easy to make, pay for, track and comment on planning applications on line. Just go to www.camden.gov.uk/planning.