



NOTES:
All dimensions must be checked on site and not scaled from this drawing.

A	Date	Revisions

BBS TECHNICAL SERVICES
Water Engineers
12 Long Copse Close - Great Bookham
Nr. Leatherhead - Surrey KT23 3PX
Tel: 01372 456 234 - Fax: 01372 451 619
email: michael.braid1@ntlworld.com

Client
Job Title
24 HEATH DRIVE
LONDON
NW 3 7 SB

Drawing Title
SWIMMING POOL
BLOCK WIRING DIAGRAM

Scale
Date **Jan 2018** Drawn by **M.B.**

Drwg. No. **HCS 1502 008** Rev.

- a. Low Level Shut Down of Circulation Pump
- b. High Level Alarm.
- c. Make Up Close.
- d. Make Up Open.

Note In Flood Alarm CONDITION. Note ALL SPRING RETURN TO CLOSE. Circulation TO STOP.