

LDC (Proposed) Report		Application number	2017/6897/P
Officer		Expiry date	
Tony Young		26/02/2018	
Application Address		Authorised Officer Signature	
16 Solent Road LONDON NW6 1TU			
Conservation Area		Article 4	
No		No	
Proposal			
Rear dormer and roof extension to dwellinghouse			
Recommendation:		Grant lawful development certificate	

Class B		
The enlargement of a dwellinghouse consisting of an addition or alteration to its roof		
If YES to any of the questions below the proposal is not permitted development:		Yes/No
B.1(a)	Is permission to use the dwellinghouse as a dwellinghouse been granted only by virtue of Class M, N, P or Q of Part 3 of this Schedule (changes of use)?	No
B.1(b)	As a result of the works, would any part of the dwellinghouse exceed the height of the highest part of the existing roof?	No
B.1(c)	As a result of the works, would any part of the dwellinghouse extend beyond the plane of any existing roof slope which forms the principal elevation of the dwellinghouse and fronts a highway?	No
B.1(d)	As a result of the works, would the cubic content of the resulting roof space exceed the cubic content of the original roof space by more than— (i) 40 cubic metres in the case of a terrace house, or (ii) 50 cubic metres in any other case?	No
B.1(e)	Would it consist of or include— (i) the construction or provision of a veranda, balcony or raised platform, or (ii) the installation, alteration or replacement of a chimney, flue or soil and vent pipe; or	No
B.1(f)	Is the dwellinghouse on article 2(3) land?	No
Conditions. If NO to the question below then the proposal is not permitted development:		
B.2(a)	Would the materials used in any exterior work be of a similar appearance to those used in the construction of the exterior of the existing dwellinghouse?	Yes
B.2(b)(i)	Other than in the case of a hip-to-gable enlargement or an	Yes

	enlargement which joins the original roof to the roof of a rear or side extension, would the enlargement be constructed so that— (aa) the eaves of the original roof are maintained or reinstated?; and (bb) the edge of the enlargement closest to the eaves of the original roof be less than 20 centimetres from the eaves measured along the roof slope from the outside edge of the eaves, so far as practicable?; and	
B.2(b)(ii)	Other than in the case of an enlargement which joins the original roof to the roof of a rear or side extension, no part of the enlargement would extend beyond the outside face of any external wall of the original dwellinghouse; and	Yes
B.2(c)	Would any windows inserted on a wall or roof slope forming a side elevation of the dwellinghouse— (i) be obscured-glazed; and (ii) be non-opening unless the opening part is higher than 1.7 metres above the floor of the room in which the window is installed?	n/a
Recommendation: Grant lawful development certificate		