

Mr Malcolm Fryer
Malcolm Fryer Architects
Unit 7
The Ivories
6 Northampton Street
London
N1 2HY

Application Ref: **2017/6676/L**
Please ask for: **Robert Lester**
Telephone: 020 7974 **2188**

12 March 2018

Dear Sir/Madam

DECISION

Planning (Listed Building and Conservation Areas) Act 1990

Approval of Details (Listed Building) Granted

Address:

**The Danish Church
St Katharine's Precinct
London
NW1 4HH**

Proposal:

Details of the cleaned stonework and new surface materials including stone and mortar pursuant to planning condition 4 of listed building consent application ref: 2016/6877/L dated 17/02/2017 (External masonry repairs to the west, north and south facades and to the turrets. Structural repairs to the turrets at high level. Installation of new fixed metal platforms and ladders within each turret to provide access within turrets and to roof from gallery level and the addition of access to the clock chamber via roof hatch from south turret roof access door).

Drawing Nos: Stone sample for stone renewal and indent repairs (Stoke Ground Bath Stone Base Bed), Lime Mortar sample for lime mortar repairs (2 parts Bath stone dust finish; 1 part Portland stone dust finish; 1 part Natural Hydraulic Lime NHL 3.5) Lime Mortar sample for repointing (3 parts Bath stone dust backing; 1 part Natural Hydraulic Lime NHL 3.5) - Photographs submitted and Samples Inspected on site.

The Council has considered your application and decided to grant Approval of Details (Listed Building) subject to the following condition(s):




Informative(s):

- 1 The proposed materials would provide a good match in texture, colour and tone to the existing materials used on the Grade II* Listed St. Katharine's Danish Church. The proposed materials would preserve the listed building and its features of special architectural or historic interest and would preserve the character and appearance of the conservation area in accordance with Camden Local Plan Policy D2. Overall, the proposals would preserve and enhance the character and setting of the heritage asset and the repairs will secure the long term health of the Church, which will see the building removed from Historic England's Heritage At Risk register.
- 2 You are advised that all conditions relating to listed building consent 2016/6877/L dated 17/02/2017 which need details to be submitted, have been approved.

You can find advice about your rights of appeal at:

<http://www.planningportal.gov.uk/planning/appeals/guidance/guidancecontent>

Yours faithfully

A handwritten signature in black ink that reads "David T. Joyce". The signature is written in a cursive, slightly slanted style.

David Joyce
Director of Regeneration and Planning