


4-1. Sound pressure level



Model	Pressure	Unit: dB(A)
AM080FXVAGH***, AM080FXVAGR***	57	
AM100FXVAGH***, AM100FXVAGR***	58	
AM120FXVAGH***, AM120FXVAGR***	62	
AM140FXVAGH***, AM140FXVAGR***	61	
AM160FXVAGH***, AM160FXVAGR***	63	
AM180FXVAGH***, AM180FXVAGR***	64	
AM200FXVAGH***, AM200FXVAGR***	65	
AM220FXVAGH***, AM220FXVAGR***	67	

GROUND FLOOR
SECOND FLOOR


Note

- ◆ Measuring place: Anechoic chamber (conversion value)
- ◆ These operation values were obtained in an anechoic room. Sound pressure level will vary depending on a range of factors such as the construction of the particular room where the equipment is installed.
- ◆ Operation sound level may differ depending on operation and ambient conditions.


Outdoor units

4-2. NC curves


1) AM080FXVAGH***, AM080FXVAGR***



2) AM100FXVAGH***, AM100FXVAGR***



3) AM120FXVAGH***, AM120FXVAGR***



4) AM140FXVAGH***, AM140FXVAGR***

