



DO NOT SCALE

THE CONTRACTOR SHALL SUPPLY & INSTALL NEW THROUGH THE WALL EXTRACTOR FAN CONTROLLED VIA PIR.
MANUFACTURER: NUJARE
MODEL: XS6 WA EXTRACT
DUTY: 21 l/s @ 10 Pa
CONTROL: REMOTE PIR SENSOR XS-PIR-R
SPEED CONTROLLER: XS MFC

FOR CONTINUATION PLEASE REFER TO VIEW BELOW FROM LEFT

ALL DIMENSIONS, LEVELS AND CLEARANCES TO BE CHECKED ON SITE PRIOR TO WORKS COMMENCING.
THIS DRAWING SHOULD BE READ IN CONJUNCTION WITH ALL OTHER PROJECT RELATED DRAWINGS, SPECIFICATIONS AND DOCUMENTS AS PART OF A SINGLE PROJECT PACKAGE.
ANY DISCREPANCY BETWEEN THIS DRAWING, OTHER DRAWINGS FORMING PART OF THIS CONTRACT, OR THE SPECIFICATION / BILLS OF QUANTITIES MUST BE CLARIFIED BEFORE COMMENCEMENT OF ANY WORK OR ORDERING OF ANY MATERIALS.
PLEASE CONSULT THE AUTHOR OR PROJECT MANAGER SHOULD THE READER REQUIRE CLARIFICATION ON ANY PART OF THIS DRAWING.
THE COPYRIGHT OF THE DRAWING AND DESIGN IS THE PROPERTY OF THE COMPANY. THIS INFORMATION HAS BEEN ISSUED UNDER SPECIFIC TERMS FOR THIS PROJECT AND MAY ONLY BE USED AND REPRODUCED ACCORDINGLY.

NOTES

- THE CONTRACTOR SHALL RUB DOWN & RE-PAINT ALL EXPOSED HEATING PIPEWORK SERVING EXISTING RADIATORS.
- CONTRACTOR SHALL SUPPLY & INSTALL WC EXTRACT FAN UNIT, EF1 TO BE CONTROLLED VIA LIGHTING CIRCUIT.
- CONTRACTOR SHALL PROVIDE & INSTALL KITCHENETTE EXTRACT EF2 CONTROLLED VIA HUMIDISTAT & CAPABLE OF BEING SPEED CONTROLLED.
- CONTRACTOR SHALL PROVIDE & INSTALL PLENUM BOX.

KEY:

EXISTING RADIATORS, HEAT EMITTERS & HTG F&R PIPEWORK SHALL BE RETAINED & REUSED WITHIN THE NEW SCHEME. THE CONTRACTOR SHALL RUB DOWN & REPAINT EXPOSED HTG F&R PIPEWORK & HEAT EMITTERS. THE FINAL COLOUR TO BE AGREED WITH ARCHITECT.

CO1	12.03.18	SH	DJ	Issued for Tender
PO1	27.02.18	SH	DJ	Preliminary Issue for Comments
Rev	Date	By	Chk	Comment



FRANKHAM

Frankham Consultancy Group Limited
E: enquire@frankham.com
www.frankham.com

SIDCUP OFFICE Irene House Five Arches Business Estate, Maddesons Road, Sidcup, Kent DA14 5AE T: 020 8309 7777 F: 020 8309 7890	OXFORD OFFICE Woodton Business Park Besselsleigh Road Woodton, Altonham, Oxfordshire OX12 6ED T: 01865 322504 F: 01865 327393
--	---

LONDON OFFICE 3rd Floor 15-17 St Cross St, London EC1N 8JW T: 020 7653 0790 F: 020 7248 3144	HAYWARDS HEATH OFFICE 1st Floor 21 Perryman Road, Haywards Heath, RH16 3TP T: 01444 444000 F: 01444 455642
---	--

Client:

British Museum
SAP Work 2018

Project Title:

West Residence and Panizzi Suite

Drawing Title:

Panizzi Suite
Level 2
Mechanical Services
Proposed Heating and Ventilation
Layout

Status:

TENDER ISSUE

Drawn By: OH	Designed By: DJ	Checked By: SH	Approved By: MJC
-----------------	--------------------	-------------------	---------------------

Original Issue Date: 27/02/2018	Scale @ A1: 1:50
------------------------------------	---------------------

Job No/ File Ref		Originator	Zone	Level
226961		FCG	MB	02
Type	Discipline	Number	Suitability	Revision
DR	M	5602	D2	C01

12/03/2018 11:04:38

X:\200000\226961 - British Museum - Panizzi Suite, Additional Toilet Provision\02-Drawings\04-MEP Eng\01M-WIP Drawings 2D-Mech\56XX-Space Heating\226961-FCG-MB-02-DR-M-5602-D2-C01.dwg