

MEMO



To: Emma Dymond - Skanska

From: Paul Harris, Associate

Cc:

Date: 13 March 2018

Project: GOSH ZCR

File ref:

Subject: Planning Condition 13 - CHP

Tel +44 (0) 20 3668 7100
Fax +44 (0) 20 3479 1591

Western Transit Shed
12-13 Stable Street
London
N1C 4AB

Regarding the Hoval PowerBloc EG (20) combined heat and power plant technical submission.

We have reviewed this submission and consider that this unit does meet the Mayor's Band B NOx emissions standards and that no further mitigation measures are required.

The technical data confirms that the unit has NOx exhaust emissions of $<45\text{mg}/\text{Nm}^3$ and as such meets the GLA band B NOx emission rating of $95\text{ mg}/\text{Mm}^3$.