

## OC INNOVATIONS - OC1

### Process Information

Oxidation using ozone and activated oxygen ions is used to treat odour emissions from commercial and industrial kitchen processes (DEFRA, 2005: Guidance on the Control of Odour and Noise from Commercial Kitchen Exhaust Systems).

The OC1 has been specifically designed for use in commercial kitchens. The system injects ozone into the kitchen extraction canopy where it reacts with odours, which are oxidized in a chemical reaction, which results in the production of carbon dioxide and water vapour. The ozone itself is consumed during the process and is converted back into oxygen.

### The benefits of purchasing an OC1 unit over traditional UV/Ozone systems are as follows:

- Compact, lightweight and quiet operation so is less obtrusive
- Quick and easy low cost installation
- Low capital and running costs – up to 50% less than traditional UVC systems
- Injection into ductwork – adding negligible back pressure to the system so requiring less energy to push air through the air handling system. This means less ductwork modifications
- The OC1 professional maintains efficiency as they remain outside of the air stream, they also require less maintenance and require less cleaning.
- Tested to EN13725:2003, CE Approved



**Spec sheet overleaf >**

## OC INNOVATIONS - OC1 (SPECIFICATIONS)

### TECHNICAL INFORMATION

Ozone Output:	10g/hr ozone output
Housing dimensions:	290mm W 290mm L 290mm H
Housing material:	Stainless Steel powder coated black
Duct work connection:	100mm circular
Volume flow rate in ductwork:	Up to 1.2m <sup>3</sup> /s per unit, subject to cooking odours.
Air residence time inside chamber:	>0.1 seconds
Pressure drop:	N/A
Weight of unit:	10Kg approx.
Electrical requirements:	240V / 1 ph / 50/60Hz
Power requirements:	168W
Safety:	THE UNIT MUST BE INTERLOCKED IN TO FAN CONTROL SYSTEM

### INSTALLATION

It is recommended to locate the units with an injection point located closest to the source of odours (i.e. Canopy plenum or nearest accessible point on ductwork, in order to maximize dwell time. In any case the dwell time must be no less than 1 second.

The system is powered via a fused spur/socket, which is interconnected to the main extraction fan control to ensure that the OC1 units only operate when the main fan is operating.

THE UNIT MUST BE INTERLOCKED INTO THE FAN CONTROL SYSTEM

### MAINTENANCE

An optional service contract is available which entails a yearly inspection of the unit. Please contact us for further information and pricing.