



Fire Strategy Key

30 Mins Fire Resistance.

Denotes Escape Route.

Means of Escape.

Fire Door - FD30-S.

Fire Door - Existing door to be coated with Nulifire intumescent coating to habitable room side

Ceiling hatch with pull down ladder to provide escape route to roof level.

S

Smoke Detector.

H

Heat Detector.

Additional Notes

A

Fire Alarm to be a category LD1 2 system to BS5839 Part 6.

Rev -

19.03.18

Issued for Planning

PLANNING

Project No.	17103		
Client	GFZ Investments Ltd.		
Date	January 2018		
Scale	1:50 @ A2		
Project	34 Great James Street		
Drawing Title:	First Floor Plan - Fire Strategy		
Drawing No.	200_603	Rev.	-
Drawn	Approved	Signed	
TMC	MW		

Marek Wojciechowski Architects

66-68 Margaret Street W1W 8SR T. 020 7580 9336 www.mw-a.co.uk

Copyright Marek Wojciechowski Architects Limited. No implied license exists. This drawing should not be used to calculate areas for the purposes of valuation. All dimensions to be checked on site by the contractor and such dimensions to be their responsibility. Do not scale drawings. All work must comply with relevant British Standards and Building Regulations requirements. Drawing errors and omissions to be reported to the architect.

0 0.5m 1m 2m 3m