


BUREAU VERITAS BUILDING CONTROL UK SITE INSPECTION RECORD

Project Number:	B17030649				
Project Description & address:	Conversion of flats to form single dwelling including erection of new basement and two storey rear bay window extension at 35 Elsworth Road, London, NW3 3BT				
Client Name/reference	Deacon and Jones	Date Initial Notice served:	01.11.2017		
Surveyor:	Prakash Kalyan	Contact number:	07791 724 112		
Contractor:	TBC	Site contact in attendance:	TBC		
Date of inspection :	24.11.17	Time of inspection :	PM	Inspection No:	1
Reason for inspection:	Commencement , Excavations, Foundations, Underground drainage, Damp proofing, Sound Insulation, Superstructure, Thermal Insulation, Fire Safety, Accessibility, Building Services, Protection from falling, collision and impact, completion, other				
Weather Conditions: Dry					
Inspection comments					
Certificates or Notices received Yes / No			Photographs Yes / No		
Status of works on site	Piling commenced				
	Comments			Photographs	
Observations/comments by area inspected	5 piles marked out for drilling. 2 completed at the time of the inspection approximately 10m deep 2 reinforcements were ready to be positioned into the pile				
Non-compliance/possible non-compliance by area inspected	Pile log to be provided				
Previous non-compliances resolved including evidence provided and date					
Next Inspection					
Note: This site inspection report is restricted to requirements under the Building Regulations current at that time. It does not constitute evidence that the Building Regulations have been satisfied until a Final Certificate has been issued for the project. It remains the responsibility of the person carrying out the work to ensure that the work complies with the Building Regulations					
Signature of Surveyor:	Prakash Kalyan	Date:	08.12.17		
Signature of contractor:		Date:			

x I confirm I have read and understood Bureau Veritas Building Control UK's risk assessments and procedures for site visits