



London Borough of Camden Our DTS Ref: 55997  
Camden Town Hall Your Ref: 2018/1270/P - Ammended Response  
Argyle Street  
Euston Road  
London  
WC1H 8EQ

27 April 2018

Dear Sir/Madam

Re: PARLIAMENT HILL SCHOOL & WILLIAM ELLIS SCHOOL, HIGHGATE ROAD, LONDON,  
NW5 1RL

#### Waste Comments

Thank you for consulting Thames Water for the discharge of matters relating to piling. Thames Water confirm they are happy for the piling condition referenced, to be discharged based on the information submitted.

#### Water Comments

#### Supplementary Comments

Thames Water have reviewed the information provided and agrees to discharge the conditions. This is based on the understanding that piling works are carried out outside of Thames Water assets exclusion zone as per the impact assessment X2039/862. Please advise Thames Water if these plans change so that we can re-assess the risk to our assets. Please discharge Condition 24.

Please see the guidance document 'Working Near Our Assets' available at the following link for more details on Thames Water policy with regards to piling, demolition, excavation and abnormal loading: (available online at <https://developers.thameswater.co.uk/developing-a-large-site/planning-your-development/working-near-or-diverting-our-pipes> ).

Plans of Thames Water apparatus can be obtained through our website at [www.thameswater-propertysearches.co.uk](http://www.thameswater-propertysearches.co.uk). Please contact Developer Services if you wish to discuss further (by email at [developer.services@thameswater.co.uk](mailto:developer.services@thameswater.co.uk) / [DSCLX2039@thameswater.co.uk](mailto:DSCLX2039@thameswater.co.uk) ). Please use the following reference in all future correspondence: DTS 55997

Demolition, piling and excavation works all have the potential to adversely impact Thames Water assets. Please bear in mind that Thames Water will hold the developer and any relevant contractor/sub-contractor liable for any losses incurred or damage caused to Thames Water assets arising from construction works or

subsequent use of the facility.

Yours faithfully  
Development Planning Department

Development Planning,  
Thames Water,  
Maple Lodge STW,  
Denham Way,  
Rickmansworth,  
WD3 9SQ  
Tel:020 3577 9998  
Email: [devcon.team@thameswater.co.uk](mailto:devcon.team@thameswater.co.uk)

This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to [devcon.team@thameswater.co.uk](mailto:devcon.team@thameswater.co.uk)