



Typical Type 7 Window Elevation 1:10 @ A1

- Fourth and Fifth story extensions to use Natural Anodised Aluminium cladding, see accompanying manufacturers details for fixings.
- Polished stainless steel cladding to be fixed to the underside of all 5th floor cantilevers.
- Window frames to be visually concealed behind cladding.
- Perforated Natural Anodised Aluminium panels to be used in front of all bathroom windows to provide privacy.
- Line of concealed window frame behind.
- Fixed shut window glazing to meet standards set out in acoustic engineers report, Glazing to provide R_{63Hz} 31 dB and R_{125Hz} 33 dB performance.



Typical Type 7 Window Section showing Head and Sill 1:10 @ A1



Typical Type 7 Window Plan showing Jamb 1:10 @ A1

- 3mm Natural Anodised Aluminium cladding with secret fixing. 75 mm Acoustic Insulation. Vapour barrier. 2 x 10mm Cementitious boards. Window Frames to be visually concealed behind anodised aluminium cladding.
- 2 x 15mm Plasterboard with 3mm skim plaster finish. 25mm Acoustic insulation with acoustic isolator track, fixed to floor and soffit. 100mm Thermal insulation Infill Structural Framing System.

NOTES

- Do not scale off these drawings. Dimensions govern.
- All dimensions are given in millimetres (mm) unless otherwise noted.
- All dimensions shall be verified on site before proceeding with the work contractor before construction and fabrication commences.
- Workmanship and materials to be accordance with the relevant current British Standard Codes of Practice and the Local Authorities requirements.
- During construction the contractor shall be responsible for maintaining the structure in a stable condition.
- These drawings are to be read in conjunction with all other contract documentation and other consultants documentation.
- If in doubt, ask!

Rev	Date	Reason for Issue	ch'd
PL-02	18-04-2018	Planning Conditions	AK
PL-01	05-03-2018	Planning Conditions	JG
PL-00	01-02-2018	Planning Conditions	JG

ambigram architects

The studio, 5 Great James Street, Bloomsbury London WC1N 3DB

www.ambigramarchitects.com
info@ambigramarchitects.com

© Copyright 2015 ambigram architects ltd

Bayham Place 48-56 Bayham Place London NW1 0EU

Project

Condition 4 - Window Type 7

Title

AA-A-1702	JP	PL-02
Job number	Drawn	Revision
July 2017		
Date		1:10 @A1
0806		1:20 @A3
Drawing no		Scale