

SAMPLE/MOCK-UP CONDITION DISCHARGE FORM 01

597 – The Honourable Society of Lincoln’s Inn

Date: 11.05.18

PLANNING APPLICATION REF: 2015/4500/L

Condition Number: Cond 4 - Samples of new flooring material for the Great Hall

Sample/Mock-up: Sample of proposed engineered timber flooring

Location/s in final build: Great Hall

Date of review with Conservation Officer: 27.07.17 (on site)

Description: 100mm wide, 22mm thick, tongue and grooved engineered European oak flooring. Quarter Cut. Ammonia fumed to match colour of timber wall panelling.

Photographs:



1. Photograph of sample of proposed timber flooring against existing timber wall panelling

Associated information: Drawings 597-19185-PL1, 43060-C4, 43060B-C1, 43060C-C1 & 43061-C6. Extract of Rick Mather Architect’s specification K21