

Acoustic Consultancy Partnership Ltd

Ground Floor, Building 1000, Lakeside North Harbour Western Road, Portsmouth, Hampshire, P06 3EZ Tel: 023 9270 4133 | Fax: 023 9270 4001 | info@acpltd.org.uk

Acoustic Consultancy Report

Environmental Noise Survey Results, Local Authority Plant Noise Requirements and Garage Enclosure Plant Noise Impact Assessment

6 Templewood Avenue

Client:	c/o Red Square
Project:	6 Templewood Avenue London NW3 7XA
Our Ref:	10858/1
Revision:	0
Survey Completed By	N. Fowler M.I.O.A.
Report Prepared By	N. Fowler M.I.O.A.
Date:	30 th May 2018



1.0 Introduction

- 1.1 ACP Ltd were requested by Red Square to carry out environmental noise monitoring, determine the plant noise criteria and provide a noise impact assessment for a proposed Garage enclosure at 6 Templewood Avenue, in line with the London Borough of Camden standard noise requirements.
- 1.2 This report provides the results of our environmental noise survey and establishes the specific plant noise criteria, based on the London Borough of Camden standard requirements and the response from The London Borough of Camden to the pre-application enquiry dated 13th March 2018.
- 1.3 The predicted plant noise levels for the proposed plant have been established based on the plant selection and noise data. A plant noise assessment has been included within this report detailing the resultant noise levels at the nearest and most affected noise sensitive properties. The nearest residential window adopted in this revised assessment report would be the rear elevation to No 8 Templewood Avenue.
- 1.4 The resultant plant noise levels have been compared to the required target noise levels in accordance with the London Borough of Camden standard noise requirements and mitigation measures proposed as appropriate.

2.0 Site Layout and Nearest Noise Sensitive Buildings

- 2.1 No 6 Templewood Avenue is a large detached property located on the junction of Templewood Avenue and Templewood Gardens.
- 2.2 The proposed plant would consist of two Mitsubishi air conditioning condensing unit, located in the rear part of the existing garage building at the rear south east elevation of the building. The existing garage building is constructed with brick walls and solid roof. There will be louvred openings in the front face of the enclosure for attenuated fresh air supply into the enclosure and attenuated discharge air from the enclosure.
- 2.3 The front face of the enclosure will be orientated so that the intake and discharge openings face south east towards the consulate building.



- 2.4 The nearest residential property facades would be as follows:
 - RPA The rear of No 8 Templewood Avenue to the north west. The proposed unit would be approximately 10m from the first floor rear façade and at an angle of, at least 90 degrees to the enclosure intake and discharge.
 - RPB The front elevation of the consulate building to the south of the site. The proposed unit would be approximately 40m from the front façade and with line of sight to the enclosure intake and discharge.
 - RPC The front elevation of the building on the opposite side of Templewood Gardens. The proposed unit would be approximately 45m from the front façade and with line of sight at an angle of 45 degrees to the enclosure intake and discharge.
- 2.5 A site plan is provided in Appendix 2

3.0 Plant and Enclosure Information

- 3.1 The proposed plant would consist of two Mitsubishi PUMY-SP-140VKM condensing units, located in rear part of the existing garage building at the rear south east elevation of the building within an attenuated plant enclosure.
- 3.2 The units have the following manufacturers noise data based on standard mode operation.

	Air Conditioning Plant Manufacturers Noise Data Sound Pressure Level, dB at 1m											
Unit	Unit 63Hz 125Hz 250Hz 500Hz 1kHz 2kHz 4kHz 8kHz dBA											
PUMY-SP-140VKM	62	58	56	53	52	47	41	34	56			

3.3 The above manufacturers noise data was measured in free field conditions over a reflecting plane. The manufacturers are unable to provide sound power level data for these units. We note the overall sound power level in cooling mode is given as 74dBA. Using the highest octave band sound pressure levels provided by the manufacturers we have assessed the probable octave band sound power level and this has been adopted for our calculations.



- 3.4 We understand the units could operate at any time during a 24 hour period on any day of the week.
- 3.5 The orientation of the enclosure, relating to the three receptor positions, is detailed in section 2.4.

4.0 Environmental Noise Monitoring Location

- 4.1 Extended, unmanned environmental noise monitoring was completed in the rear garden of the property with the microphone set up on an extension pole mounted on a tripod.
- 4.2 The position was considered representative of the existing noise climate affecting the facades of the adjacent dwellings.

5.0 Monitoring Equipment

- 5.1 The noise monitoring equipment comprised of a Svantek 971 type 1 real time analyser, serial number 34934. A weatherproof microphone protection system was also used.
- 5.2 The meter calibration was verified before and after the measurement period by a Svantek SV31 acoustic calibrator, serial number 24688. Any deviation was within an acceptable tolerance.
- 5.3 The meter and calibrator have current calibration certificates, available upon request.

6.0 Noise Monitoring Period and Survey Weather Conditions

- 6.1 The survey was carried out between 15.00 hours on Monday 6th November and 12.00 hours on Monday 13th November 2017.
- 6.2 Due to an unmanned survey being undertaken, weather conditions during the survey period were based on weather records for the area which indicated conditions were mostly acceptable for environmental noise monitoring, particularly at night, with good spells of dry weather with wind speeds well below 5.0m/sec.



7.0 Noise Measurement Parameters

The survey established the prevailing L_{AFmax}, L_{Aeq,T}, L_{A10,T}, and L_{A90,T} noise levels, measured using F time weighting, with a 15 minute reference time period.

8.0 Monitoring Results and Observations

- 8.1 The recorded environmental noise measurements are representative of the existing noise climate applicable to the nearest noise sensitive receptors.
- 8.2 Our observations on site confirmed the existing noise climate was mainly influenced by traffic noise from the surrounding roads, together with general activity in the area.
- 8.3 The lowest measured background noise level during the entire survey period was 30 dB LA90(15min) recorded at night between 01.00-03.00 hours.

9.0 Local Authority Criteria for Proposed Plant Noise

- 9.1 The London Borough of Camden standard noise requirement is specified in the Camden Local Plan, adopted version dated July 2017. Camden Policy A4: Noise and Vibration makes reference to the Noise and Vibration Thresholds provided in Appendix 3.
- 9.2 Appendix 3 identifies the following thresholds for noise and vibration in terms of the "effect" levels described in the National Planning Policy Framework and Planning Practice Guidance.

NOEL – No Observed Effect Level LOAL – Lowest Observed Adverse Effect Level SOAEL – Significant Observed Adverse Effect Level



9.3 The Industrial and Commercial Noise Sources section detailed in Appendix 3 state:

"A relevant standard or guidance document should be referenced when determining values for LOAEL and SOAEL for non-anonymous noise. Where appropriate and within the scope of the document it is expected that British Standard 4142:2014 "Methods for rating and assessing industrial and commercial sound (BS4142) will be used. For such cases a Rating Level of 10dB below background (15dB if tonal components are present) should be considered as the design criterion".

Table C: Noise levels applicable to proposed industrial and commercial developments (including plant and machinery)

Existing Noise Sensitive Receptor	Assessment Location	Design Period	LOAEL (Green)	LOAEL to SOAEL (Amber)	SOAL (Red)
	Outside dining or bedroom window (façade)	Day	Rating level 10dB below background	Rating level between 9dB below and 5dB above background	Rating level greater than 5dB above background
Dwellings	Outside bedroom window (façade)	Night	Rating level 10dB below background and no events exceeding 57dBL _{Amax}	Rating level between 9dB below and 5dB above background or noise events between 57dB and 88dBL _{Amax}	Rating level greater than 5dB above background and/or events exceeding 88dBL _{Amax}

- 9.4 This type of modern air conditioning plant would not have a distinguishable discrete continuous note audible at the receptor positions.
- 9.5 It is also noted that our initial acoustic report has been reviewed by the Council's Environmental Health Officer who stated the following condition should be imposed if a formal planning application was to be approved:

"The sound level from the plant shall be 10dB (15dB if tonal) below the lowest background sound level at the nearest residential receptor at any time. The mitigation measures identified in the Fixed Plant Noise Impact Assessment reference: 10858 shall be installed and maintained to ensure compliance with the above requirements. "



9.6 Based on the requirements from the Environmental Health Officer, and the results of our environmental noise survey given in Appendix 1, the plant noise criteria to be achieved at the façades of all receptor positions detailed in Section 2.0 of this report, and allowing for 24 hour operation of the plant, would be:

Plant Noise Criteria 20 dB L_{Aeq,T}

10.0 Plant Noise Assessment

- 10.1 The proposed plant noise has been calculated at the façade of the three receptor positions and attenuation proposals will need to be incorporated into the intake and discharge louvred openings, and acoustic wall lining to the intake plenum, to ensure the target noise levels are achieved in accordance with the London Borough of Camden standard noise requirements.
- 10.2 The required attenuation for the intake and discharge openings for the three receptor positions has been calculated as detailed below.

Receptor	Louvred			Minimum	Require	d Insertio	n Loss, dE	3	
Position	Openings	63	125	250	500	1k	2k	4k	8k
RPA	Intake	10	14	17	21	28	26	20	16
КРА	Discharge	14	18	28	39	37	35	25	16
חחח	Intake	10	14	17	21	28	26	20	16
RPB	Discharge	14	18	28	39	37	35	25	16
RPC	Intake	10	14	17	21	28	26	20	16
RPC	Discharge	14	18	28	39	37	35	25	16

10.3 Based on the above tables the required attenuation to be installed behind the intake and discharge openings, to ensure compliance with the external requirements of the London Borough of Camden at any of the receptor positions, would be as follows.

Louvred		Minimum Required Insertion Loss, dB									
Openings	63	125	250	500	1k	2k	4k	8k			
Intake	10	14	17	21	28	26	20	16			
Discharge	14	18	28	39	37	35	25	16			

10.4 The attenuated calculations for each receptor position are provided in Appendix 3.



11.0 Conclusions

- 11.1 Our plant calculations confirm that attenuation proposals will need to be incorporated into the intake and discharge louvred openings and the walls of the intake plenum to ensure the target noise levels are achieved in accordance with the London Borough of Camden standard noise requirements.
- 11.2 We have proposed attenuation measures for the louvred openings that will result in the London Borough of Camden noise criteria being achieved as confirmed by calculations in Appendix 3. The predicted cumulative noise levels from the attenuated plant are given in the table below.

Receptor Position	Predicted Plant Noise Level L _{Aeq(15min)} dB	Target Plant Noise Level L _{Aeq(15min)} dB
RPA	18	20
RPB	15	20
RPC	10	20



Appendix 1 Environmental Noise Monitoring Results

Date	Monitoring	Time		Measured Sound I	Pressure Level, dB		Lowest
Date	Position	lime	LAFmax	LAeq,T	LA10,T	LA90,T	LA90,T
		15:00 to 15:15 15:15 to 15:30	72.2	47.2 47.0	48.9	38.9	_
			<u>65.3</u> 65.5	47.0	<u>50.5</u> 52.7	<u>38.8</u> 40.3	38.8
		15:30 to 15:45 15:45 to 16:00	67.1	50.4	51.9	39.9	-
		16:00 to 16:15	67.1	44.8	47.6	<u> </u>	
		16:15 to 16:30	70.8	44.8	50.0	40.3	-
		16:30 to 16:45	63.7	46.4	49.7	39.5	39.5
		16:45 to 17:00	57.8	46.6	50.7	40.1	-
		17:00 to 17:15	58.8	46.8	49.3	41.2	
		17:15 to 17:30	67.8	49.1	51.9	43.4	
		17:30 to 17:45	76.1	50.8	53.8	41.7	41.1
		17:45 to 18:00	66.8	47.1	49.5	41.1	
		18:00 to 18:15	66.0	46.1	49.0	41.2	
		18:15 to 18:30	59.9	45.8	48.1	41.8	
		18:30 to 18:45	75.8	47.4	49.3	41.6	41.1
		18:45 to 19:00	64.6	45.2	47.7	41.1	1
		19:00 to 19:15	59.5	44.6	47.2	40.9	
Monday	1401	19:15 to 19:30	63.7	49.2	51.8	41.3	40.0
06.11.207	MP1	19:30 to 19:45	62.5	46.5	49.3	42.1	40.9
001111207		19:45 to 20:00	61.1	44.7	47.2	41.1	1
		20:00 to 20:15	62.6	45.3	47.4	41.9	
		20:15 to 20:30	57.2	44.7	47.6	41.2	41.2
		20:30 to 20:45	61.9	45.5	47.5	41.8	41.2
		20:45 to 21:00	64.4	46.2	48.5	41.7	
		21:00 to 21:15	60.4	44.4	46.0	41.3	
		21:15 to 21:30	72.8	48.2	47.3	41.5	41.3
		21:30 to 21:45	63.9	44.8	46.9	41.4	41.5
		21:45 to 22:00		44.1	45.5	41.3	
		22:00 to 22:15	62.9	44.5	45.6	40.4	
		22:15 to 22:30		43.8	45.9	40.5	40.4
		22:30 to 22:45	63.8	44.0	45.9	40.8	40.4
		22:45 to 23:00	60.0	45.7	47.0	40.5	
		23:00 to 23:15	52.8	42.4	44.1	39.7	
		23:15 to 23:30	56.6	42.4	44.3	39.7	38.4
		23:30 to 23:45	52.3	41.8	44.1	38.8	50.4
		23:45 to 00:00	55.9	41.6	43.3	38.4	



Date	Monitoring	ті	ne			Measured Sound	Pressure Level, dB		Lowes
Date	Position		ne		LAFmax	LAeq,T	LA10,T	LA90,T	LA90,T
				00:15	60.2	42.2	43.6	38.7	
				00:30	60.9	40.8	42.5	38.3	38.3
				00:45	<u>52.9</u> 45.7	<u>41.2</u> 40.7	42.7 42.4	<u>38.8</u> 38.8	-
				01:15	55.0	40.9	42.4	38.3	
				01:30	52.0	40.5	42.4	38.0	36.7
				01:45	<u>73.1</u> 49.5	42.9 39.1	<u>41.9</u> 40.7	<u> </u>	-
				02:15	57.0	40.0	42.4	36.3	
		02:15 t	o (02:30	49.0	39.6	41.9	36.6	36.3
)2:45	55.7	40.7	43.4	36.8	50.5
				03:00 03:15	<u>60.9</u> 53.5	40.7 41.1	42.9 44.4	<u>36.4</u> 36.1	
			o (03:30	52.9	42.3	45.2	37.7	35.9
				03:45	55.1	42.9	45.7	37.5	55.5
				04:00 04:15	55.9 51.9	40.3 40.7	43.0 43.6	<u>35.9</u> 35.1	
				04:30	54.8	40.1	42.8	35.7	25.1
		04:30 t	o ()4:45	56.7	40.2	42.6	35.6	35.1
				05:00	<u>50.1</u> 47.5	<u>39.4</u> 39.3	41.7	35.5	
)5:15)5:30	50.3	39.3	41.2 39.3	<u>36.4</u> 35.6	
				05:45	57.5	41.6	42.6	36.5	35.6
		05:45 t	o (06:00	55.8	39.6	40.6	35.7	
				06:15	45.9	37.9	39.6	35.6	
				06:30 06:45	<u>55.3</u> 49.7	<u>39.5</u> 39.7	41.0 41.6	<u>36.6</u> 37.4	35.6
		06:45 t	o (07:00	51.2	40.3	41.5	38.1	1
		07:00 t	o (07:15	54.9	42.2	44.3	38.9	-
	1			07:30 07:45	<u>58.9</u> 57.4	<u>44.9</u> 43.2	47.8 44.8	<u>40.3</u> 40.4	38.9
				07:45	60.8	43.2	44.8	40.4	1
		08:00 t	o (08:15	69.2	45.9	46.7	41.4	1
		08:15 t	o (08:30	55.5	44.2	45.7	42.0	41.4
				08:45 09:00	<u>63.1</u> 66.6	<u>46.8</u> 47.2	49.2 49.4	<u>42.9</u> 43.3	-
)9:15	64.2	47.2	50.8	43.5	
		09:15 t	o (09:30	62.0	47.7	50.4	43.2	43.2
				09:45	59.7	47.9	50.7	43.9	43.2
				10:00 10:15	<u>59.2</u> 65.4	47.5 47.8	49.9 49.7	<u>43.6</u> 43.6	
				10:30	59.2	48.7	51.2	44.6	42.4
				10:45	66.4	49.9	52.5	44.0	42.4
				11:00	60.7	47.1	49.5	42.4	
				11:15 11:30	<u>61.1</u> 65.8	<u>49.1</u> 48.0	51.8 50.7	<u>43.1</u> 43.3	_
				11:45	59.9	47.3	49.7	43.0	43.0
Tuesday	MP1	11:45 t	o 1	12:00	70.3	50.5	52.2	43.5	
07.11.2017	1411 1			12:15	59.8	47.7	50.7	42.8	
				12:30 12:45	<u>60.7</u> 62.1	47.2 48.9	50.4 51.7	<u>42.3</u> 43.7	42.3
				13:00	65.6	48.1	50.3	43.9	
		13:00 t	o 1	13:15	62.9	47.5	49.8	43.6	
			0 1	13:30	62.2	50.0	53.3	45.2	43.6
				13:45 14:00	<u>61.4</u> 62.1	48.5 48.8	<u>50.8</u> 51.2	<u>44.3</u> 44.4	
				14:15	62.9	48.8	51.3	45.2	
				14:30	66.4	48.3	50.5	44.1	42.6
				14:45 15:00	<u>61.6</u> 64.0	48.1 47.6	51.0 49.2	42.6	-
				15:15	59.8	46.2	49.2	<u>43.1</u> 43.4	
		15:15 t	o 1	15:30	64.0	48.2	50.7	43.3	43.3
				15:45	66.1	48.2	50.4	44.1	43.5
				16:00 16:15	<u>68.7</u>	50.3 47.6	52.7 49.8	<u>44.0</u> 42.5	+
				16:30	<u>65.0</u> 63.6	47.6	49.8 50.9	42.3	42.2
		16:30 t	o 1	16:45	64.5	47.1	49.5	42.5	42.3
				17:00	58.5	47.1	49.8	42.5	
				17:15 17:30	<u>59.4</u> 69.8	47.7 49.1	50.8 50.7	42.3 42.0	-
				17:45	60.0	49.1	49.9	43.5	42.0
		17:45 t	o 1	18:00	64.2	48.3	50.8	42.4]
		18:00 t	o 1	18:15	65.9	47.3	49.8	42.5	
				18:30 18:45	<u>61.9</u> 78.3	46.5 47.7	49.5 48.1	<u>41.6</u> 42.3	41.6
				19:00	62.6	46.7	49.5	42.5	
		19:00 t	o 1	19:15	65.0	47.5	49.7	42.6	
				19:30	55.0	44.3	46.7	41.3	41.3
				19:45 20:00	<u>59.7</u> 58.4	47.0 45.7	50.1 48.2	<u>42.3</u> 42.3	-
		20:00 t		20:15	64.5	46.7	49.4	41.5	
		20:15 t	o 2	20:30	64.9	48.1	50.9	42.0	41.5
				20:45	66.0	49.6	52.5	42.0	
				21:00 21:15	<u>69.0</u> 75.2	54.5 51.8	58.1 55.6	<u>46.5</u> 41.4	+
				21:30	72.0	50.9	53.6	40.8	40.8
		21:30 t	o 2	21:45	68.7	55.2	58.4	47.4	40.8
				22:00	70.5	56.1	59.5	48.3	-
				22:15 22:30	<u>69.4</u> 72.0	<u>55.2</u> 56.8	58.3 60.4	<u>48.0</u> 49.8	·-
				22:45	70.6	56.7	60.0	49.6	48.0
		22:45 t	o 2	23:00	72.8	59.3	62.3	53.3	1
			o 2	23:15	71.1	57.9	61.3	50.9	_
				2 <u>3:30</u> 23:45	<u>69.7</u>	<u>56.4</u> 55.7	60.1 59.3	<u>48.8</u> 47.4	47.4
	1	∠J.JU [00:00	<u>69.5</u> 70.3	55.7	59.3	47.4	-



Data	Monitoring	ті	ne		Measured Sound	Pressure Level, dE	8	Lowest
Date	Position		ne	LAFmax	LAeq,T	LA10,T	LA90,T	LA90,T
			o 00:		53.9	57.5	46.2	_
			o 00: o 00:		<u>51.1</u> 50.6	54.1 53.6	43.6 42.6	42.0
		00:45 t	o 01:	0 66.5	49.2	51.9	42.0	
			o 01: o 01:		50.9 49.4	54.1 52.5	<u>44.1</u> 41.6	20.0
		01:30 t	o 01:	5 72.2	48.2	50.0	40.1	39.6
			o 02: o 02:		<u>48.9</u> 48.3	<u>49.8</u> 51.3	<u>39.6</u> 38.1	
		02:15 t	o 02:	0 65.8	45.6	47.6	36.4	35.2
			o 02: o 03:		42.8 43.6	44.3 45.9	37.0 35.2	
		03:00 t	o 03:	5 60.0	39.8	41.7	35.0	
			o 03: o 03:		37.5 36.5	40.0 36.1	<u>32.4</u> 32.0	31.5
		03:45 t	o 03.		35.7	35.9	31.5	
			o 04: o 04:		<u>35.2</u> 35.8	37.6 36.8	<u>32.0</u> 32.4	_
			o 04: o 04:		34.5	34.9	32.4	32.0
			o 05:		35.0	35.3	32.4	
			o 05: o 05:		<u>34.2</u> 35.5	35.4 37.0	32.5 33.1	22.5
		05:30 t	o 05:	5 50.6	36.4	38.1	33.8	32.5
			o 06: o 06:		48.0 40.0	51.6 41.5	34.3 35.6	
		06:15 t	o 06:	0 48.4	38.2	39.6	36.0	35.5
			o 06:		37.5	39.1	35.5	
			o 07: o 07:		<u>40.9</u> 39.8	<u>40.8</u> 41.9	36.6 37.0	
		07:15 t	o 07:	0 55.5	42.1	45.5	38.0	37.0
			o 07: o 08:		<u>49.1</u> 45.0	53.0 46.0	<u>39.3</u> 39.2	_
		08:00 t	o 08:	5 63.8	47.9	51.3	39.2	_
			o 08: o 08:		51.0 48.3	53.0 49.9	40.4 40.2	39.2
		08:45 t	o 09:	0 69.9	48.4	51.5	41.0	_
			o 09:		47.7 49.0	50.2 51.1	41.3	_
			o 09: o 09:		49.0	52.4	43.1 42.7	41.3
		09:45 t	o 10:	0 63.6	49.3	52.0	44.5	
			o 10: o 10:		<u>56.1</u> 57.7	<u>61.2</u> 63.5	45.1 45.3	
		10:30 t	o 10:	5 66.9	55.1	59.5	44.4	43.6
			o 11: o 11:		<u>48.3</u> 48.5	51.4 51.4	<u>43.6</u> 43.0	
			o 11:		48.9	51.8	43.2	42.5
Vedsnesday			o 11: o 12:		<u>49.0</u> 51.5	52.0 54.4	42.5	42.5
08.11.2017	MP1		o 12: o 12:		51.5	52.3	46.0 44.6	
001112017		12:15 t	o 12:	67.0	48.9	51.5	42.6	41.1
			o 12: o 13:		48.0 49.4	51.7 51.4	41.1 41.8	_
		13:00 t	o 13:	5 59.1	47.0	50.0	40.5	
			o 13: o 13:		50.0 46.8	52.7 49.9	41.1 40.5	39.9
			o 14:		49.0	52.7	39.9	
			o 14: o 14:		<u>49.3</u> 45.7	51.9 48.8	39.6 40.8	_
			o 14: o 14:		46.0	49.2	39.1	39.1
		14:45 t	o 15:	0 65.0	49.4	53.0	41.2	
			o 15: o 15:		45.7 48.8	49.0 51.9	40.0 41.6	
		15:30 t	o 15:	5 62.4	47.2	50.8	39.9	39.9
			o 16: o 16:		54.4 53.6	<u>58.6</u> 57.2	42.8 43.0	
		16:15 t	o 16:	0 70.4	53.7	56.6	45.5	40.4
			0 16: 0 17:		54.1	58.1 50.3	41.4 40.4	-0.4
		17:00 t	o 17: o 17:		46.8 48.5	50.3 51.9	40.4	
		17:15 t	o 17:	0 70.0	46.7	48.8	38.5	38.5
			o 17: o 18:		49.1 48.0	51.0 50.5	39.7 38.6	-
		18:00 t	o 18:	5 60.9	44.7	47.8	38.4	_
			o 18: o 18:		50.2 44.3	52.8 47.3	40.2 39.6	38.4
			o 19:		43.5	46.4	38.9	
			<u>0 19:</u>		45.3	48.8	39.5	_
			o 19: o 19:		45.5 48.2	<u>48.8</u> 50.0	<u>39.5</u> 39.2	39.1
		19:45 t	o 20:	0 57.5	44.1	47.4	39.1	
			o 20: o 20:		45.1 42.3	48.3 44.3	38.5 38.4	20.4
		20:30 t	o 20:	5 59.4	45.0	48.4	38.8	38.4
			o 21: o 21:		46.2 47.0	50.1 50.5	38.5 38.6	
			o 21: o 21:	0 61.7	46.0	49.1	40.1	38.6
		21:30 t	o 21:	5 63.1	47.6	51.0	41.3	38.0
			o 22: o 22:		42.3 44.6	<u>43.7</u> 47.5	<u>39.9</u> 40.2	
		22:15 t	o 22:	0 58.3	43.5	44.8	40.1	38.4
			o 22: o 23:		46.2 42.2	46.1 43.5	<u>39.0</u> 38.4	50.4
		23:00 t	0 23:	5 56.1	42.2	41.6	38.0	
		23:15 t	o 23:	0 57.0	43.7	45.0	39.2	38.0
		23:30 t	o 23:	5 62.9	42.6	43.2	39.2	



Date	Monitoring	Tir	ne			Measured Sound	Pressure Level, dB		Lowest
Date	Position		iic.		LAFmax	LAeq,T	LA10,T	LA90,T	LA90,T
			o 00):15	55.4	43.2	44.0	40.5	
				0:30	58.4	42.9	43.9	39.1	37.8
):45 L:00	<u>56.7</u> 54.6	<u>41.4</u> 40.9	42.3 41.9	<u>37.8</u> 38.3	-
				L:15	65.3	43.2	42.8	38.1	
		01:15 t		L:30	50.3	39.7	41.2	37.7	36.1
				L:45 2:00	<u>46.2</u> 45.8	<u>39.6</u> 38.3	<u>41.3</u> 40.0	<u>37.3</u> 36.1	_
				2:15	46.5	37.7	39.4	35.8	
		02:15 t	o 02	2:30	49.4	38.4	39.8	36.3	35.7
				2:45	48.9	37.8	39.8	35.7	
				3:00 3:15	<u>43.8</u> 55.1	37.3 38.1	<u>38.7</u> 38.6	<u>35.9</u> 35.2	
			o 03	3:30	50.9	37.6	39.3	35.0	35.0
				3:45	49.5	38.4	41.1	35.4	55.0
				4:00 4:15	45.2 49.3	37.4 39.1	<u>39.1</u> 42.4	<u>35.0</u> 35.2	
				1:30	54.9	38.0	39.8	36.0	25.2
		04:30 t	o 04	1:45	52.8	40.4	44.2	36.2	35.2
				5:00	58.3	40.2	41.6	36.0	
				5:15 5:30	51.0 53.2	<u>38.8</u> 39.8	40.9 41.1	<u>36.0</u> 36.7	
				5:45	49.4	40.3	43.5	36.2	36.0
		05:45 t	o 06	5:00	64.8	48.1	51.4	37.5	
				5:15	53.5	43.1	46.3	39.0	
				5:30 5:45	<u>51.9</u> 51.1	<u>41.3</u> 42.2	<u>43.9</u> 43.9	<u>38.5</u> 40.2	38.5
		06:45 t		7:00	54.3	44.1	46.5	41.4	
		07:00 t	o 07	7:15	63.3	46.2	48.8	42.0	_
				7:30 7:45	<u>59.9</u> 63.8	<u>48.2</u> 49.2	<u>51.7</u> 50.4	<u>43.9</u> 45.0	42.0
				3:00	65.9	49.2	51.6	45.0	
		08:00 t	o 08	3:15	66.6	48.5	50.4	44.6	1
				3:30	57.2	47.3	48.9	45.3	44.6
				3:45 9:00	65.6 60.5	<u>48.1</u> 50.0	<u>49.5</u> 53.1	<u>45.7</u> 46.0	-
				9:15	67.9	49.1	50.8	46.0	
		09:15 t	o 09	9:30	68.5	51.7	53.7	47.1	46.0
				9:45	60.6	<u>49.9</u> 49.7	52.8	46.5	-
):00):15	<u>61.4</u> 62.7	49.7	51.6 50.6	<u>46.4</u> 46.2	
				0:30	66.7	48.9	50.6	46.1	45.3
):45	59.8	48.1	50.3	45.3	45.5
				L:00	70.0	51.2 49.9	52.0	46.1	
				L:15 L:30	<u>69.5</u> 68.0	51.1	<u>51.9</u> 54.1	<u>46.1</u> 46.4	
				L:45	61.8	52.0	55.6	47.0	46.1
Thursday	MP1			2:00	69.1	52.5	55.4	47.2	
09.11.2017				2:15 2:30	60.0 58.3	<u>49.7</u> 46.7	53.2 48.4	45.2 44.1	_
				2:45	76.3	49.5	50.2	45.5	44.1
				3:00	68.1	50.2	52.4	45.8	
			o 13	3:15	62.5	49.7	53.0	44.3	
			0 13	3:30 3:45	71.0 62.6	<u>48.4</u> 48.2	49.7 51.3	<u>41.8</u> 41.7	40.5
				1:00	58.7	46.0	49.2	40.5	
		14:00 t	o 14	1:15	61.4	45.0	47.9	40.3	
				1:30	63.3	48.0	51.1	40.4	37.2
				1:45 5:00	<u>63.2</u> 57.1	45.4 43.2	48.4 46.1	<u>37.2</u> 38.5	
				5:15	71.9	51.6	53.5	40.7	
		15:15 t	o 15	5:30	65.8	50.2	53.6	41.6	40.7
				5:45	<u>66.3</u>	48.1	<u>49.2</u> 48.7	41.5	,
				5:00 5:15	<u>57.8</u> 71.3	46.6 49.9	48.7	<u>42.4</u> 45.7	1
		16:15 t	o 16	5:30	82.5	57.8	54.0	44.3	43.7
				5:45	60.5	51.3	53.8	44.4	
				7:00 7:15	<u>65.4</u> 68.1	53.8 56.8	58.7 61.2	<u>43.7</u> 44.3	+
		17:15 t		7:30	71.3	48.3	49.7	43.7	42.5
		17:30 t	o 17	7:45	60.1	47.7	50.7	42.5	42.5
				3:00 3:15	<u>62.9</u> 61.2	48.1 48.5	50.1 52.1	<u>43.4</u> 43.1	
				3:30	56.1	46.4	48.8	43.4	42.0
		18:30 t	o 18	3:45	58.8	46.9	49.3	43.2	42.0
				9:00	59.3	45.1	47.1	42.0	-
				9:15 9:30	<u>59.2</u> 68.3	<u>46.1</u> 48.9	48.6 50.0	<u>43.0</u> 42.9	
		19:30 t	o 19	9:45	61.4	45.5	48.7	37.9	35.7
		19:45 t	o 20	0:00	58.3	42.4	45.7	35.7	
):15):30	60.7 57.5	45.1 43.3	47.8 46.1	<u> </u>	-
):45	60.3	43.3	46.6	37.8	36.3
	1	20:45 t	o 21	L:00	58.5	42.0	44.8	36.3	
				L:15	56.1	40.6	42.0	35.9	_
				L:30 L:45	56.1 67.3	41.5 44.3	44.3 46.1	<u>35.8</u> 36.9	35.2
				2:00	59.7	44.5	44.0	35.2	
		22:00 t	o 22	2:15	56.3	40.6	42.6	36.1	_
				2:30	66.6	45.2	45.4	37.6	35.4
				2:45 3:00	<u>60.7</u> 54.4	43.7 40.3	<u>46.4</u> 43.5	<u>37.8</u> 35.4	-
	1		<u>v 23</u>	3:15	55.3	39.5	43.5	33.4	1
		23:00 t	0 12-	5.T2 I	33.3	33.3	40.4	55.4	
		23:15 t	o 23	3:30 3:45	<u> </u>	45.9 40.7	40.4 44.9 44.3	35.1 34.3	33.4



Date	Monitoring	Tim	0		Measured Sound	Pressure Level, dB		Lowest
Date	Position		e	LAFmax	LAeq,T	LA10,T	LA90,T	LA90,T
		00:00 to 00:15 to		51.2 49.5	37.8	<u>39.3</u> 39.6	<u>34.5</u> 35.4	_
		00:15 to 00:30 to		49.5	<u>38.0</u> 39.9	42.4	36.5	34.5
		00:45 to		52.1	39.9	<u>41.7</u> 41.0	36.7	
		01:00 to 01:15 to		<u>50.1</u> 50.4	<u>39.4</u> 38.9	41.0	<u>37.0</u> 36.7	36.7
		01:30 to	01:45	53.9	40.4	42.4	37.3	30.7
		01:45 to 02:00 to		<u>51.2</u> 51.4	<u>39.9</u> 39.8	42.0 42.1	<u>36.9</u> 36.7	
		02:15 to	02:30	51.7	39.0	40.8	35.7	35.6
		02:30 to 02:45 to		<u>49.3</u> 52.9	38.9 39.6	41.3 41.8	<u>35.6</u> 36.2	
		03:00 to		47.7	39.6	41.8	36.7	
		03:15 to		50.5	40.4	42.3	38.1	36.7
		03:30 to 03:45 to		57.3 50.1	<u>39.8</u> 41.5	<u>41.4</u> 43.6	<u>37.6</u> 38.6	
		04:00 to	04:15	51.0	41.4	43.4	38.3	_
		04:15 to 04:30 to		<u>64.3</u> 50.8	46.1 40.7	<u>44.7</u> 42.8	<u>37.7</u> 38.1	37.7
		04:45 to	05:00	48.4	40.4	41.9	38.3	
		05:00 to		50.7	<u>39.4</u> 39.6	40.9	<u> </u>	
		05:15 to 05:30 to		<u>54.3</u> 54.9	40.0	41.0 41.8	37.6	37.5
		05:45 to	06:00	50.1	40.8	42.7	38.5	
		06:00 to 06:15 to		<u>52.2</u> 58.8	<u>42.2</u> 43.7	<u>44.6</u> 45.6	<u>38.8</u> 40.2	
		06:30 to		59.8	43.9	45.2	41.2	38.8
		06:45 to 07:00 to		67.0	47.9 45.6	48.5 47.5	42.6	
		07:00 to 07:15 to		<u>60.0</u> 63.2	45.0	47.5	<u>43.0</u> 44.0	42.0
		07:30 to	07:45	62.0	46.8	48.5	44.0	43.0
		07:45 to 08:00 to		<u>61.4</u> 59.5	47.4 47.1	<u>49.1</u> 49.2	<u>44.4</u> 44.5	
		08:15 to		70.8	52.4	51.9	44.5	44.5
		08:30 to		62.2	49.1	51.4	45.4	44.5
		08:45 to 09:00 to		<u>61.5</u> 64.1	<u>49.2</u> 51.2	51.2 54.2	<u>46.0</u> 46.4	
		09:15 to	09:30	68.6	55.7	58.9	50.0	46.4
		09:30 to 09:45 to		71.5 72.2	57.1 59.5	<u>60.8</u> 62.9	<u>48.9</u> 50.7	-
		10:00 to		68.4	53.4	56.3	47.4	
		10:15 to		65.2	51.7	54.7	46.0	44.6
		10:30 to 10:45 to		<u>68.2</u> 64.2	50.7 52.1	53.3 55.9	44.6 45.2	
		11:00 to	11:15	66.4	54.8	58.7	47.4	_
		<u>11:15 to</u>		<u>58.0</u> 64.4	50.2 48.8	52.6	<u>46.7</u> 44.6	44.4
Friday	1401	11:30 to 11:45 to		69.5	48.9	<u>51.2</u> 51.6	44.0	
10.11.2017	MP1	12:00 to	12:15	59.1	50.2	53.9	44.6	
		12:15 to 12:30 to		<u>60.1</u> 60.6	<u>48.8</u> 49.9	<u>51.4</u> 52.8	<u>45.0</u> 44.7	44.6
		12:45 to	13:00	70.3	51.2	52.9	48.0	
		13:00 to		64.7	50.8 47.9	52.8	46.6	_
		13:15 to 13:30 to		58.1 76.2	51.3	50.4 53.6	44.1 46.9	44.1
		13:45 to	14:00	68.2	55.8	60.3	46.7	
		14:00 to 14:15 to		61.2 60.7	<u>49.7</u> 48.9	52.2 52.0	<u>45.6</u> 44.6	
		14:30 to	14:45	74.8	51.9	54.5	43.7	43.7
		14:45 to		63.2	49.8	52.7	44.4	
		15:00 to 15:15 to		<u>60.0</u> 59.9	50.0 48.8	52.4 51.5	<u>46.0</u> 44.2	44.0
		15:30 to	15:45	64.9	48.9	51.0	45.3	44.0
		15:45 to 16:00 to		<u>61.4</u> 61.8	48.0 48.6	<u>50.8</u> 51.0	<u>44.0</u> 45.2	
		16:15 to	16:30	63.4	48.5	51.1	43.4	42.4
		16:30 to	16:45	59.9	46.4	48.8	42.4	+2.4
	1	16:45 to 17:00 to		<u>65.8</u> 66.9	49.3 48.7	52.1 50.4	<u>43.4</u> 43.8	
	1	17:15 to	17:30	59.4	46.7	49.3	43.0	43.0
		17:30 to 17:45 to		<u>63.5</u> 59.1	47.4 47.7	50.0 50.1	43.3 43.6	-
		18:00 to		57.1	46.4	48.9	43.0	
		18:15 to	18:30	61.0	46.7	48.7	42.8	42.6
		18:30 to 18:45 to		59.6 67.2	46.3 48.5	<u>48.8</u> 50.8	42.6 43.2	
		19:00 to	19:15	60.6	47.1	49.8	42.9	
	1	<u>19:15</u> to 19:30 to		<u>62.0</u> 60.9	47.7 47.6	<u>49.2</u> 50.0	<u>44.8</u> 43.8	42.9
	1	19:45 to	20:00	62.1	48.3	50.2	43.1	1
		20:00 to	20:15	57.3	46.1	48.6	42.7	_
	1	20:15 to 20:30 to		57.9 59.0	46.7 46.8	<u>48.7</u> 48.6	<u>43.5</u> 43.7	42.7
		20:45 to	21:00	54.7	46.1	48.3	43.4	1
		21:00 to 21:15 to		71.0 58.5	<u>48.2</u> 46.2	47.9 48.0	<u>42.7</u> 43.4	-
	1	21:15 to		55.8	46.2	48.0	43.4	42.0
		21:45 to	22:00	60.3	44.6	46.3	42.0]
		22:00 to 22:15 to		<u>61.8</u> 77.9	45.4 46.8	<u>46.9</u> 46.9	41.8 42.1	
	1	22:30 to		55.0	44.7	46.4	42.0	41.8
		22:45 to	23:00	62.7	44.6	45.9	42.0	
	1	23:00 to 23:15 to		<u>55.1</u> 55.1	<u>44.4</u> 44.2	46.5 45.8	41.8 42.0	
		23:30 to	23:45	59.6	44.9	47.1	41.9	41.2
	1	23:45 to		55.3	43.8	45.7	41.2	1



Date	Monitoring		Time			Measured Sound	Pressure Level, dE	3	Lowest
Dute	Position		mile		LAFmax	LAeq,T	LA10,T	LA90,T	LA90,T
		00:00	to	00:15	60.5	44.1	44.5	40.2	_
		00:15 00:30	to to	00:30 00:45	<u>63.2</u> 54.9	<u>44.8</u> 44.6	47.6 46.9	41.2 41.0	40.2
		00:45	to	01:00	64.2	49.5	51.4	46.5	
		01:00	to	01:15	66.4	49.1	51.5	44.9	
		01:15 01:30	to to	01:30 01:45	<u>65.7</u> 67.7	51.9 53.0	54.7 56.2	47.4 46.3	42.9
		01:45	to	02:00	67.6	50.0	52.8	40.3	
		02:00	to	02:15	67.0	49.6	52.6	42.2	
		02:15 02:30	to to	02:30 02:45	<u>66.4</u> 66.7	53.7 52.8	56.9 56.2	<u>48.4</u> 46.0	42.2
		02:45	to	03:00	66.3	52.8	55.8	45.4	
		03:00	to	03:15	66.5	50.7	54.5	42.1	
		03:15	to	03:30 03:45	65.9	51.7	<u>55.3</u> 59.6	42.9 49.5	42.1
		03:30 03:45	to to	03:45	<u>67.3</u> 68.1	<u>56.4</u> 54.9	59.0	49.5	
		04:00	to	04:15	67.6	54.0	57.7	46.3	
		04:15	to	04:30	66.2	56.8	59.6	52.0	46.3
		04:30 04:45	to to	04:45 05:00	<u>66.5</u> 69.2	<u>56.8</u> 56.3	<u>59.7</u> 59.5	52.0 50.4	
		05:00	to	05:15	67.3	55.6	58.6	50.4	
		05:15	to	05:30	68.8	57.3	60.1	52.6	50.3
		05:30	to	05:45	68.3	57.1	60.1	51.6	50.5
		05:45 06:00	to to	06:00 06:15	<u>69.9</u> 69.9	58.3 60.4	<u>61.4</u> 63.5	<u>50.8</u> 54.7	-
		06:15	to	06:30	68.5	57.6	60.5	52.5	52.5
		06:30	to	06:45	69.5	58.6	61.2	54.1	52.5
		06:45	to	07:00	71.7	61.6	64.1	57.1	
		07:00 07:15	to to	07:15 07:30	74.7 77.3	62.4 60.5	<u>64.6</u> 62.9	<u>58.7</u> 56.5	
		07:30	to	07:45	75.3	60.6	62.9	56.5	54.3
		07:45	to	08:00	72.9	59.8	62.7	54.3	ļ
		08:00 08:15	to to	08:15	76.5	56.0 53.4	<u>59.4</u> 56.7	48.8 45.8	-
		08:30	to	08:30 08:45	75.6 71.6	52.3	56.7 55.9	45.8	41.7
		08:45	to	09:00	70.7	50.3	53.7	41.7	
		09:00	to	09:15	70.7	50.6	53.7	40.5	
		09:15 09:30	to to	09:30 09:45	<u>65.7</u> 65.2	51.1 51.8	54.5 55.3	43.8 44.8	40.5
		09:45	to	10:00	65.9	49.9	53.3	42.4	
		10:00	to	10:15	66.7	49.3	52.4	39.7	
		10:15	to	10:30 10:45	<u>72.2</u> 67.7	<u>49.9</u> 50.5	53.3	40.5 42.4	39.7
		10:30 10:45	to to	10:45	68.4	50.3	53.6 53.8	42.4	
		11:00	to	11:15	66.6	48.2	52.0	38.7	
		11:15	to	11:30	65.0	48.3	51.9	38.9	37.7
Saturday		11:30 11:45	to to	11:45 12:00	73.3 67.6	48.5 48.1	52.1 51.7	<u>38.4</u> 37.7	-
11.11.2017	MP1	12:00	to	12:15	68.0	46.8	49.2	36.5	
		12:15	to	12:30	67.0	51.9	53.8	40.5	36.5
		12:30	to	12:45	71.6	56.3	56.7	47.7	
		12:45 13:00	to to	13:00 13:15	<u>64.1</u> 67.8	51.5 53.3	54.3 56.7	41.9 41.6	
		13:15	to	13:30	67.3	50.1	50.4	35.4	35.4
		13:30	to	13:45	65.7	51.3	53.9	41.3	55.4
		13:45	to	14:00	64.4	<u>48.3</u> 47.7	52.0	37.2	
		14:00 14:15	to to	14:15 14:30	<u>63.4</u> 63.1	46.7	50.6 49.6	37.4 35.3	25.2
		14:30	to	14:45	63.0	47.7	51.7	37.1	35.3
		14:45	to	15:00	65.8	49.9	53.1	38.5	
		15:00 15:15	to to	15:15 15:30	<u>66.0</u> 67.9	<u>48.2</u> 48.9	51.0 51.9	37.5 36.7	
		15:30	to	15:45	70.1	52.4	55.1	34.1	32.9
		15:45	to	16:00	57.4	43.3	47.0	32.9	L
		16:00 16:15	to to	16:15 16:30	<u>63.4</u> 63.8	45.1 46.4	<u>48.6</u> 50.3	34.4 35.4	-
		16:30	to	16:45	66.4	47.4	50.9	35.5	31.9
		16:45	to	17:00	58.1	44.0	48.1	31.9	
		17:00	to	17:15	64.7	45.5	49.0	33.2	-
		17:15 17:30	to to	17:30 17:45	<u>61.9</u> 61.1	<u>44.7</u> 46.4	47.7 50.3	<u>34.2</u> 33.7	33.2
		17:45	to	18:00	59.8	45.6	49.6	36.7	1
		18:00	to	18:15	55.1	42.3	45.9	36.5	4
		18:15 18:30	to to	18:30 18:45	<u>54.1</u> 58.6	42.9 43.9	46.1 46.8	<u>37.4</u> 37.4	36.5
		18:45	to	19:00	66.8	43.5	40.8	37.4	1
		19:00	to	19:15	65.7	45.1	48.2	36.2	
		<u>19:15</u> 19:30	to	19:30 19:45	57.2	<u>44.9</u> 45.0	48.3	37.9	36.2
		19:30	to to	20:00	<u>59.2</u> 63.5	45.0	<u>48.6</u> 47.6	37.6 38.5	1
		20:00	to	20:15	74.0	49.8	50.1	39.0	
		20:15	to	20:30	57.1	43.5	47.0	37.3	37.3
		20:30 20:45	to to	20:45 21:00	57.6 56.8	42.8 44.6	45.8 48.1	<u>38.1</u> 38.5	-
		21:00	to	21:15	60.8	44.0	40.1	37.0	1
		21:15	to	21:30	71.5	54.7	58.2	38.2	35.9
		21:30 21:45	to	21:45 22:00	82.6	56.9 51.0	54.9	36.5	-
		21:45	to to	22:00	<u>81.7</u> 56.3	41.6	48.0 44.1	35.9 35.7	+
		22:15	to	22:30	56.0	41.0	43.8	34.2	34.1
		22:30	to	22:45	82.8	54.3	48.1	35.7	34.1
		22:45	to	23:00	53.2	38.8	41.2	34.1	+
		23:00 23:15	to to	23:15 23:30	<u>58.6</u> 56.7	<u>40.4</u> 38.6	<u>42.2</u> 39.9	<u>33.6</u> 34.6	
		23:30	to	23:45	55.1	39.2	41.0	35.1	33.6
	1	23:45	to	00:00	59.4	40.9	42.4	34.6	




Date	Monitoring	ті	me			Measured Sound	Pressure Level, dB		Lowest
Date	Position		inc i		LAFmax	LAeq,T	LA10,T	LA90,T	LA90,T
			o 0	0:15	58.1	41.3	45.4	31.3	
				0:30	58.8	42.0	45.3	31.5	31.3
				0:45	<u>57.6</u> 52.6	<u>41.2</u> 36.3	44.5 38.5	<u>32.6</u> 31.8	-
				1:15	49.4	36.0	38.4	31.5	
		01:15 t		1:30	54.6	38.0	39.6	32.1	30.0
				1:45 2:00	<u>50.5</u> 53.5	<u>34.5</u> 36.3	36.0 38.0	<u>30.0</u> 30.2	-
				2:15	54.8	39.5	43.0	30.4	1
		02:15 t	o 0	2:30	54.2	36.8	39.0	30.1	30.1
				2:45	50.8	37.6	40.7	31.8	- 30.1
				3:00 3:15	<u>63.3</u> 66.7	48.5 51.2	<u>51.6</u> 54.9	<u>38.1</u> 42.1	
			o 0	3:30	68.2	50.4	53.9	39.7	34.8
				3:45	67.0	53.3	57.1	42.6	54.0
				4:00 4:15	65.0 65.1	<u>44.8</u> 49.5	47.5 53.6	<u>34.8</u> 35.2	-
				4:30	68.5	54.1	57.5	46.8	25.2
		04:30 t	o 0	4:45	68.8	55.1	58.1	49.5	35.2
				5:00	66.8	52.0	56.1	40.7	-
				5:15 5:30	<u>67.5</u> 64.9	<u>49.2</u> 48.9	52.0 52.2	<u>37.8</u> 40.6	
				5:45	68.0	48.1	50.5	36.0	35.2
		05:45 t	o 0	6:00	64.4	44.5	46.6	35.2	
				6:15	62.9	42.2	42.6	33.0	-
				6:30 6:45	<u>62.2</u> 61.1	<u>42.4</u> 41.9	43.2 42.7	<u>33.4</u> 34.6	33.0
		06:45 t		7:00	62.0	43.7	46.9	35.3	1
		07:00 t	o 0	7:15	72.3	57.7	60.9	51.2	
				7:30	<u>71.2</u> 69.9	<u>57.5</u> 58.7	62.0 62.5	<u>44.1</u> 47.1	41.2
				8:00	69.9	58.7	53.8	47.1	1
		08:00 t	o 0	8:15	69.2	49.5	52.5	40.4	1
				8:30	65.6	46.3	49.0	39.6	39.6
				8:45 9:00	<u>67.5</u> 66.7	47.5 49.8	50.1 53.2	<u>39.8</u> 40.6	-
				9:15	63.0	46.1	48.8	40.2	
		09:15 t	o 0	9:30	64.4	46.7	49.7	40.8	40.2
				9:45	61.1	48.4	51.6	42.4	-
				0:00	62.9 65.5	<u>48.9</u> 48.4	52.5 50.7	<u>42.9</u> 43.3	
				0:30	69.4	50.1	52.6	43.9	43.3
			o 1	0:45	65.0	51.1	54.4	44.9	43.3
				1:00	67.3	50.5	52.4	44.3	-
				1:15 1:30	<u>61.0</u> 61.3	<u>48.8</u> 48.0	51.8 50.7	<u>43.6</u> 43.9	
				1:45	65.6	50.0	52.6	44.7	43.6
Sunday	MP1			2:00	63.6	50.9	53.9	44.0	
12.11.2017				2:15	<u>65.5</u> 67.7	<u>49.4</u> 50.5	52.1 53.1	<u>44.2</u> 45.3	-
				2:30 2:45	61.6	50.5	53.7	45.7	43.6
				3:00	61.7	49.5	52.6	43.6	
			0 1	3:15	67.7	50.9	53.9	45.6	
			0 1	3:30 3:45	<u>65.6</u> 63.1	50.3 49.9	53.6	<u>43.9</u> 45.0	43.9
				4:00	61.3	50.4	52.9 53.5	45.0	
		14:00 t	o 1	4:15	67.5	53.3	56.5	45.7	
				4:30	68.0	50.4	53.2	44.1	44.1
				4:45 5:00	60.6 68.2	50.0 52.1	52.8 55.2	44.6 46.8	
				5:15	70.1	52.5	55.6	46.2	
		15:15 t	o 1	5:30	62.7	50.8	54.1	45.1	43.3
				5:45	68.2	52.6	55.1	44.9	
				6:00 6:15	<u>65.0</u> 64.6	50.6 50.1	54.1 53.4	<u>43.3</u> 44.0	+
				6:30	64.5	50.8	54.2	44.3	42.5
		16:30 t	o 1	6:45	62.0	47.8	50.8	42.5	+2.5
				7:00	<u>62.4</u> 63.5	<u>48.9</u> 49.1	51.6 52.2	<u>44.1</u> 43.0	+
				7:30	68.0	48.0	50.6	41.6	A1 C
		17:30 t	o 1	7:45	70.0	47.4	49.2	42.8	41.6
				8:00	67.7	48.1	51.0	42.7	+
				8:15 8:30	<u>64.3</u> 68.1	<u>46.9</u> 49.1	<u>49.9</u> 50.3	<u>41.7</u> 41.5	1
				8:45	58.6	45.9	48.0	41.5	41.5
		18:45 t	o 1	9:00	61.5	48.0	50.5	43.4	
				9:15 9:30	<u>70.2</u> 59.6	51.7	53.6 48.7	<u>43.7</u> 42.7	-
				9:30	<u> </u>	<u>46.7</u> 50.0	48.7	42.7	41.8
		19:45 t	o 2	0:00	59.9	46.6	49.8	41.8	1
				0:15	66.8	47.1	49.7	42.5	-
				0:30	<u>66.0</u> 69.8	<u>49.1</u> 50.1	51.7 53.9	<u>42.2</u> 43.0	42.2
				1:00	70.3	50.0	52.3	43.0	
		21:00 t	o 2	1:15	65.5	49.3	51.8	42.7	
				1:30	68.9	49.9	52.9	42.5	41.4
				1:45 2:00	<u>55.1</u> 63.7	45.5 48.8	<u>48.1</u> 52.7	<u>41.4</u> 41.7	-
				2:15	55.4	40.0	47.2	40.7	1
		22:15 t	o 2	2:30	55.1	43.3	45.5	40.5	40.2
				2:45	57.4	44.2	46.9	40.2	
			0 2	3:00 3:15	<u>66.2</u> 67.5	<u>44.7</u> 48.7	47.0 50.2	<u>40.6</u> 40.6	
				3:15	55.2	48.7	48.2	40.6	-
		23:30 t	o 2	3:45	54.3	44.4	47.2	40.4	39.9
	1			0:00	55.9	44.4	47.3	39.9	1



Date	Monitoring	Time			Measured Sound Pressure Level, dB									
Position		iiiie			LAFmax	LAeq,T	LA10,T	LA90,T	LA90,T					
		00:00	to	00:15	57.4	44.3	47.1	39.7						
		00:15	to	00:30	56.7	44.1	46.8	40.2	39.7					
		00:30	to	00:45	56.7	42.7	44.5	39.8	39.7					
		00:45	to	01:00	59.4	44.0	46.9	39.8						
		01:00	to	01:15	51.8	42.2	44.4	38.8						
		01:15	to	01:30	56.1	43.9	46.8	38.6	37.1					
		01:30	to	01:45	54.3	42.4	45.6	38.0	57.1					
		01:45	to	02:00	53.8	41.2	44.4	37.1						
		02:00	to	02:15	49.3	40.1	42.9	36.1						
		02:15	to	02:30	48.5	38.8	41.6	35.7	35.1					
		02:30	to	02:45	49.6	38.8	41.0	35.4	55.1					
		02:45	to	03:00	51.7	40.2	43.7	35.1						
		03:00	to	03:15	52.9	38.6	40.4	34.7	_					
		03:15	to	03:30	48.3	38.1	40.8	34.7	34.5					
		03:30	to	03:45	51.1	38.6	40.6	34.5	0.15					
		03:45	to	04:00	49.5	38.5	41.5	35.0						
		04:00	to	04:15	51.2	37.8	40.0	34.4	_					
		04:15	to	04:30	49.4	37.0	39.0	34.2	34.1					
	04:30	to	04:45	50.5	38.2	40.4	35.1							
		04:45	to	05:00	43.3	36.3	38.2	34.1						
		05:00	to	05:15	53.4	38.4	40.3	34.8	_					
		05:15	to	05:30	56.7	38.5	40.6	35.1	34.8					
Monday MP		05:30	to	05:45	54.7	39.3	41.5	36.0						
	MP1	05:45	to	06:00	48.2	40.2	42.9	37.1						
13.11.2017		06:00	to	06:15	55.6	40.6	43.0	37.1	-					
		06:15 06:30	to	06:30	53.6 52.1	<u>40.4</u> 41.9	42.1	<u>37.6</u> 37.9	37.1					
			to	06:45			44.9		-					
		06:45 07:00	to	07:00 07:15	<u>61.5</u> 62.9	42.0 45.9	43.6 49.0	<u>39.2</u> 40.0						
		07:00	to	07:30	58.0	45.3	49.0	40.0	-					
		07:30	to to	07:45	62.5	45.3	48.3	41.0	40.0					
		07:45	to	07.45	59.6	45.4	47.8	41.4	-					
		07.45	to	08:15	60.4	45.1	47.6	41.9						
		08:15	to	08:30	61.2	44.9	46.2	42.1	-					
		08:30	to	08:45	62.6	46.6	49.4	42.3	41.4					
		08:45	to	09:00	60.1	46.7	49.5	43.0	-					
		09:00	to	09:15	63.5	49.5	52.6	44.8						
		09:15	to	09:30	60.1	48.8	51.6	44.8						
		09:30	to	09:45	71.5	49.2	52.0	43.2	43.2					
		09:45	to	10:00	61.7	47.6	50.2	43.4	1					
		10:00	to	10:15	60.9	47.6	50.2	42.6						
		10:15	to	10:30	69.5	50.8	52.5	42.2	40 7					
		10:30	to	10:45	63.2	47.2	49.3	41.2	40.7					
		10:45	to	11:00	60.7	46.2	49.8	40.7						
		11:00	to	11:15	65.5	48.4	51.4	43.6						
		11:15	to	11:30	66.7	45.8	47.7	39.9	20.0					
		11:30	to	11:45	62.2	46.6	49.1	42.7	39.9					
		11:45	to	12:00	68.7	50.2	52.5	43.5	1					



Appendix 2 Site Plan





Appendix 3

Plant Calculation - RPA

Plant sound power level, dB 80 76 74 71 70 65 59 52 Correction for number of units 2 3	11	63Hz	125Hz	250Hz	500Hz	1kHz	2kHz	4kHz	8kHz	Overal I					
Correction for number of units 2 3 <	(plant ope	n to plantı	room)				9	1:	2:	5(1	2	4	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	dBA
Loss 0	Plant sound power level, dB						80	76	74	71	70	65	59	52	
Plantroom reverberant correction L,m 1.4 W,m 2.7 H,m 2.5 RT 0.5 1 <	Correction for number of units					2	3	3	3	3	3	3	3	3	
Calculated plantroom rev noise le 84 80 78 75 74 69 63 56 Measured plantroom rev noise level 90 0	Loss						0	0	0	0	0	0	0	0	
Measured plantroom rev noise le 0	Plantroom reverberant correction	L,m <mark>1.4</mark> W	,m <mark>2.7</mark>	H,m <mark>2.5</mark>	RT	0.5	1	1	1	1	1	1	1	1	
Total plantroom rev noise level 84 80 78 75 74 69 63 56 Intake Plenum Loss 3 </td <td>Calculated plantroom rev noise le</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>84</td> <td>80</td> <td>78</td> <td>75</td> <td>74</td> <td>69</td> <td>63</td> <td>56</td> <td></td>	Calculated plantroom rev noise le						84	80	78	75	74	69	63	56	
Intake Plenum Loss 3	Measured plantroom rev noise le	0	0	0	0	0	0	0	0						
Intake opening surface area m2 2.4 <	Total plantroom rev noise level	84	80	78	75	74	69	63	56						
Intake opening directivity angle 90 m2 2.4 1 0 -2 -8 -14 -14 -14 -14 In to out correction	Intake Plenum Loss						3	3	3	3	3	3	3	3	
In to out correction	Intake opening surface area				m2	2.4	4	4	4	4	4	4	4	4	
Distance correction m 10 -31 <td>Intake opening directivity</td> <td>angle</td> <td>90</td> <td>m2</td> <td>2</td> <td>.4</td> <td>1</td> <td>0</td> <td>-2</td> <td>-8</td> <td>-14</td> <td>-14</td> <td>-14</td> <td>-14</td> <td></td>	Intake opening directivity	angle	90	m2	2	.4	1	0	-2	-8	-14	-14	-14	-14	
Loss Loss on intake side of system 6	In to out correction						-6	-6	-6	-6	-6	-6	-6	-6	
Addition 0 0 0 0 0 1 0 0 Unattenuated intake noise level 43 38 34 25 18 14 7 0 25 Attenuator Insertion Loss %FA 0 L,mm user 3 10 14 17 21 28 26 20 16 13 Attenuated intake noise level Discharge (plant ducted to discharge) T S Z4 17 4 -10 -12 -13 -16 13 Plant sound power level, dB Expension of each unit open to plantroom 1 78 74 71 70 65 59 52 Reverberant level via discharge 2 of each unit open to plantroom 1 78 74 72 69 68 63 57 50 Total sound power at discharge 2 of each unit open to plantroom 1 78 74 72 69 68 63 57 50 Correction for number of units 2 3 3 3 3 3 3 3 3 3 </td <td>Distance correction</td> <td></td> <td></td> <td></td> <td>m</td> <td>10</td> <td>-31</td> <td>-31</td> <td>-31</td> <td>-31</td> <td>-31</td> <td>-31</td> <td>-31</td> <td>-31</td> <td></td>	Distance correction				m	10	-31	-31	-31	-31	-31	-31	-31	-31	
Unattenuated intake noise level 43 38 34 25 18 14 7 0 29 Attenuator Insertion Loss %FA 0 L,mm user 3 10 14 17 21 28 26 20 16 Attenuated intake noise level 33 24 17 4 -10 -12 -13 -16 13 Mathemated intake noise level Discharge (plant ducted to discharge) Mathemate Mathemat Mathemate Mathem	Loss	Loss o	า	6	6	6	6	6	6	6	6				
Attenuator Insertion Loss %FA 0 L,mm user 3 10 14 17 21 28 26 20 16 Attenuated intake noise level 33 24 17 4 -10 -12 -13 -16 13 Matching Discharge (plant ducted to discharge) matching matching <td>Addition</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> <td>1</td> <td>0</td> <td>0</td> <td></td>	Addition						0	0	0	0	0	1	0	0	
Attenuated intake noise level 33 24 17 4 -10 -12 -13 -16 13 Discharge (plant ducted to discharge) 33 24 17 4 -10 -12 -13 -16 13 Plant sound power level, dB math for the plant of plant ducted to discharge 20 feach unit open to plantrom 1 78 74 71 70 65 59 52 Reverberant level via discharge 20 feach unit open to plantrom 1 78 74 72 69 68 63 57 50 Total sound power at discharge 20 feach unit open to plantrom 1 78 74 72 69 68 63 57 50 Total sound power at discharge 20 feach unit open to plantrom 1 78 74 72 69 68 63 57 50 Total sound power at discharge 20 feach unit open to plantrom 1 78 74 72 69 68 63 57 50 Total sound power at discharge 20 feach unit open to plantrom m2 2.4 2 <td>Unattenuated intake noise level</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>43</td> <td>38</td> <td>34</td> <td>25</td> <td>18</td> <td>14</td> <td>7</td> <td>0</td> <td>29</td>	Unattenuated intake noise level						43	38	34	25	18	14	7	0	29
Discharge (plant ducted to discharge) No	Attenuator Insertion Loss	%FA	0	L,mm	us	er 3	10	14	17	21	28	26	20	16	
Discnarge (plant ducted to discharge) H b H bb H b H bb	Attenuated intake noise level						33	24	17	4	-10	-12	-13	-16	13
Plant sound power level, dB 80 76 74 71 70 65 59 52 Reverberant level via discharge 2 of each unit open to plantroom 1 78 74 72 69 68 63 57 50 Total sound power at discharge 2 of each unit open to plantroom 1 78 74 72 69 68 63 57 50 Total sound power at discharge 2 3		-	harge)				63Hz	125Hz	250Hz	500Hz	1kHz	2kHz	4kHz	8kHz	Overal I
Reverberant level via discharge 2 of each unit open to plantroom 1 78 74 72 69 68 63 57 50 Total sound power at discharge							80	76	74	71	70	65	59	52	dB A
Total sound power at discharge Second power at discharge S		2 of each ur									_				
Correction for number of units 2 3 <			hit open												
End reflection loss m2 2.4 2 1 0 0 0 0 0 0 0 Discharge opening directivity angle 90 m2 2.4 1 0 -2 -8 -14 -14 -14 Distance correction m 10 -31	Total sound power at discharge		hit open	i to plantro	50111					73	72		-		
Discharge opening directivity angle 90 m2 2.4 1 0 -2 -8 -14 -14 -14 -14 Distance correction m 10 -31 <td></td> <td></td> <td>nit open</td> <td>i to plantro</td> <td></td> <td>2</td> <td>82</td> <td>78</td> <td>76</td> <td></td> <td></td> <td>67</td> <td>61</td> <td>54</td> <td></td>			nit open	i to plantro		2	82	78	76			67	61	54	
Distance correction m 10 -31 <td>Correction for number of units</td> <td></td> <td>nit open</td> <td>i to plantro</td> <td></td> <td></td> <td>82 3</td> <td>78 3</td> <td>76 3</td> <td>3</td> <td>3</td> <td>67 3</td> <td>61 3</td> <td>54 3</td> <td></td>	Correction for number of units		nit open	i to plantro			82 3	78 3	76 3	3	3	67 3	61 3	54 3	
Loss 0	Correction for number of units End reflection loss				m2	2.4	82 3 2	78 3 1	76 3 0	3 0	3	67 3 0	61 3 0	54 3 0	
Addition 0<	Correction for number of units End reflection loss Discharge opening directivity				m2 2	2.4 .4	82 3 2 1	78 3 1 0	76 3 0 -2	3 0 -8	3 0 -14	67 3 0 -14	61 3 0 -14	54 3 0 -14	
Unattenuated discharge noise lev 53 49 46 37 30 25 19 12 41 Attenuator insertion loss %FA 0 L,mm user 4 14 18 28 39 37 35 25 16	Correction for number of units End reflection loss Discharge opening directivity Distance correction				m2 2	2.4 .4	82 3 2 1 -31	78 3 1 0 -31	76 3 0 -2 -31	3 0 -8 -31	3 0 -14 -31	67 3 0 -14 -31	61 3 0 -14 -31	54 3 0 -14 -31	
Attenuator insertion loss %FA 0 L,mm user 4 14 18 28 39 37 35 25 16	Correction for number of units End reflection loss Discharge opening directivity Distance correction Loss				m2 2	2.4 .4	82 3 2 1 -31 0	78 3 1 0 -31 0	76 3 0 -2 -31 0	3 0 -8 -31 0	3 0 -14 -31 0	67 3 0 -14 -31 0	61 3 0 -14 -31 0	54 3 0 -14 -31 0	
	Correction for number of units End reflection loss Discharge opening directivity Distance correction Loss Addition	angle			m2 2	2.4 .4	82 3 2 1 -31 0 0	78 3 1 0 -31 0 0	76 3 -2 -31 0 0	3 0 -8 -31 0 0	3 0 -14 -31 0 0	67 3 0 -14 -31 0 0	61 3 0 -14 -31 0 0	54 3 0 -14 -31 0 0	41
	Correction for number of units End reflection loss Discharge opening directivity Distance correction Loss Addition Unattenuated discharge noise le	angle	90	m2	m2 2 m	2.4 .4 10	82 3 2 1 -31 0 0 53	78 3 1 0 -31 0 0 49	76 3 -2 -31 0 0 46	3 0 -8 -31 0 0 37	3 0 -14 -31 0 0 30	67 3 0 -14 -31 0 0 25	61 3 0 -14 -31 0 0 19	54 3 0 -14 -31 0 0 0 12	41
TOTAL UNATTENUATED 54 50 47 38 31 26 20 13 41	Correction for number of units End reflection loss Discharge opening directivity Distance correction Loss Addition Unattenuated discharge noise le Attenuator insertion loss	angle %FA	90	m2	m2 2 m	2.4 .4 10	82 3 2 1 -31 0 0 53 14	78 3 1 0 -31 0 0 49 18	76 3 -2 -31 0 0 46 28	3 0 -8 -31 0 0 0 37 39	3 0 -14 -31 0 0 30 37	67 3 -14 -31 0 0 25 35	61 3 0 -14 -31 0 0 0 19 25	54 3 0 -14 -31 0 0 0 12 16	41
TOTAL ATTENUATED 40 32 21 5 -5 -8 -5 -3 19	Correction for number of units End reflection loss Discharge opening directivity Distance correction Loss Addition Unattenuated discharge noise le Attenuator insertion loss	angle %FA	90	m2	m2 2 m	2.4 .4 10 er 4	82 3 2 1 -31 0 0 53 14 39	78 3 1 0 -31 0 0 49 18 31	76 3 -2 -31 0 0 46 28 18	3 0 -8 -31 0 0 37 39 -2	3 0 -14 -31 0 0 30 37 37 -7	67 3 0 -14 -31 0 0 25 35 -10	61 3 0 -14 -31 0 0 19 25 -6	54 3 0 -14 -31 0 0 0 12 16 -4	



Plant Calculation - RPB

IN (plant ope	63Hz	125Hz	250Hz	500Hz	1kHz	2kHz	4kHz	8kHz	Overal I dBA					
Plant sound power level, dB	80	76	74	71	70	65	59	52	UDA					
Correction for number of units				2	3	3	3	3	3	3	3	3		
Loss						0	0	0	0	0	0	0	0	
Plantroom reverberant correction	L,m 1.4 A	/,m 2.7	H,m 2.5	RT	0.5	1	1	1	1	1	1	1	1	
Calculated plantroom rev noise le	84	80	78	75	74	69	63	56						
Measured plantroom rev noise le	0	0	0	0	0	0	0	0						
Total plantroom rev noise level						84	80	78	75	74	69	63	56	
Intake Plenum Loss						3	3	3	3	3	3	3	3	
Intake opening surface area				m2	2.4	4	4	4	4	4	4	4	4	
Intake opening directivity	angle	0	m2	2	.4	5	6	7	8	9	9	9	9	
In to out correction	U		•		-6	-6	-6	-6	-6	-6	-6	-6		
Distance correction				-43	-43	-43	-43	-43	-43	-43	-43			
Loss	Loss o	on intake	6	6	6	6	6	6	6	6				
Addition				0	0	0	0	0	1	0	0			
Unattenuated intake noise level					35	32	31	29	29	25	18	11	33	
Attenuator Insertion Loss	%FA	0	L,mm	us	er 3	10	14	17	21	28	26	20	16	
Attenuated intake noise level	•					25	18	14	8	1	-1	-2	-5	11
Dis (plant duct	charge ed to disc	harge)				63Hz	125Hz	250Hz	500Hz	1kHz	2kHz	4kHz	8kHz	Overal I dBA
Plant sound power level, dB		• •		_		80	76	74	71	70	65	59	52	UDA
· · · ·	2 of each u	nit oper	to plantr	oom	1	78	74	72	69	68	63	57	50	
Total sound power at discharge						82	78	76	73	72	67	61	54	
Correction for number of units					2	3	3	3	3	3	3	3	3	
End reflection loss				m2	2.4	2	1	0	0	0	0	0	0	
Discharge opening directivity	angle	0	m2	2	2.4	5	6	7	8	9	9	9	9	
Distance correction				m	40	-43	-43	-43	-43	-43	-43	-43	-43	
Loss						0	0	0	0	0	0	0	0	
Addition						0	0	0	0	0	0	0	0	
Unattenuated discharge noise le							43	43	41	41	36	30	23	45
Attenuator insertion loss	%FA	0	L,mm	us	er 4	14	18	28	39	37	35	25	16	
Attenuated discharge noise level	•					31	25	15	2	4	1	5	7	15
		TOTA	L UNATT	ENU	ATED	46	44	43	41	41	37	30	23	45
	32	26	18	9	6	3	6	7	16					



Plant Calculation - RPC

IN (plant oper	63Hz	125Hz	250Hz	500Hz	1kHz	2kHz	4kHz	8kHz	Overal I dBA					
Plant sound power level, dB	-	-		_		80	76	74	71	70	65	59	52	UDA .
Correction for number of units				2	3	3	3	3	3	3	3	3		
Loss						0	0	0	0	0	0	0	0	
Plantroom reverberant correction	L.m 1.4 A	/.m 2.7	H.m 2.5	RT	0.5	1	1	1	1	1	1	1	1	
Calculated plantroom rev noise le	,	,	, -			84	80	78	75	74	69	63	56	
Measured plantroom rev noise le	0	0	0	0	0	0	0	0						
Total plantroom rev noise level						84	80	78	75	74	69	63	56	
Intake Plenum Loss						3	3	3	3	3	3	3	3	
Intake opening surface area				m2	2.4	4	4	4	4	4	4	4	4	
Intake opening directivity	angle	45	m2	2	2.4	3	3	3	3	3	3	3	3	
In to out correction			•		-6	-6	-6	-6	-6	-6	-6	-6		
Distance correction				45	-44	-44	-44	-44	-44	-44	-44	-44		
Loss	Loss o	on intake	n	6	6	6	6	6	6	6	6			
Addition				0	0	0	0	0	1	0	0			
Unattenuated intake noise level					32	28	26	23	22	18	11	4	26	
Attenuator Insertion Loss	%FA	0	L,mm	us	er 3	10	14	17	21	28	26	20	16	
Attenuated intake noise level						22	14	9	2	-6	-8	-9	-12	5
Dis (plant duct	charge ed to disc	harge)				63Hz	125Hz	250Hz	500Hz	1kHz	2kHz	4kHz	8kHz	Overal I dBA
Plant sound power level, dB		0.				80	76	74	71	70	65	59	52	ubа
	2 of each u	nit oper	to plantr	oom	1	78	74	72	69	68	63	57	50	
Total sound power at discharge					-	82	78	76	73	72	67	61	54	
Correction for number of units					2	3	3	3	3	3	3	3	3	
End reflection loss				m2	2.4	2	1	0	0	0	0	0	0	
Discharge opening directivity	angle	45	m2	2	2.4	3	3	3	3	3	3	3	3	
Distance correction	U U			m	45	-44	-44	-44	-44	-44	-44	-44	-44	
Loss						0	0	0	0	0	0	0	0	
Addition						0	0	0	0	0	0	0	0	
Unattenuated discharge noise lev						42	39	38	35	34	29	23	16	38
Attenuator insertion loss	%FA	0	L,mm	us	er 4	14	18	28	39	37	35	25	16	
Attenuated discharge noise level	I					28	21	10	-4	-3	-6	-2	0	10
		ΤΟΤΑ	L UNATT	ENU	ATED	43	40	38	35	34	30	23	16	39
	29	22	13	3	-1	-4	-1	0	11					