

10 - 11 LINCOLNS INN FIELDS

GARRET DESIGN LTD

DESIGN & ACCESS STATEMENT: PROPOSED PLANT LOCATION AND SPECIFICATION

DATE: 06/06/18

REVISION: P1





Contents

1. INTRODUCTION

1.1 Purpose

1.2 Scope

1.3 The Brief

2. ASSESSMENT

2.1 The Site

2.2 Historic Architectural Context

2.3 Constraints and Opportunities

3. EVALUATION & DESIGN

3.1 Plan

3.2 Section and Elevation

4. Correspondence

4.1 Daiken Technical Data

4.2 Auricl Acoustic Report

1. Introduction

1.1 Purpose

1.1 Purpose

The purpose of this document is to describe the intent to replace the existing Plant Units for 10-11 Lincolns Inn Fields. Although the scope of works is not substantial with only minor alterations to the exterior, a thorough analysis of the proposal has been articulated within this document. This is due to the sensitivity of the site location within the Bloomsbury Conservation Area and proximity of the Grade I Listed Sir John Soane Museum.

1.2 Scope

The statement:

Assesses the site and context

Considers the constraints and opportunities

Describes the Specification of new Condenser Units

Assesses the Acoustics on surrounding area

1.3 The Brief

The proposals are for works to existing offices at 10 - 11 Lincoln's Inn Fields. The brief considers the replacement of existing Plant located on the roof space of No.9 Lincolns Inn Fields, with more modern and efficient models.


2. Assessment

2.1 The Site

The site is situated at 10-11 Lincoln's Inn Fields WC2A3BP, which falls within the Bloomsbury Conservation Area. The referenced building consists of a; basement; mezzanine; ground; and five upper floors.

Built in 1970, Lincolns Inn fields was granted the Civic Trust Award 5 years after construction in 1975- This award is a recognition to buildings which have demonstrated architecture/ design of high quality, sustainability, access to all and having made a Irrefutable cultural, social or economic augmentation to the local community.

Juxtaposed to 10-11 Lincolns Inn Fields is; No.12-14 which is the home of the Sir John Soane Museum; No.9 is occupied by the Grain and Feed association which is classified as a Grade II listed building.



2. Assessment

2.2 Historic and Architectural context

The site is located within the Sub Area 9: Lincoln's Inn Fields/ Inns of Court/High Holborn of the Bloomsbury Conservation Area.

Lincoln's Inn Fields takes its name from its proximity next to (The honourable society of) Lincoln's Inn. The history of the two has been intertwined from its early beginnings as a recreational field for the law students, known as the Purse and Cup Field. The land was seized by the Crown in 1537 and subsequently purchased by William Newton in 1630's, who submitted an application to develop the land into the square we know today. Newton brokered an agreement with the council and Inns of Court to develop only the area around the perimeter of the fields, leaving the centre as a wide open space. The overall layout and west side of the square was built by Inigo Jones in the Baroque style of which only 16C Lindsey House remains.

In the following years the square was developed as grand individual town houses to the west, rows of terraces to the north and large institutional buildings to the south. The square was originally occupied by the landed gentry up until the 1790's but when fashion began to turn to the West they followed. Subsequently the wealthy lawyers began to move into the square, such as Farrer & Co and Frere Chomeley. More recently the entire south side of the square bar the Royal College of Surgeons is now occupied by London School of Economics. This microcosm of learned bodies of lawyers, solicitors, scholars, institutes and museums has characterised the square.

The key listed buildings upon this page epitomise the varying styles of classicism which are diffused and regurgitated to unify the squares order. Newcastle House was built in 1680's in the English Baroque, No.57-58 in the Neoclassical style in 1730's and the Royal College of Surgeons remodelled in the Neoclassical style in 1806.

The application site is located on the North side of Lincoln's Inn Fields with a detailed description following overleaf.




Lindsey House - A



No.57 & 58 - B



"Butterwalk" - C



Newcastle House - D



Royal College of Surgeons - E

2. Assessment

2.2 Historic and Architectural context

Lincoln's Inn Fields North Terraces

The Bloomsbury Conservation Area Appraisal and Management Strategy describes the notable characteristics of the north side of Lincoln's Inn Fields:

"5.149 The north side of the square comprises a row of town houses of different ages and styles, most of which are listed. They tend to occupy narrower plot widths than the properties on the west side. Dating from the early 18th to 20th centuries, the properties range from three to six storeys.

The most notable buildings in the row are Nos 12-14 (consec) housing Sir John Soane's Museum. Listed grade I, these three linked four storey houses were built and remodelled by Soane, for use as his house, studio and as a museum, over three decades from circa 1792 to 1824. They have a symmetrical grey brick front, with a highly sculpted projecting stone centrepiece.

Also of significance are Nos 17-18, built as offices for Equity and Law Assurance in 1871-72 by the eminent 19th century architect Alfred Waterhouse. Its western neighbour, at No 19, dates from 1868-69, and was designed by Philip Webb.

Of lesser interest are the 20th century buildings at Nos 3-4, 10-11, 20-23 (consec) and 29. The later examples, as found at Nos 3-4 by T Saunders Associates (1970-72) and Nos 10-11 by Westwood Piet, Poole and Smart(1983-84), are more consistent with the older town houses, due to the simpler architectural treatment of their brick fronts and their five-storey height.



2. Assessment

2.2 Historic and Architectural context

Sir John Soane Museum

Adjoining the site the three terrace's of No's 12-14 are occupied by the former home, studio and private museum of Sir John Soane, which is now open free to the public. It houses the collection and life works of one of the prominent British neoclassical architects of the 18th century. He notably also designed the Dulwich Picture Gallery and Bank of England and was appointed the Professor of Architecture at the Royal Academy in 1806. His bequeath gift to the nation has become a breeding ground of ideas for the pilgrims of students which study the antiquities, artefact, art, literature, models and studies which were left for "benefit of amateurs and students".

The terraces at Lincoln's Inn Fields were progressively rebuilt by Soane to form a symmetrical neoclassical facade. No.12 was built in c1792-94; No.13, c1812-13; No.14, c1824. The key architectural features are outlined below:


1. The central terrace No.13 is dominated by the Portland stone loggia with three bays of arched windows, ornate blind balustrade and enrich panels above. It is surmounted by a classical stone figures to each corner. The recessed second floor outer bays are articulated with pilaster strips and friezes. The projecting middle bay is adorned with acroteria.
2. The slim curved wrought iron balconies sit in front of the northern brick façades of No. 12 and 14.
3. The moderation of the logical vertical progression is controlled by the sill string on 2nd floor, brick modillion and stone cornice at 3rd floor. The dominance of the parapet line to the central bays is accentuated by the recess stone pilasters and balustrade with acroteria finials.
4. The slate mansard roof with dormers, brick chimneys and lead detailing sit above the 3rd floor stone cornice and block course on No.12 and 14.



Central terrace No. 13



Portland stone loggia with ornate blind balustrade



Museum Section



All Soane's buildings between 1808 and 1815 by J.Gandy

2. Assessment

2.3 Constraints and Opportunities

Opportunities


The brief and scope propose to replace the existing plant units currently accessed via the roof level of number 9 Lincolns Inn Fields. Due to number no.9 achieving a Grade II listing we must be sympathetic towards any works which could impact the buildings integrity. We will not be changing the location of the units, simply updating the model to a more efficient version.

Constraints



The addition of the new condenser units should not be in conflict acoustically or ecstatically with the iconic neighbouring architecture.

3. Evaluation & Design

3.1 Plan






DUCTWORK CONNECTIONS TO BE MADE IN SOLID DUCTWORK, WITH ONLY SUPPORT FROM MAIN WALL. NO BRACKET ON ROOF.



Evaluation & Design

3.2 Section and Elevation




Technical Data

4.1 Correspondence with Daikin



Ventilation
Technical Data
VAM-FC



- > VAM150FCVE
 - > VAM250FCVE
 - > VAM350FCVE
 - > VAM500FCVE
 - > VAM650FCVE
 - > VAM800FCVE
- > VAM1000FCVE
 - > VAM1500FCVE
 - > VAM2000FCVE

See full report in attachments




2-1 Technical Specifications				VAM150F C	VAM250F C	VAM350F C	VAM500F C	VAM650F C	VAM800F C	VAM1000 FC	VAM1500 FC	VAM2000 FC		
Power input - 50Hz	Heat exchange mode	Nom.	Ultra high	kW	0.132	0.161	0.071 (1)	0.147 (1)	0.188 (1)	0.320 (1)	0.360 (1)	0.617 (1)	0.685 (1)	
			High	kW	0.111	0.079	0.057 (1)	0.101 (1)	0.114 (1)	0.241 (1)	0.309 (1)	0.463 (1)	0.575 (1)	
			Low	kW	0.058	0.064	0.020 (1)	0.049 (1)	0.063 (1)	0.185 (1)	0.198 (1)	0.353 (1)	0.295 (1)	
	Bypass mode	Nom.	Ultra high	kW	0.132	0.161	0.071 (1)	0.147 (1)	0.188 (1)	0.320 (1)	0.360 (1)	0.617 (1)	0.685 (1)	
			High	kW	0.111	0.079	0.057 (1)	0.101 (1)	0.114 (1)	0.241 (1)	0.309 (1)	0.463 (1)	0.575 (1)	
			Low	kW	0.058	0.064	0.020 (1)	0.049 (1)	0.063 (1)	0.185 (1)	0.198 (1)	0.353 (1)	0.295 (1)	
Temperature exchange efficiency - 50Hz	Ultra high		%	77.0 (2) / 72.0 (3)	74.9 (2) / 69.5 (3)	78.0 (2) / 71.6 (4)	77.0 (2) / 70.2 (4)	77.0 (2) / 69.8 (4)	77.0 (2) / 67.8 (4)	78.0 (2) / 70.2 (4)	78.0 (2) / 69.5 (4)	78.0 (2) / 70.2 (4)		
	High		%	78.3 (2) / 72.3 (3)	76.0 (2) / 70.0 (3)	79.3 (2) / 71.9 (4)	78.8 (2) / 70.7 (4)	79.1 (2) / 71.2 (4)	78.2 (2) / 68.8 (4)	78.6 (2) / 71.1 (4)	79.6 (2) / 70.3 (4)	79.6 (2) / 71.3 (4)		
	Low		%	82.8 (2) / 73.2 (3)	80.1 (2) / 72.0 (3)	84.1 (2) / 73.0 (4)	80.9 (2) / 71.3 (4)	81.1 (2) / 72.9 (4)	79.1 (2) / 69.6 (4)	80.2 (2) / 73.4 (4)	80.8 (2) / 71.0 (4)	80.5 (2) / 74.6 (4)		
Enthalpy exchange efficiency - 50Hz	Cooling	Ultra high	%	60.3 (2)		63.4 (2)		60.3 (2)		62.4 (2)		63.4 (2)		
			High	%	61.9 (2)		61.2 (2)		65.0 (2)		63.4 (2)		64.2 (2)	
			Low	%	67.3 (2)		64.5 (2)		70.7 (2)		66.9 (2)		66.3 (2)	
	Heating	Ultra high	%	66.6 (2)		67.6 (2)		64.5 (2)		65.5 (2)		67.6 (2)		
			High	%	67.9 (2)		67.4 (2)		68.9 (2)		67.6 (2)		68.8 (2)	
			Low	%	72.4 (2)		70.7 (2)		73.7 (2)		71.1 (2)		69.7 (2)	
Operation mode				Heat exchange mode, bypass mode, fresh-up mode										
Heat exchange system				Air to air cross flow total heat (sensible + latent heat) exchange										
Heat exchange element				Specially processed non-flammable paper										
Dimensions	Unit	Height	mm	285		301		364		726				
		Width	mm	776		828		1,000		1,510				
		Depth	mm	525		816		868		1,160		868		
Weight	Unit	kg	24.0		33.0		51.0		54.0		63.0			
Casing				Material Galvanised steel plate										
Fan				Type Sirocco fan										
Air flow rate - 50Hz	Heat exchange mode	Ultra high	m³/h	150 (5)	250 (5)	350 (1)	500 (1)	650 (1)	800 (1)	1,000 (1)	1,500 (1)	2,000 (1)		
			High	m³/h	140 (5)	230 (5)	320 (1)	410 (1)	545 (1)	725 (1)	950 (1)	1,350 (1)	1,880 (1)	
			Low	m³/h	105 (5)	155 (5)	210 (1)	310 (1)	450 (1)	665 (1)	820 (1)	1,230 (1)	1,500 (1)	
		Bypass mode	Ultra high	m³/h	150 (5)	250 (5)	350 (1)	500 (1)	650 (1)	800 (1)	1,000 (1)	1,500 (1)	2,000 (1)	
			High	m³/h	140 (5)	230 (5)	320 (1)	410 (1)	545 (1)	725 (1)	950 (1)	1,350 (1)	1,880 (1)	
			Low	m³/h	105 (5)	155 (5)	210 (1)	310 (1)	450 (1)	665 (1)	820 (1)	1,230 (1)	1,500 (1)	
External static pressure - 50Hz	Ultra high	Pa	90 (5)	70 (5)	103 (1)	83 (1)	100 (1)	109 (1)	147 (1)	116 (1)	132 (1)			
	High	Pa	87 (5)	63 (5)	93 (1)	57 (1)	73 (1)	94 (1)	135 (1)	97 (1)	118 (1)			
	Low	Pa	40 (5)	25 (5)	51 (1)	35 (1)	49 (1)	78 (1)	100 (1)	80 (1)	77 (1)			
Fan motor				Quantity 2										
Output				50 Hz		W		30		80		106		
Air filter				Type Multidirectional fibrous fleeces										
Sound pressure level - 50Hz	Heat exchange mode	Ultra high	dBA	27.0	28.0	32.0	33.0	34.5	36.0	39.5	40.0			
		High	dBA	26.0		31.5		33.0	34.5	35.0	38.0			
		Low	dBA	20.5	21.0	23.5	24.5	27.0	31.0	34.0	35.0			
	Bypass mode	Ultra high	dBA	27.0	28.0	32.0	33.5	34.5	36.0	40.5	40.0			
		High	dBA	26.5	27.0	31.0	32.5	34.0	34.5	35.5	38.0			
		Low	dBA	20.5	21.0	24.5	25.5	27.0	31.0	33.5	35.0			
Operation range				Min. *CDB -15										
Max. *CDB				50										
Relative humidity				% 80% or less										
On coil temperature				Cooling Max. *CDB -										
				Heating Min. *CDB -										
Connection duct diameter				mm		100		150		200		250		
Insulation material				Self-extinguishable urethane foam										

Technical Data

4.1 Correspondence with Daikin

2-1 Technical Specifications			VAM150F C	VAM250F C	VAM350F C	VAM500F C	VAM650F C	VAM800F C	VAM1000 FC	VAM1500 FC	VAM2000 FC	
General	Supplier/Manufacturer details	Name or trademark	Daikin Europe N.V.									
	Product description	Model identifier	VAM150 FCVE	VAM250 FCVE	VAM350 FCVE	VAM500 FCVE	VAM650 FCVE	VAM800 FCVE	VAM1000 FCVE	VAM1500 FCVE	VAM2000 FCVE	
Specific energy consumption (SEC)	Cold climate	kWh/(m ² .a)	-56.0 (6)	-50.5 (6)								
	Average climate	kWh/(m ² .a)	-22.1 (6)	-27.0 (6)								
	Warm climate	kWh/(m ² .a)	-0.100 (6)	-5.30 (6)								
SEC class			D / (6)	B / (6)								
Type of product			Bidirectional RVU / (7)			Bidirectional NRVU / (7)						
Type of drive			Multi-speed drive									
Heat recovery system			recuperative									
Thermal efficiency	%		73.6 (3)	72.2 (3)	71.6 (4)	70.2 (4)	69.8 (4)	69.0 (4)	70.2 (4)	69.5 (4)	70.2 (4)	
Maximum flow rate at 100 Pa ESP	Flow rate	m ³ /h	130 (5)	207 (5)								
	Electric power input	W	129	160								
Sound power level (L _{WA})	dB		40	43	48	50	51	53		55	57	
Nominal flow rate	m ³ /s		-	0.097	0.139	0.181	0.222	0.278	0.417	0.556		
Reference flow rate	m ³ /s		0.025	0.040								
Reference pressure difference	Pa		50.0									
Effective electric power input	kW		-	0.055	0.121	0.140	0.241	0.279	0.465	0.532		
Specific power input	W/(m ³ /h)		0.626 (8)	0.445 (8)								
Internal specific fan power	W/(m ³ /s)		-	350	644	594	845	818	852	811		
Ventilation control	Type	Clock control										
	Factor	0.950 (6)										
Maximum external leakage	%		7.42	4.66	4.13	2.89	3.81	3.09	6.59	3.09	6.59	
Maximum internal leakage	%		4.50		8.10	8.20	7.70		6.50	7.70	6.50	
Filter energy performance	kWh		-		279 (7)							
Filter service warning			Displayed on controller / (5)									
Instructions for pre-disassembly			www.daikineurope.com/energylabel									
Annual electricity consumption	kWh/a		18.9 (6)	13.6 (6)								
Annual heating saved	Cold climate	kWh/a	41.0 (6)	40.6 (6)								
	Average climate	kWh/a	80.2 (6)	79.4 (6)								
	Warm climate	kWh/a	18.5 (6)	18.4 (6)								
Face velocity	m/s		-	0.648	0.926	1.20	1.48	1.38	1.39	1.38		
External pressure	Pa		-	59.7	56.4	52.6	56.8	84.8	60.0	67.7		
Internal pressure drop	Pa		-	94.9	143	151	210	249	189	160		
Fan efficiency	%		-	-	32.9	47.2	37.1					
2-2 Electrical Specifications			VAM150F C	VAM250F C	VAM350F C	VAM500F C	VAM650F C	VAM800F C	VAM1000 FC	VAM1500 FC	VAM2000 FC	
Power supply	Name	VE										
	Phase	1~										
	Frequency	Hz	50/60									
	Voltage	V	220-240/220									
Voltage range	Min.	%	-10									
	Max.	%	10									
Current	Minimum circuit amps (MCA)	A	0.900		1.30	1.60	2.50	3.00	5.00			
	Maximum fuse amps (MFA)	A	15.0		16.0							
	Fan motor rated output	kW	0.03x2		0.08x2	0.106x2	0.210x2		0.210x4			
	Full load amps (FLA)	Fan motor	A	0.400		0.600	0.700	1.10	1.30	2.20		
		Fan motor 2	A	0.400		0.600	0.700	1.10	1.30	2.20		
Fan motor 3		A	-		-	-	-	-	2.20			
Fan motor 4		A	-		-	-	-	-	2.20			

See full report in attachments



Acoustic Report



10-11 Lincoln's Inn Fields
London

Plant Noise Assessment Report

12 June 2018

For
1 GC Management Limited London
10-11 Lincolns Inn Fields
London
WC2A 3BP

10-11 Lincoln's Inn Fields, London
Plant Noise Assessment Report



Contents

SUMMARY	2
1.0 INTRODUCTION	3
2.0 DESCRIPTION OF SITE AND PROPOSALS	3
3.0 CAMDEN COUNCIL REQUIREMENTS	3
4.0 NOISE SURVEY METHODOLOGY	4
5.0 NOISE SURVEY RESULTS	5
6.0 PLANT NOISE ASSESSMENT	5
6.1 Proposed Plant	5
6.2 Nearest Noise Sensitive Property	5
6.3 Plant Noise Predictions	5
APPENDIX A – ACOUSTIC TERMINOLOGY	7
APPENDIX B – TIME HISTORY GRAPH	8

Project Number	13485	Issue Date	12 June 2018
Document Reference	R/PNA/1/180612	Version	01

Report Produced by	Peter Wheeler BSc(Hons) MSc AMIOA	T: 020 7859 4530 E: pwheeler@auricl.com
--------------------	--------------------------------------	--

Report Approved by	Nicholas Jones BEng(Hons) CEng MIOA	T: 07739 715411 E: njones@auricl.com
--------------------	--	---

auricl Limited	107 Cheapside London EC2V 6DN	Centaur House Ancells Business Park Ancells Road Fleet GU51 2UJ Registered Company 09824075
----------------	-------------------------------------	--

12 June 2018

Page 1

10-11 Lincoln's Inn Fields, London
Plant Noise Assessment Report



SUMMARY

A new ventilation unit is proposed as part of the refurbishment at 10-11 Lincolns Inn Fields in London. Camden Council has external noise requirements for new items of building services plant, requiring a background noise survey and plant noise assessment to be undertaken.

A noise survey has been undertaken by auricl to determine background noise levels that are representative of the nearest noise sensitive property.

A noise assessment has been undertaken to predict noise emissions associated with the ventilation unit at the nearest residential property.

The predicted noise level associated with the new ventilation unit complies with the Camden Council requirements during daytime and night-time periods.

Copyright © auricl Limited 2018. All rights reserved. This report is confidential to the party to whom it is addressed and their professional advisers for the specific purpose to which it refers. No responsibility is accepted to third parties, and neither the whole nor any part of this report nor reference thereto may be published or disclosed without the written consent of auricl Limited.

12 June 2018

Page 2

Acoustic Report

10-11 Lincoln's Inn Fields, London
Plant Noise Assessment Report



10-11 Lincoln's Inn Fields, London
Plant Noise Assessment Report



1.0 Introduction

A new ventilation unit is proposed externally as part of the building refurbishment at 10-11 Lincoln's Inn Fields. Camden Council has external noise requirements for new items of building services plant, requiring a background noise survey and plant noise assessment to be undertaken.

auricl has been instructed to undertake a background noise survey and acoustic assessment of the new ventilation unit, in relation to the Camden Council requirements.

This report presents the methodology and results of a noise survey to determine background noise levels that are representative of the nearest noise sensitive properties, as well as an acoustic assessment of the plant to address the Camden Council requirements.

2.0 Description of Site and Proposals

The site is occupied by an office building with Lincoln's Inn Fields and a park to the south-east and mainly office buildings around the remainder of the site. The nearest noise sensitive property is noted to be the hotel on the north-western side of Whetstone Park.

A heat recovery ventilation unit is proposed externally at roof level on the western side of the building.

Figure 2.1 shows the approximate site extent in red with the nearest noise sensitive property in green and the approximate location of the proposed ventilation unit in blue.

Figure 2.1 Existing Site Extent and Surroundings



3.0 Camden Council Requirements

Camden Council typically requires plant noise emissions to be limited to a level at least 10 dB lower than the L_{A90} background noise level, when determined at a distance of 1m from the nearest noise sensitive property.

4.0 Noise Survey Methodology

An unmanned environmental noise survey was undertaken over a 48-hour period between Wednesday 30 May 2018 and Friday 1 June 2018. This measurement period was selected to assess background noise levels during typical daytime and night-time periods, when the ventilation unit is proposed to be operational.

The equipment used for the noise survey is described in Table 4.1.

Table 4.1 Description of Equipment used for Noise Survey

Item	Make & Model	Serial Number
Type 1 sound level meter	01 dB FUSION	11388
Type 1 ½" microphone	GRAS 40 CE	259634
Calibrator	01 dB CAL21	34375252

L_{Aeq} and L_{A90} sound pressure levels were measured throughout the noise survey over 125-millisecond intervals.

The noise monitoring equipment was calibrated before and after the noise survey period. No significant change was found. Laboratory equipment calibration certificates can be provided upon request.

The measurement position was located with the microphone attached to an extendable pole protruding from a top floor window on the northern side of the site. The measurement position is considered to be representative of background noise levels at the nearest noise sensitive property (the hotel on the north-western side of Whetstone Park).

The measurement position is indicated in purple on Figure 4.1.

Figure 4.1 Site Plan Indicating Approximate Location of Measurement Position



Acoustic Report

10-11 Lincoln's Inn Fields, London
Plant Noise Assessment Report



Due to the nature of the noise survey, i.e. unmanned, we are unable to comment on the weather conditions throughout the entire noise survey period. However, at the beginning of the survey period, there was noted to be very little cloud with very dry, still and clear conditions. These conditions are understood to be representative of the full survey period and are considered appropriate for undertaking environmental noise measurements.

5.0 Noise Survey Results

Appendix B presents a time history graph showing the L_{Aeq} and L_{A90} sound pressure levels measured throughout the noise survey (shown as 15-minute intervals).

We would consider the levels measured to be reasonable, taking into account the location of the measurement position and the dominant nearby noise sources.

Due to the nature of the unmanned noise survey we are unable to comment on the exact noise climate throughout the entire survey period, however, at the beginning and end of the survey period, the daytime noise climate at the measurement position was noted to be affected by road traffic using surrounding roads. We anticipate the same would also be true of night-time periods.

The lowest measured L_{A90} background noise levels for daytime and night-time periods are summarised in Table 5.1.

Table 5.1 Lowest Measured Background Noise Levels

Lowest Measured L_{A90} (15 min) Background Noise Level (dB)	
Daytime (07:00 – 23:00 hours)	Night-time (23:00 – 07:00 hours)
52	51

6.0 Plant Noise Assessment

This section presents our assessment and calculations of noise emissions from the proposed condenser units, in relation to the Camden Council requirements.

6.1 Proposed Plant

A ventilation unit is proposed to be fitted on the roof of 10-11 Lincoln's Inn Fields. The proposed unit is a Daikin VAM500FC. The manufacturer states that the unit operates at a sound pressure level of 33dB at 1.5m. The proposed position of the plant is shown on Figure 2.1 in blue.

6.2 Nearest Noise Sensitive Property

We have considered the nearest noise sensitive property to be the hotel on the north side of Whetstone Park, the closest façade being at a distance of approximately 10m from the proposed ventilation unit.

6.3 Plant Noise Predictions

Our calculations to predict the plant noise level at the nearest noise sensitive property are presented in Table 6.1.

10-11 Lincoln's Inn Fields, London
Plant Noise Assessment Report



Table 6.1 Plant Noise Emission Calculations

Element	predicted sound pressure level (dB)	
VAM Unit Sound Pressure Level at 1.5m	33	
Distance Attenuation	-11	
Predicted Noise Level at Nearest Residential Property	22	
Lowest Background Noise Level	52 (day)	51 (night)
Difference	-30	-29

It can be seen that the predicted noise level complies with Camden Council's requirements at the nearest noise sensitive property during daytime and night-time periods.

Acoustic Report

10-11 Lincoln's Inn Fields, London
Plant Noise Assessment Report



Appendix A – Acoustic Terminology

Parameter	Description
Decibel (dB)	A logarithmic scale representing the sound pressure or power level relative to the threshold of hearing (20×10^{-6} Pascals).
Sound Pressure Level (L_p)	The sound pressure level is the sound pressure fluctuation caused by vibrating objects relative to the threshold of hearing.
A-weighting (L_A or dBA)	The sound level in dB with a filter applied to increase certain frequencies and decrease others to correspond with the average human response to sound.
$L_{Aeq,T}$	The A-weighted equivalent continuous noise level over the time period T (typically T= 16 hours for daytime periods, T = 8 hours for night-time periods). This is the sound level that is equivalent to the average energy of noise recorded over a given period.
$L_{A90}(15 \text{ min})$	The noise level exceeded for 90% of the time (also referred to as the background noise level), measured over a 15 minute period

10-11 Lincoln's Inn Fields, London
Plant Noise Assessment Report



Appendix B – Time History Graph

