

Application No:	Consultees Name:	Received:	Comment:	Response:
2018/2557/P	James Beggs	22/06/2018 11:02:12	OBJ	Irrespective of intent, drawings contain far too many errors indicative of lack of scrutiny by applicant. EG - north point varies substantially between drawings. New stair from LG to Ground floor not annotated as such. New balcony at Ground floor not annotated as such and contradicts limit of extension indicated on visual (overlooking?)Section lines are incorrect, both of which fail to indicate the new motorised rooflight shown on plan. Roof projections above first floor shown on second floor existing plan are not indicated anywhere else nor is the second floor plan included. Very poor standard which should not be acceptable to any planning authority as constituting the standard required of a valid submission. LBC require D&A statements to be prepared by a suitably qualified person - the signature complies, but the review clearly does not.??
