

**Addendum to the Air Quality Report Issued in Support of Planning Submission for 20-23 Greville Street.**

This statement is made with reference to Camden's Clean Air Action Plan and in particular, to the use in new developments of extra low Nox emitting boilers of below 40mg/kWh.

The above development does not include for the installation of any Nox emitting plant and therefore at the completion of the project there will be no Nox emitting boilers installed at the site.

It is possible that future incoming tenants may wish to install boilers that will emit Nox. Under these circumstances and in support of the boroughs Air Quality Plan the building owner undertakes to allow under licence of each tenant's tenure, the installation of plant creating Nox emissions of below 40mg/kWh.