

[REDACTED]
Sent: 29 June 2018 17:01

To: Planning [REDACTED]

Subject: 3rd Party Planning Application - 2018/2217/P

London Borough of Camden Our DTS Ref: 53102

Camden Town Hall Your Ref: 2018/2217/P

Argyle Street

Euston Road

London

WC1H 8EQ

29 June 2018

Dear Sir/Madam

Re: GARAGES TO THE SOUTH OF, 27A WEST END LANE, LONDON, NW6 4QJ

Waste Comments

Thank you for consulting Thames Water for the discharge of matters relating to combined (foul and surface water) network infrastructure. Thames Water confirms they are happy for the Combined water network condition referenced to be discharged based on the information submitted

Thank you for consulting Thames Water for the discharge of matters relating to piling. Thames Water are unable to support the discharge of this condition for the reasons outlined below.

Water Comments

Supplementary Comments

We support discharge of Conditions 11 and 17

Please submit a piling method statement and a piling layout plan clearly indicating the locations of all piles to be installed on the development site. This plan should show the positions of the piles in relation to Thames Water clean and waste water assets and local topography such as roads (please include road names), existing buildings and/or any other notable features.

More details on the asset protection impact study process can be found in the guidance document "Working Near Our Assets" (available online at

[REDACTED]
Please bear in mind that Thames Water will hold the developer and any relevant

contractor/sub-contractor liable for any losses incurred or damage caused to Thames Water assets arising from construction works or subsequent use of the facility.

Please use the following reference in all future correspondence: DTS 53102

Yours faithfully
Development Planning Department

