



Proposed Installation						
Ref. No.	Function	Manufacturer's Outdoor Unit Reference	Dimension mm			Sound Pressure dB(A)
			Height	Width	Depth	
P1	Ground Floor Offices VRF	RYYQ12T	1685	930	765	61
P2	First Floor Offices VRF	RXYSQ8TY1	1430	940	460	55
P3	Reception	RXM35M	550	828	311	47
P4	Ground Small Meeting Rm	RXM35M	550	828	311	47
P5	Ground High Level Wall	RXM35M	550	828	311	47
P6	Comms Room	RXM35M	550	828	311	47

Rev. A 25-04-2018  
 Specification to outdoor units revised.  
 Rev. B 28-08-2018  
 Sound barrier wall added.

8-12 Leeke Street LONDON WC1X 9HU  
 Proposed Roof Plan  
 Dwg. No: LSP02B  
 Scale 1:100 @ A3 Date: March 2018

15 Cloudesley Road, Islington, London N1 0EL  
 Tel: 07768 653012 Email: yap@yap.com