

SOUTH EAST ELEVATION

CDM REGULATIONS - SIGNIFICANT FINDINGS

RED: HIGH RISK	AMBER: MEDIUM RISK	GREEN: LOW RISK
Asbestos is likely to be present. Carry out Refurbishment/demolition survey. Report findings to CA/Principal Designer/Principal Contractor before proceeding.	Ensure regular collections of debris to ensure a clear site and prevent a fire hazard.	Proximity of trees may obstruct scatfolding to perimeter of building.
Existing glass is not safety glass therefore will shatter into sharp shards.		External level changes are common around the site - ensure level working platforms are achieved.
Removal of electrical switch gear - ensure this is carried out in accordance with the service providers instructions.		Removal of trees to be carried out in accordance with arboricultural's method statements.

Image: state sta	 AIR PERMEABILITY TARGET: NO WORSE THAN 3.0m³/(m²hr) BUILDING REGULATION PART E COMPLIANCE: SEPARATING WALL AND FLOOR CONSTRUCTIONS TO BE IN ACCORDANCE WITH ROBUST DETAILS 2017. PRIOR TO COMMENCEMENT, ROBUST DETAIL PLOT REGISTRATION IS REQUIRED, AND COMPLETED CHECKLISTS SUBMITTED ON COMPLETION. NB. PRE COMPLETION SOUND TESTING WILL BE REQUIRED IN THE EVENT OF ANY DIVERGENCE FROM THE RELEVANT ROBUST DETAIL 	<text><list-item></list-item></text>	ith & s.s. and a A
	H42.115 PRECAST CONCRETE CLADDING L30.550B METAL BALUSTRADE		
		C 25.05.18 GL CONSTRUCTION RSG rev date intaks description drawing: SOUTH EAST ELEVATION project: 5-7 LANCASTER GROVE drawing roc status code/ revi 1409/4503 C status: CONSTRUCTION scale 6.11: dtte: LS 0.011	
		1:50 FEB 2017 FEB 2017)