

Application No:	Consultees Name:	Received:	Comment:	Response:
2018/2880/P	Covent Garden Community Association	22/07/2018 20:11:06	NOBJ	The CGCA has no objection to the condenser units on this site as long as the officer is satisfied that residents will not be disturbed by the noise and the units will be switched off when the retail unit closes - a timer should be installed to ensure this.
