

Gentet, Matthias

From: Gentet, Matthias
Sent: 16 August 2018 11:18
To: Gentet, Matthias
Subject: FW: Your application reference: 2018/3495/L - 1 Chamberlain Street

From: Patrick Bonfield <patrick@webb-architects.co.uk>
Sent: 15 August 2018 15:45
To: Gentet, Matthias <Matthias.Gentet@camden.gov.uk>
Cc: return Webb <richard@webb-architects.co.uk>; Duncan Mercer <dm@michaelchester.co.uk>
Subject: RE: Your application reference: 2018/3495/L - 1 Chamberlain Street

Dear Matthias,

Thank you for the feedback.

Please see the following in reply:

Condition 4-

We confirm that the existing stairs, newel posts, spindles, handrails will remain.

The remedial work suggested by the structural engineer Duncan Mercer of Michael Chester and Partners is to remove the finishes and then re-wedge the treads and re-secure the stringers. The finishes will then be reinstated.

Condition 5-

The existing floor boards below the new floor boards to the ground floor will remain as will the existing joists to all floors.

Best regards

Patrick Bonfield

Architect RIBA

WEBB ARCHITECTS LIMITED

t 020 8968 0279
w www.webb-architects.co.uk
a Studio B

7 Wellington Road
Kensal Green
London NW10 5LJ

This e-mail may contain information which is confidential, legally privileged and/or copyright protected. This e-mail is intended for the addressee only. If you receive this in error, please contact the sender and delete the material from your computer. See our new Privacy Notice [here](#) which tells you how we store and process the data we hold about you and residents.