

[REDACTED]  
**Sent:** 17 August 2018 14:59

**To:** Planning [REDACTED]

**Subject:** 3rd Party Planning Application - 2018/3553/P

London Borough of Camden Our DTS Ref: 58852  
Camden Town Hall Your Ref: 2018/3553/P  
Argyle Street  
Euston Road  
London  
WC1H 8EQ

17 August 2018

Dear Sir/Madam

Re: Camden (Buck Street) Market, 192-200 Camden High Street, London, NW1 8QP

**Waste Comments**

With regard to surface water drainage, Thames Water would advise that if the developer follows the sequential approach to the disposal of surface water we would have no objection. Where the developer proposes to discharge to a public sewer, prior approval from Thames Water Developer Services will be required. Should you require further information please refer to our website. <https://developers.thameswater.co.uk/Developing-a-large-site/Apply-and-pay-for-services/Wastewater-services>


Thames Water would advise that with regard to Foul Water sewage network infrastructure capacity, we would not have any objection to the above planning application, based on the information provided

**Water Comments**

On the basis of information provided, Thames Water would advise that with regard to water network and water treatment infrastructure capacity, we would not have any objection to the above planning application. Thames Water recommends the following informative be attached to this planning permission. Thames Water will aim to provide customers with a minimum pressure of 10m head (approx 1 bar) and a flow rate of 9 litres/minute at the point where it leaves Thames Waters pipes. The developer should take account of this minimum pressure in the design of the proposed development.

Yours faithfully  
Development Planning Department

[REDACTED]



This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to

