

## SAMPLE/MOCK-UP CONDITION DISCHARGE FORM

597 - The Honourable Society of Lincoln's Inn

### PLANNING APPLICATION 2015/4408/P

**Condition Number:** 17 - A sample of all facing materials, including a sample panel of the facing brickwork (demonstrating the proposed colour, texture, face-bond and pointing), shall be provided on site and approved in writing before the relevant parts of the works are commenced. The approved panel shall be retained on site until the work has been completed

**Sample/Mock-Up:** Brick Sample Panel

**Location/s in final build:** Library Extension

**Date of review with LBC  
Conservation Officer:** 11th October 2017

**Description:** 225x107.5x68mm Hand-made clay facing brickwork. Bespoke blend: 90% *Dark Tudor Red*, 10% *Mixed Tudor Red*. Flemish bond, (half brick thick). 10mm Hydraulic Lime Mortar joints, colour: HZT60.

#### Photographs:



1. (Left) Photograph showing facing brickwork sample panel demonstrating the proposed colour, texture, face-bond, and pointing located adjacent to the existing Library building. Sample panel to be retained on site for the duration of the works.

2. (below) Photograph close up of sample panel.



**Associated Information:** Specification: F10  
Drawings: 597-12540, 12541, 12543, 12522  
597-15203, 15204  
597-40221, 40226, 40227, 40232, 40233, 41200, 41217, 41222, 41225,  
41239