



Domino's, 35 Pratt Street, Camden

Plant Noise Assessment

Report 18/0393/R01

Domino's, 35 Pratt Street, Camden

Plant Noise Assessment

Report 18/0393/R01

Domino's Pizza UK & Ireland Ltd

1 Thornbury
West Ashland
Milton Keynes
Buckinghamshire
MK6 4BB

Revision	Description	Date	Prepared	Approved
0	1 st Issue	28 August 2018	Josh Large	Adam Sharpe

This report and associated surveys have been prepared and undertaken for the private and confidential use of our client only. If any third party whatsoever comes into possession of this report, they rely on it at their own risk and Cole Jarman Limited accepts no duty or responsibility (including in negligence) to any such third party.



Plant Noise Assessment

Table of Contents

1	Introduction	3
2	Site Description	3
3	Background Noise Survey	3
3.1	Methodology	3
3.2	Results	4
4	Plant Noise Limits	5
5	Plant Noise Assessment	6
5.1	Proposed Installation	6
5.2	Methodology	6
5.3	Results	7
6	Conclusions	8

Attachments

Glossary of Acoustic Terms

18/0393/SP1

Site Plan illustrating unattended measurement position and 1st assessment position.

18/0393/SP2

Site Plan illustrating unattended measurement and assessment positions.

18/0393/TH01

Time history graph illustrating unattended measurement results.

18/0393/PNS1

Plant noise schedule.

18/0393/CS1-CS21

Plant noise calculation sheets.

 End of Section



Plant Noise Assessment

1 Introduction

- 1.1 It is proposed to convert the vacant restaurant at 35 Pratt Street, Camden to a Domino's Pizza outlet. As part of this conversion, an assessment of noise emissions from the unit's proposed mechanical services scheme is necessary.
- 1.2 Cole Jarman have undertaken an unattended noise survey on site in order to quantify the existing noise climate to inform a subsequent assessment of mechanical services noise.
- 1.3 This report contains full details of the environmental noise survey, assessment methodology and required mitigation measures in order to meet the services noise limits in accordance with Local Authority requirements.

2 Site Description

- 2.1 The site is located at 35 Pratt Street, Camden Town, London, NW1 0BG, and previously traded as a Japanese Restaurant. It occupies the ground floor with an additional basement, and has 2 storeys of residences above.
- 2.2 Bounded to the south eastern side of the site is Pratt Street, which similarly features restaurants with residences above running along its northern edge. Further to the south east is a residential area and underground car park. To the north of the site is St. Martin's Gardens, a local communal park. To the west of site is Bayham Street, a busy road consisting of commercial units and offices.
- 2.3 The noise climate perceived on site was most notably caused by road traffic on Pratt Street, with construction noise audible in the distance at the time of equipment setup.
- 2.4 The site falls under the jurisdiction of the London Borough of Camden.

3 Background Noise Survey

3.1 Methodology

- 3.1.1 An unattended noise survey was undertaken at the site commencing at 1200 hours on 15 August, concluding at 1200 hours on 16 August 2018.
- 3.1.2 Measurements of background noise levels were made at one position. This has been illustrated in attached site plan 18/0393/SP1 and is described below.
 - MP1 – Approximately 2m above ground level outside the rear kitchen window, approximately 1m from the façade.



Plant Noise Assessment

- 3.1.3 This position was selected to quantify background noise levels representative of those at the nearest noise sensitive receivers.
- 3.1.4 Measurements of the L_{Aeq} , L_{Amax} and L_{A90} indices were recorded over consecutive 15 minute periods for the duration of the survey using the equipment listed within table T1 (see attached Glossary of Acoustic Terms for an explanation of the noise units used).

Item	Manufacturer	Type
Sound Level Analyser	Brüel & Kjær	2260
Acoustic Calibrator	Brüel & Kjær	4231
Weatherproof windshield	Brüel & Kjær	UA1404

T1 Equipment used during noise survey.

- 3.1.5 The microphone was fitted within a weatherproof enclosure, and the sound level meter calibrated before and after the survey in order to confirm an acceptable level of accuracy. No significant drift was noted to have occurred.
- 3.1.6 The weather conditions when setting up the equipment were mild and cloudy, with a light breeze. When collecting the equipment, the weather conditions were mild with light rainfall. The periods affected by rainfall (taken to be from 0700 onwards on 16 August) have been omitted from our results.

3.2 Results

- 3.2.1 The results of the noise measurements are presented in attached figure 18/0393/TH01.
- 3.2.2 The representative background noise levels recorded during the day and night time measurement hours during the survey duration are set out in table T2 below:

Location	Representative Background Noise Level, dB(A)	
	Daytime (0700-2300)	Night time (2300-0700)
MP1: Approximately 2m above ground level outside the rear kitchen window	45	40

T2 Measured representative background noise levels, L_{A90} .



Plant Noise Assessment

4 Plant Noise Limits

- 4.1 The site falls under the jurisdiction of the London Borough of Camden.
- 4.2 Policy A4 of the London Borough of Camden's *Local Plan 2017* relates specifically to noise:

We will only grant permission for noise generating development, including any plant and machinery, if it can be operated without causing harm to amenity.

Planning conditions will be imposed to require that plant and equipment which may be a source of noise is kept working efficiently and within the required noise limits and time restrictions.

Conditions may also be imposed to ensure that attenuation measures are kept in place and are effective throughout the life of the development.

- 4.3 With regard to noise from new mechanical services plant, Appendix 3 of the Local Plan sets out the following:

A relevant standard or guidance document should be referenced when determining values for LOAEL and SOAEL for non-anonymous noise. Where appropriate and within the scope of the document it is expected that British Standard 4142:2014 'Methods for rating and assessing industrial and commercial sound' (BS 4142) will be used. For such cases a 'Rating Level' of 10 dB below background (15dB if tonal components are present) should be considered as the design criterion).

- 4.4 Based on the results of our background noise survey set out within table T2, in addition to the guidance set out above, we recommend that the following plant emission limits are to apply at the nearest noise sensitive premises, illustrated in 18/0393/SP2.

Location	Noise Emission Limit, dB	
	Daytime (0700-2300)	Night time (2300-0700)
AP1 – 1 st floor residential window on rear façade of site	35	30
AP2 – 1 st floor residential window on eastern façade of site	35	30
AP3 – 1 st floor window at residence to east of site	35	30

T3 Plant noise emission limits at the nearest residential properties.



Plant Noise Assessment

- 4.5 To put the recommended night-time limit of 30dB(A) in context, allowing for a typical loss of 12dB(A) from a partially open window would result in noise levels below 20dB(A) inside any residences exposed to this level of external plant noise.
- 4.6 Internal noise levels below 20dB(A) are more than 10dB(A) below the guideline level of $L_{Aeq,8h}$ 30dB suggested in BS8233:2014¹, as being appropriate for bedrooms to provide suitable conditions for sleeping.
- 4.7 The noise limits will be applied at the nearest noise sensitive dwellings.
- 4.8 The noise limits apply at 1m from the outside of the closest residential windows. Plant noise that includes a tonal component would also be subject to 5 dB penalty as set out in the planning condition.

5 Plant Noise Assessment

5.1 Proposed Installation

5.1.1 The specification for the proposed plant is as follows:

- AC Condenser Mitsubishi Heavy Industries FDC100VNX;
- Cold Room Condenser Karbox 2464;
- AHU Supply Fan Air Vent Tech Model 5;
- Kitchen Extract Fan Vent Axia Black Sabre BSC500/4.

5.1.2 The air conditioning unit, cold room condenser and extract fan have all been installed on the site's northern façade, while the supply fan is on the eastern side.

5.1.3 It has been assumed that all four units will be running during the site's opening hours of 1100 hours to 2300 hours, however only the cold room condenser will be operational during the store's closing times.

5.2 Methodology

5.2.1 Our assessment has used manufacturer's noise data for all units. This has been set out on the attached schedule 18/0393/PNS1. The noise data suggests that no tonality correction need be applied.

5.2.2 The noise levels generated by the plant have been calculated by correcting the noise levels for distance, radiation, duct and screening losses, and façade reflections where appropriate.

5.2.3 Details of our calculations are set out on attached sheets 18/0393/CS1-CS21

¹ British Standard 8233:2014 - Guidance and sound insulation and noise reduction for buildings



Plant Noise Assessment

5.3 Results

5.3.1 The results of our assessment indicate that mitigation of noise emissions will be required on all plant units in order to meet the Local Authority's noise emission limits.

5.3.2 It will be necessary to house both the AC and Cold Room condensers within acoustic enclosures.

5.3.3 The required enclosures can either be custom made using high performance acoustic louvres or manufactured enclosures. Examples of companies which produce high performance enclosures include Environ Technologies Ltd² and Sound Planning³. The minimum insertion loss requirements for these enclosures can be found in table T4 below.

The enclosure must be sized to allow sufficient airflow to the condenser unit and installed on suitable vibration isolation mounts.

5.3.4 In addition, it will also be necessary to attenuate the AHU Supply and Kitchen Extract fans through the provision of in-duct silencers.



Column Title	Insertion Loss at Octave Band Centre Frequency (Hz)							
	63	125	250	500	1k	2k	4k	8k
ENC-1: Acoustic Enclosure	12	13	20	29	36	37	39	39
AS-1: AHU Supply	8	16	28	43	47	47	39	22
AS-2: Kitchen Extract	8	17	32	40	42	30	23	13



T4 Required insertion losses

5.3.5 The silencers should be located within the demise of the building, close to the fans so that noise breakout from the ducts is also attenuated. The kitchen extract fan silencer should be Melinex-faced to allow for cleaning.

5.3.6 We would expect the insertion losses required for the silencers set out above to be achieved with the following configurations:

- AS-1: 1800mm, 35% free area;
- AS-2: 1800mm, 38% free area (Melinex-faced).



² <http://www.Environ.co.uk>

³ <http://www.soundplanning.co.uk/>



Plant Noise Assessment

- 5.3.7 These descriptions are only a guide and the figures in table T4 should be met. It should be noted that in order for these silencers to be applied, the ductwork will need to be extended.
- 5.3.8 Any pressure drops from the attenuators or the atmospheric duct termination grilles should be limited to 40Pa to avoid regenerated noise.
- 5.3.9 The fresh air intake and extract air discharge louvres should be sized at a face velocity of no more than 2m/s to avoid regenerated noise.
- 5.3.10 The rating noise levels calculated with the mitigation measures specified above are shown in table T5.

Location	Rating Noise Level, dB(A) (<i>Limit</i>)	
	Daytime (0700-2300)	Night time (2300-0700)
AP1 – Residence at rear façade of site, at first floor level	26 (35)	17 (30)
AP2 – Residence at eastern façade of site, at first floor level	29 (35)	0 (30)
AP3 – Residence to east of site, at first floor level	34 (35)	12 (30)

T5 Plant noise emission limits at the nearest residential properties.

6 Conclusions

- 6.1 It is proposed to convert the vacant restaurant at 35 Pratt Street, Camden to a Domino's Pizza outlet. As part of this conversion, an assessment of noise emissions from the unit's proposed mechanical services scheme is necessary.
- 6.2 Cole Jarman have undertaken an unattended noise survey on site in order to quantify the existing noise climate to inform a subsequent assessment of mechanical services noise.
- 6.3 Noise mitigation measures have been recommended on the basis of this assessment and it has been shown that the limits would be met at all times.

■ End of Section



Plant Noise Assessment

Glossary of Acoustic Terms

L_{Aeq} :

The notional steady sound level (in dB) which over a stated period of time, would have the same A-weighted acoustic energy as the A-weighted fluctuating noise measurement over that period. Values are sometimes written using the alternative expression dB(A) L_{eq} .

L_{Amax} :

The maximum A-weighted sound pressure level recorded over the period stated. L_{Amax} is sometimes used in assessing environmental noise when occasional loud noises occur, which may have little effect on the L_{Aeq} noise level. Unless described otherwise, L_{Amax} is measured using the “fast” sound level meter response.

L_{A10} & L_{A90} :

If non-steady noise is to be described, it is necessary to know both its level and degree of fluctuation. The L_{An} indices are used for this purpose. The term refers to the A-weighted level (in dB) exceeded for n% of the time specified. L_{A10} is the level exceeded for 10% of the time and as such gives an indication of the upper limit of fluctuating noise. Similarly, L_{A90} gives an indication of the lower levels of fluctuating noise. It is often used to define the background noise.

L_{A10} is commonly used to describe traffic noise. Values of dB L_{An} are sometimes written using the alternative expression dB(A) L_n .

L_{AX} , L_{AE} or SEL

The single event noise exposure level which, when maintained for 1 second, contains the same quantity of sound energy as the actual time varying level of one noise event. L_{AX} values for contributing noise sources can be considered as individual building blocks in the construction of a calculated value of L_{Aeq} for the total noise. The L_{AX} term can sometimes be referred to as Exposure Level (L_{AE}) or Single Event Level (SEL).

■ End of Section




Figure 18/0393/SP1

Title:
Site Plan illustrating Measurement and Assessment positions, at rear of site



Measurement Position



Assessment Position

Project:
Domino's, 35 Pratt Street, Camden

Date: August 2018 Revision: -

Scale:
Not to scale

Figure 18/0393/SP2

Title:
Site Plan illustrating Measurement and Assessment positions, at rear of site




Project:
Domino's, 35 Pratt Street, Camden

Date: August 2018 Revision: -

Scale:
Not to scale



Figure 18/0393/TH01





Schedule of Plant and Air Handling Equipment Sound Levels, dB

Reference	Description	Data ¹ Source	Noise Level Type	Noise Levels (dB)							
				63	125	250	500	1k	2k	4k	8k
Supply Fan	Air Vent Tech Model 5	Man	Sound Power, Lw	77	79	73	74	77	77	74	69
AC Condenser	Mitsubishi Heavy Industries FDC100VNX	Man	Sound Power, Lw	49	56	60	62	59	56	52	44
Cold Room Condenser	Karbox 2464	Man	Sound Power, Lw	64	61.5	61.5	63	59.4	57.3	54.1	46.9
Extract Fan	Vent Axia Black Sabre BSC500/4	Man	Sound Power, Lw	80	79	76	72	75	75	68	61

Notes

1 - Man refers to data supplied by the equipment manufacturer or supplier, Emp refers to data calculated using empirical formulae, and Meas refers to data measured by Cole Jarman



AC Condenser to AP1 Day



	Octave Band Centre Frequency (Hz)							
	63	125	250	500	1k	2k	4k	8k
Noise Source								
Noise Source - AC Condenser								
Sound Power Levels	49	56	60	62	59	56	52	44
Silencer								
Silencer - ENC-1								
	-12	-13	-20	-29	-36	-37	-39	-39
Point Source Radiation Loss								
Radiation - Quarterspherical								
	-5	-5	-5	-5	-5	-5	-5	-5
Point Source Distance Loss								
Start Distance (m)	1							
End Distance (m)	5							
	-14	-14	-14	-14	-14	-14	-14	-14
External Receiver								
External Receiver - AP1 Day								
Sound Pressure, Lp	18	24	21	14	4	0	-6	-14



Cold Room Condenser to AP1 Day



	Octave Band Centre Frequency (Hz)						
	63	125	250	500	1k	2k	4k

Noise Source

Noise Source - Cold Room Condenser

Sound Power Levels	64	62	62	63	59	57	54	47
---------------------------	-----------	-----------	-----------	-----------	-----------	-----------	-----------	-----------

Silencer

Silencer - ENC-1

	-12	-13	-20	-29	-36	-37	-39	-39
--	-----	-----	-----	-----	-----	-----	-----	-----

Point Source Radiation Loss

Radiation - Quarterspherical

	-5	-5	-5	-5	-5	-5	-5	-5
--	----	----	----	----	----	----	----	----

Point Source Distance Loss

Start Distance (m)

1

End Distance (m)

6

	-16	-16	-16	-16	-16	-16	-16	-16
--	-----	-----	-----	-----	-----	-----	-----	-----

External Receiver

External Receiver - AP1 Day

Sound Pressure, Lp	31	28	21	13	3	0	-5	-13
---------------------------	-----------	-----------	-----------	-----------	----------	----------	-----------	------------





Cold Room Condenser to AP1 Night



	Octave Band Centre Frequency (Hz)						
	63	125	250	500	1k	2k	4k

Noise Source

Noise Source - Cold Room Condenser

Sound Power Levels	64	62	62	63	59	57	54	47
---------------------------	-----------	-----------	-----------	-----------	-----------	-----------	-----------	-----------

Silencer

Silencer - ENC-1

	-12	-13	-20	-29	-36	-37	-39	-39
--	-----	-----	-----	-----	-----	-----	-----	-----

Point Source Radiation Loss

Radiation - Quarterspherical

	-5	-5	-5	-5	-5	-5	-5	-5
--	----	----	----	----	----	----	----	----

Point Source Distance Loss

Start Distance (m) 1

End Distance (m) 6

	-16	-16	-16	-16	-16	-16	-16	-16
--	-----	-----	-----	-----	-----	-----	-----	-----

External Receiver


External Receiver - AP1 Night

Sound Pressure, Lp	31	28	21	13	3	0	-5	-13
---------------------------	-----------	-----------	-----------	-----------	----------	----------	-----------	------------





Extract Fan to AP1 Day



	Octave Band Centre Frequency (Hz)						
	63	125	250	500	1k	2k	4k

Noise Source

Noise Source - Extract Fan

Sound Power Levels	80	79	76	72	75	75	68	61
---------------------------	-----------	-----------	-----------	-----------	-----------	-----------	-----------	-----------

Silencer

Silencer - AS-2

	-8	-17	-32	-40	-42	-30	-23	-13
--	----	-----	-----	-----	-----	-----	-----	-----

Circular Unlined Duct Losses CJ

Diameter (mm)	500							
Length (m)	1							
	0	0	0	0	0	0	0	0

End Reflection

Width/Diameter (m)	0.5							
Length (m)	0.5							
Rec or Circ - Rectangular								
Free or Flush - Flush								
	-9	-4	0	0	0	0	0	0

External Grille Directivity

Width (m)	0.65							
Height (m)	0.65							
Vertical (°)	90							
Horizontal (°)	160							
	-2	-3	-6	-11	-18	-21	-21	-21

Point Source Radiation Loss

Radiation - Hemispherical	-8	-8	-8	-8	-8	-8	-8	-8
---------------------------	----	----	----	----	----	----	----	----






18/0393/CS10

	Octave Band Centre Frequency (Hz)							
	63	125	250	500	1k	2k	4k	8k
<i>Point Source Distance Loss</i>								
Start Distance (m)	1							
End Distance (m)	2.5							
	-8	-8	-8	-8	-8	-8	-8	-8
<i>External Receiver</i>								
External Receiver - AP1 Day								
Sound Pressure, Lp	45	39	22	5	-1	8	8	11



Supply Fan to AP1 Day



	Octave Band Centre Frequency (Hz)						
	63	125	250	500	1k	2k	4k

Noise Source

Noise Source - Supply Fan

Sound Power Levels	77	79	73	74	77	77	74	69
---------------------------	-----------	-----------	-----------	-----------	-----------	-----------	-----------	-----------

Silencer

Silencer - AS-1

	-8	-16	-28	-43	-47	-47	-39	-22
--	----	-----	-----	-----	-----	-----	-----	-----

Circular Unlined Duct Losses CJ

Diameter (mm)	400							
Length (m)	1							
	0	0	0	0	0	0	0	0

End Reflection

Width/Diameter (m)	0.4							
Length (m)	0.4							
Rec or Circ - Rectangular								
Free or Flush - Flush								
	-10	-6	-1	0	0	0	0	0

External Grille Directivity

Width (m)	0.55							
Height (m)	0.55							
Vertical (°)	175							
Horizontal (°)	10							
	-1	-2	-3	-7	-8	-8	-8	-8

Point Source Radiation Loss

Radiation - Hemispherical	-8	-8	-8	-8	-8	-8	-8	-8
---------------------------	----	----	----	----	----	----	----	----





18/0393/CS11

		Octave Band Centre Frequency (Hz)							
		63	125	250	500	1k	2k	4k	8k
Point Source Distance Loss									
Start Distance (m)	1								
End Distance (m)	7.7								
		-18	-18	-18	-18	-18	-18	-18	-18
Maekawa Screening Loss									
Path Difference (m)	1								
		-10	-12	-15	-18	-20	-20	-20	-20
External Receiver									
External Receiver - AP1 Day									
Sound Pressure, Lp		22	18	0	-20	-24	-24	-19	-7



AC Condenser to AP2 Day



	Octave Band Centre Frequency (Hz)							
	63	125	250	500	1k	2k	4k	8k
Noise Source								
Noise Source - AC Condenser								
Sound Power Levels	49	56	60	62	59	56	52	44
Silencer								
Silencer - ENC-1								
	-12	-13	-20	-29	-36	-37	-39	-39
Point Source Radiation Loss								
Radiation - Quarterspherical								
	-5	-5	-5	-5	-5	-5	-5	-5
Point Source Distance Loss								
Start Distance (m)	1							
End Distance (m)	10							
	-20	-20	-20	-20	-20	-20	-20	-20
Maekawa Screening Loss								
Path Difference (m)	1							
	-10	-12	-15	-18	-20	-20	-20	-20
Facade Reflection								
Reflection (dB)	3							
	3	3	3	3	3	3	3	3
External Receiver								
External Receiver - AP2 Day								
Sound Pressure, Lp	5	9	3	-7	-19	-23	-29	-37



Cold Room Condenser to AP2 Day



	Octave Band Centre Frequency (Hz)							
	63	125	250	500	1k	2k	4k	8k
Noise Source								
Noise Source - Cold Room Condenser								
Sound Power Levels	64	62	62	63	59	57	54	47
Silencer								
Silencer - ENC-1								
	-12	-13	-20	-29	-36	-37	-39	-39
Point Source Radiation Loss								
Radiation - Quarterspherical								
	-5	-5	-5	-5	-5	-5	-5	-5
Point Source Distance Loss								
Start Distance (m)	1							
End Distance (m)	11.5							
	-21	-21	-21	-21	-21	-21	-21	-21
Maekawa Screening Loss								
Path Difference (m)	1							
	-10	-12	-15	-18	-20	-20	-20	-20
Facade Reflection								
Reflection (dB)	3							
	3	3	3	3	3	3	3	3
External Receiver								
External Receiver - AP2 Day								
Sound Pressure, Lp	19	13	3	-7	-20	-23	-28	-35



Cold Room Condenser to AP2 Night



	Octave Band Centre Frequency (Hz)							
	63	125	250	500	1k	2k	4k	8k
Noise Source								
Noise Source - Cold Room Condenser								
Sound Power Levels	64	62	62	63	59	57	54	47
Silencer								
Silencer - ENC-1								
	-12	-13	-20	-29	-36	-37	-39	-39
Point Source Radiation Loss								
Radiation - Quarterspherical								
	-5	-5	-5	-5	-5	-5	-5	-5
Point Source Distance Loss								
Start Distance (m)	1							
End Distance (m)	11.5							
	-21	-21	-21	-21	-21	-21	-21	-21
Maekawa Screening Loss								
Path Difference (m)	1							
	-10	-12	-15	-18	-20	-20	-20	-20
Facade Reflection								
Reflection (dB)	3							
	3	3	3	3	3	3	3	3
External Receiver								
External Receiver - AP2 Night								
Sound Pressure, Lp	19	13	3	-7	-20	-23	-28	-35



Extract Fan to AP2 Day



	Octave Band Centre Frequency (Hz)							
	63	125	250	500	1k	2k	4k	8k

Noise Source

Noise Source - Extract Fan

Sound Power Levels	80	79	76	72	75	75	68	61
---------------------------	-----------	-----------	-----------	-----------	-----------	-----------	-----------	-----------

Silencer

Silencer - AS-2

	-8	-17	-32	-40	-42	-30	-23	-13
--	----	-----	-----	-----	-----	-----	-----	-----

Circular Unlined Duct Losses CJ

Diameter (mm)	500							
Length (m)	1							
	0	0	0	0	0	0	0	0

End Reflection

Width/Diameter (m)	0.5							
Length (m)	0.5							
Rec or Circ - Rectangular								
Free or Flush - Flush								
	-9	-4	0	0	0	0	0	0

External Grille Directivity

Width (m)	0.65							
Height (m)	0.65							
Vertical (°)	30							
Horizontal (°)	100							
	0	0	0	-2	-8	-8	-8	-8

Point Source Radiation Loss

Radiation - Hemispherical	-8	-8	-8	-8	-8	-8	-8	-8
---------------------------	----	----	----	----	----	----	----	----






18/0393/CS15

		Octave Band Centre Frequency (Hz)							
		63	125	250	500	1k	2k	4k	8k
Point Source Distance Loss									
Start Distance (m)	1								
End Distance (m)	7								
		-17	-17	-17	-17	-17	-17	-17	-17
Maekawa Screening Loss									
Path Difference (m)	1								
		-10	-12	-15	-18	-20	-20	-20	-20
Facade Reflection									
Reflection (dB)	3								
		3	3	3	3	3	3	3	3
External Receiver									
External Receiver - AP2 Day									
Sound Pressure, Lp		31	24	7	-10	-17	-6	-6	-3



Supply Fan to AP2 Day



	Octave Band Centre Frequency (Hz)						
	63	125	250	500	1k	2k	4k

Noise Source

Noise Source - Supply Fan

Sound Power Levels	77	79	73	74	77	77	74	69
---------------------------	-----------	-----------	-----------	-----------	-----------	-----------	-----------	-----------

Silencer

Silencer - AS-1

	-8	-16	-28	-43	-47	-47	-39	-22
--	----	-----	-----	-----	-----	-----	-----	-----

Circular Unlined Duct Losses CJ

Diameter (mm)	400							
Length (m)	1							
	0	0	0	0	0	0	0	0

End Reflection

Width/Diameter (m)	0.4							
Length (m)	0.4							
Rec or Circ - Rectangular								
Free or Flush - Flush								
	-10	-6	-1	0	0	0	0	0

External Grille Directivity

Width (m)	0.55							
Height (m)	0.55							
Vertical (°)	90							
Horizontal (°)	0							
	0	0	0	0	-4	-7	-7	-7

Point Source Radiation Loss

Radiation - Hemispherical	-8	-8	-8	-8	-8	-8	-8	-8
---------------------------	----	----	----	----	----	----	----	----





18/0393/CS16

	Octave Band Centre Frequency (Hz)							
	63	125	250	500	1k	2k	4k	8k
<i>Point Source Distance Loss</i>								
Start Distance (m)	1							
End Distance (m)	2.5							
	-8	-8	-8	-8	-8	-8	-8	-8
<i>External Receiver</i>								
External Receiver - AP2 Day								
Sound Pressure, Lp	43	42	28	15	10	7	12	24



AC Condenser to AP3 Day



	Octave Band Centre Frequency (Hz)						
	63	125	250	500	1k	2k	4k

Noise Source

Noise Source - AC Condenser

Sound Power Levels	49	56	60	62	59	56	52	44
---------------------------	-----------	-----------	-----------	-----------	-----------	-----------	-----------	-----------

Silencer

Silencer - ENC-1

	-12	-13	-20	-29	-36	-37	-39	-39
--	-----	-----	-----	-----	-----	-----	-----	-----

Point Source Radiation Loss

Radiation - Quarterspherical

	-5	-5	-5	-5	-5	-5	-5	-5
--	----	----	----	----	----	----	----	----

Point Source Distance Loss

Start Distance (m)

1

End Distance (m)

14

	-23	-23	-23	-23	-23	-23	-23	-23
--	-----	-----	-----	-----	-----	-----	-----	-----

Facade Reflection

Reflection (dB)

3

	3	3	3	3	3	3	3	3
--	---	---	---	---	---	---	---	---

External Receiver

External Receiver - AP3 Day

Sound Pressure, Lp	12	18	15	8	-2	-6	-12	-20
---------------------------	-----------	-----------	-----------	----------	-----------	-----------	------------	------------





Cold Room Condenser to AP3 Day

	Octave Band Centre Frequency (Hz)							
	63	125	250	500	1k	2k	4k	8k
Noise Source								
Noise Source - Cold Room Condenser								
Sound Power Levels	64	62	62	63	59	57	54	47
Silencer								
Silencer - ENC-1								
	-12	-13	-20	-29	-36	-37	-39	-39
Point Source Radiation Loss								
Radiation - Quarterspherical								
	-5	-5	-5	-5	-5	-5	-5	-5
Point Source Distance Loss								
Start Distance (m)	1							
End Distance (m)	15.5							
	-24	-24	-24	-24	-24	-24	-24	-24
Facade Reflection								
Reflection (dB)								
	3							
	3	3	3	3	3	3	3	3
External Receiver								
External Receiver - AP3 Day								
Sound Pressure, Lp	26	23	16	8	-2	-5	-11	-18



Cold Room Condenser to AP3 Night



	Octave Band Centre Frequency (Hz)						
	63	125	250	500	1k	2k	4k

Noise Source

Noise Source - Cold Room Condenser

Sound Power Levels	64	62	62	63	59	57	54	47
---------------------------	-----------	-----------	-----------	-----------	-----------	-----------	-----------	-----------

Silencer

Silencer - ENC-1

	-12	-13	-20	-29	-36	-37	-39	-39
--	-----	-----	-----	-----	-----	-----	-----	-----

Point Source Radiation Loss

Radiation - Quarterspherical

	-5	-5	-5	-5	-5	-5	-5	-5
--	----	----	----	----	----	----	----	----

Point Source Distance Loss

Start Distance (m)

1

End Distance (m)

15.5

	-24	-24	-24	-24	-24	-24	-24	-24
--	-----	-----	-----	-----	-----	-----	-----	-----

Facade Reflection

Reflection (dB)

3

	3	3	3	3	3	3	3	3
--	---	---	---	---	---	---	---	---

External Receiver


External Receiver - AP3 Night

Sound Pressure, Lp	26	23	16	8	-2	-5	-11	-18
---------------------------	-----------	-----------	-----------	----------	-----------	-----------	------------	------------





Extract Fan to AP3 Day



	Octave Band Centre Frequency (Hz)						
	63	125	250	500	1k	2k	4k

Noise Source

Noise Source - Extract Fan

Sound Power Levels	80	79	76	72	75	75	68	61
---------------------------	-----------	-----------	-----------	-----------	-----------	-----------	-----------	-----------

Silencer

Silencer - AS-2

	-8	-17	-32	-40	-42	-30	-23	-13
--	----	-----	-----	-----	-----	-----	-----	-----

Circular Unlined Duct Losses CJ

Diameter (mm) 500

Length (m) 1

	0	0	0	0	0	0	0	0
--	---	---	---	---	---	---	---	---

End Reflection

Width/Diameter (m) 0.5

Length (m) 0.5

Rec or Circ - Rectangular

Free or Flush - Flush

	-9	-4	0	0	0	0	0	0
--	----	----	---	---	---	---	---	---

External Grille Directivity

Width (m) 0.65

Height (m) 0.65

Vertical (°) 10

Horizontal (°) 90

	0	0	0	0	-4	-7	-7	-7
--	---	---	---	---	----	----	----	----

Point Source Radiation Loss

Radiation - Hemispherical

	-8	-8	-8	-8	-8	-8	-8	-8
--	----	----	----	----	----	----	----	----






18/0393/CS20

		Octave Band Centre Frequency (Hz)							
		63	125	250	500	1k	2k	4k	8k
Point Source Distance Loss									
Start Distance (m)	1								
End Distance (m)	11								
		-21	-21	-21	-21	-21	-21	-21	-21
Facade Reflection									
Reflection (dB)	3								
		3	3	3	3	3	3	3	3
External Receiver									
External Receiver - AP3 Day									
Sound Pressure, Lp		38	32	18	6	3	12	12	15



Supply Fan to AP3 Day



	Octave Band Centre Frequency (Hz)						
	63	125	250	500	1k	2k	4k

Noise Source

Noise Source - Supply Fan

Sound Power Levels	77	79	73	74	77	77	74	69
---------------------------	-----------	-----------	-----------	-----------	-----------	-----------	-----------	-----------

Silencer

Silencer - AS-1

	-8	-16	-28	-43	-47	-47	-39	-22
--	----	-----	-----	-----	-----	-----	-----	-----

Circular Unlined Duct Losses CJ

Diameter (mm)	400							
Length (m)	1							
	0	0	0	0	0	0	0	0

End Reflection

Width/Diameter (m)	0.4							
Length (m)	0.4							
Rec or Circ - Rectangular								
Free or Flush - Flush								
	-10	-6	-1	0	0	0	0	0

External Grille Directivity

Width (m)	0.55							
Height (m)	0.55							
Vertical (°)	10							
Horizontal (°)	30							
	1	2	3	4	4	6	6	6

Point Source Radiation Loss

Radiation - Hemispherical	-8	-8	-8	-8	-8	-8	-8	-8
---------------------------	----	----	----	----	----	----	----	----





18/0393/CS21

		Octave Band Centre Frequency (Hz)							
		63	125	250	500	1k	2k	4k	8k
Point Source Distance Loss									
Start Distance (m)	1								
End Distance (m)	5								
		-14	-14	-14	-14	-14	-14	-14	-14
Facade Reflection									
Reflection (dB)	3								
		3	3	3	3	3	3	3	3
External Receiver									
External Receiver - AP3 Day									
Sound Pressure, Lp		41	41	28	16	16	17	22	34



An RSK company

Cole Jarman Limited Reg. in England and Wales No. 7102436
Spring Lodge, 172 Chester Road, Helsby, United Kingdom WA6 0AR

info@colejarman.com www.colejarman.com

Head Office +44 (0)1932 829007
John Cree House, 24b High Street, Addlestone, Surrey KT15 1TN
Manchester Office +44 (0)161 2093644
Peter House, 1 Oxford Street, Manchester M1 5AN