



5 All concrete (except blinding concrete) is to be minimum 30 Nimm2 with 20 demeter aggregate and is to be mechanically vibrated, when placed. All concrete work must comply with BS 8110.

6 The Contractor must provide full details of their proposed temporary works, before commencing the structural works.

4 All brickwork is to be 20.5 Nmm2 in 1:16 mortar unless used as an external facing brick. All blockwork is to be 7.0 Nmm2 in 1:16 mortar. All unless noted offerwise on drawing.

2 All steelwork is to be grade S355, shot blasted and painted with 2 coats of zinc phosphate primer or red oxide primer unless noted on drawing as galvanised, or concrete cased. All boits are to be grade 8.8. All fabrication is to be done in accordance with BS5950.

This drawing is to be read in conjunction with the Architects drawings and the project specification. Do not scale off the drawing.

3 All timber is to be C24 grade (unless noted as C16 on the drawing) and tanalised. Paint all cut ends with timber preservative, on site. Plywood must comply with EN638, Class 3.

Typical Underpin Shoring Section Detail

COOPER ASSOCIATES CONSULTING CIVIL AND STRUCTURAL ENGINEERS

6 Bartholomew Place LONDON, EC1A 7HH Tet 020 7606 0192 post

Atelier Brown

Flat 1 9-10 Regent Square London, WC1H 8HZ

Typical Temporary Works Details

CA5591/T01