



Summary of Natural Moisture Content, Liquid Limit and Plastic Limit Results

| | | | |
|------------------|----------------------------------|-------------------|------------|
| Job No. 24222 | Project Name 32 Kylemore Road | Programme | |
| | | Samples received | 16/03/2018 |
| Project No. - | Client Plus Rooms | Schedule received | 19/03/2018 |
| | | Project started | 20/03/2018 |
| | | Testing Started | 23/03/2018 |

| Hole No. | Sample | | | | Soil Description | NMC % | Passing 425µm % | LL % | PL % | PI % | Remarks |
|----------|--------|----------|-----------|------|---|----------|-----------------------|---------|---------|---------|---------|
| | Ref | Top m | Base m | Type | | | | | | | |
| WS1 | - | 1.50 | - | D | Brown, orangish brown and blue grey silty CLAY with rare rootlets and fine gravel | 32 | 99 | 94 | 29 | 65 | |
| WS1 | - | 4.00 | - | D | Brown and blue grey silty CLAY with occasional selenite crystals | 34 | 100 | 86 | 28 | 58 | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |

| | | | |
|--|--|--|---|
| | Test Methods: BS1377: Part 2: 1990: Natural Moisture Content : clause 3.2 Atterberg Limits: clause 4.3, 4.4 and 5.0 | Test Report by K4 SOILS LABORATORY Unit 8 Olds Close Olds Approach Watford Herts WD18 9RU Tel: 01923 711 288 Email: James@k4soils.com | Checked and Approved Initials J.P Date: 26/03/2018 |
| | Approved Signatories: K.Phaure (Tech.Mgr) J.Phaure (Lab.Mgr) | | MSF-5-R1 |