

5 October 2018

Mechanical Addendum 1

Re: Street Markets, Centre Point

Dear Sirs

1. Front of House Kitchen Extract ductwork specification

Front of house kitchen extract ductwork from canopies to the back corridor / store room at ground floor, will be exposed to customers' view. The contractor shall supply and install Stainless Steel ductwork of the following specification

- a. Duct to be straight seamed duct – spirally wound duct will not be acceptable
- b. Slip jointed and sealed
- c. 1mm sheet thickness
- d. Mirror polished finish
- e. Stainless steel access panels for cleaning every 2m centres

Contractor to refer to attached image "FOH ductwork" in respect of the extent of stainless-steel ductwork installation and required aesthetics of the duct. Contractor to contact the following supplier to obtain cost:

Airmatic
Kieran Cunliffe
Contracts Engineer
kieran@airmatic.co.uk
Office: 0161 764 4004 | Fax: 0161 762 9992 Mob:07841574010
Wellington Street, Bury, BL8 2BD
Airmatic.co.uk

Contractor to include cost of Stainless-Steel ductwork supply and installation as separate item in their cost return under:

"Uplift cost for Supply of FOH Stainless Steel Ductwork"

Cost to include price difference between standard ductwork specified in tender documents and Stainless-steel ductwork

2. PC Sum for Acoustic Attenuation of Mechanical Plant

This PC sum is only for items not shown on tender drawings or specified in the tender documents. All items that are shown on the drawings, i.e. ductwork silencers etc., are to be included in tender cost, under "Ventilation – Supply and Extract Ductwork"



We could help
lower your energy bills



3. Carrier Plant

Please find attached specification of proposed Carrier plant. Contractor to note change in specification of air cooled heat pump HP.5.

Contractor shall obtain cost from a nominated supplier:

John Colling
Regional Account Manager | Carrier Air Conditioning. A division of Toshiba Carrier UK Ltd
Unit 20 Rosevale Industrial Estate
171 Moira Road
Lisburn
Co Antrim
BT28 1RW

Office Direct Tel: +44 (0) 2892670431 | Mobile: +44 (0) 7712790870
Fax: +44 (0) 2892601729
john.colling@carrier.utc.com | www.ciat.uk.com |www.carrieraircon.co.uk