THE SYSTEM SHALL BE INSTALLED TO COMPLY WITH ACPO 2000, BS EN 50131 & BS 8243.

CONTRACTOR TO FIT DATA PROTECTION ACT COMPLIANT CCTV COVERAGE SIGN AT FRONT ENTRANCE.

SECURITY INSPECTORATE (NSI) TO NACOSS GOLD STANDARD.

ALL FIRE ALARM CABLES SHALL BE PH120 ENHANCED GRADE CABLE; FIRE RETARDANT, SELF EXTINGUISHING.

ALL EQUIPMENT AND ACCESSORIES TO BE RECESSED IN WALLS ie. A FLUSH INSTALLATION. UNDER NO CIRCUMSTANCES WILL SURFACE WIRING BE ACCEPTED.

ALL WIREWAYS TO BE CONCEALED WITHIN THE BUILDING FABRIC, EXCEPT IN RISERS, CEILING VOIDS AND FLOOR VOIDS.

DRAWING TO BE READ IN CONJUNCTION WITH THE INSTALLATION SPECIFICATION AND ALL OTHER RELEVANT DRAWINGS. FIRE ALARM SYSTEM TO COMPLY WITH BS5839 PART 1:2017

GENERAL NOTES



