

WIRING SYSTEMS TO BE SUPPORTED BY FIRE-RESISTANT FIXINGS AND FASTENINGS.
CABLE TO BE CLIPPED TO SOFFIT UNLESS OTHERWISE INDICATED.
AT EACH DETECTOR, CABLE TO BE ADEQUATELY SUPPORTED BETWEEN SOFFIT AND CEIL LEVEL. CABLE TO TERMINATE INTO A BESA BOX AT CEILING LEVEL.
FOR WALL MOUNTED DEVICES CABLE TO TERMINATE ABOVE CEILING INTO 20mm GALVANIS CONDUIT RECESSED INTO BUILDING FABRIC.
INTRUDER ALARM SYSTEM TO BE INSTALLED TO THE STANDARDS REQUIRED BY THE NATION SECURITY INSPECTORATE (NSI) TO NACOSS GOLD STANDARD.
THE SYSTEM SHALL BE INSTALLED TO COMPLY WITH ACPO 2000, BS EN 50131 & BS 8243.
CONTRACTOR TO FIT DATA PROTECTION ACT COMPLIANT CCTV COVERAGE SIGN AT FRO ENTRANCE. DEVICES ON COLUMNS TO BE FULLY FIRE PROTECTED BY BUILDER.
ALL SERVICES/ROUTES THROUGHOUT BUILDING TO BE FULLY CO-ORDINATED ON SITE PR
TO INSTALLATION.
NOTE:
FIRE ALARM TO BE INTERFACED WITH, BUT NOT LIMITED TO THE FOLLOWING:
<ol> <li>MECHANICAL PLANT</li> <li>ANSUL FIRE SUPPRESSION SYSTEMS</li> </ol>
<ol> <li>MUSIC / PLAYER / AUDIO VISUAL SYSTEMS. AUDIO TO 0%</li> <li>LIGHTING TO 100%</li> </ol>
<ol> <li>GAS SUPPLY SHUTDOWN</li> <li>DB KITCHEN - COOKING. CONTACTOR OPERATED SHUTDOWN</li> </ol>
7. WHERE APPLICABLE: HOLD OPEN DOORS FAIL CLOSED. AUTOMATIC DOORS TO EXTERNAL FIRE EXIT TO POWER OPEN
<ol> <li>SPRINKLER SYSTEM</li> <li>LANDLORD FIRE ALARM SYSTEM</li> </ol>
A TENDER ISSUE MK 01/10/20
REV DETAILS BY APP DATE CLIENT:
STREAT MARKETS LTD
CENTRE POINT, LINK BLDG, W1 DRAWING BASEMENT LEVEL -1
FIRE ALARM & SECURITY & AV
DRAWN APPROVED DATE:
BY: M.KNOTT BY: SEP'18
PROJECT No.:DRAWING No.:SCALE: E0111:50
LEHDING SERVICES DESIGN LTD Unit 10, 10 Redlands Crescent, Larne, Co. Antrim, N.Ireland. BT40 1FF. Tel. +44(0) 2828 277 123.
Global House, Ashley Avenue, Epsom, London. KT18 5AD. Tel. +44(0) 1372 253 207. Web: www.lehding.co.uk Email. info@lehding.co.uk
Unit 10, 10 Redlands Crescent, Larne, Co. Antrim, N.Ireland. BT40 1FF. Tel. +44(0) 2828 277 123. Global House, Ashley Avenue, Epsom, London. KT18 5AD. Tel. +44(0) 1372 253 207.

GENERAL NOTES DRAWING TO BE READ IN CONJUNCTION WITH THE INSTALLATION SPECIFICATION AND ALL OTHER RELEVANT DRAWINGS.

FIRE ALARM SYSTEM TO COMPLY WITH BS5839 PART 1:2017

ALL WIREWAYS TO BE CONCEALED WITHIN THE BUILDING FABRIC, EXCEPT IN RISERS, CEILING VOIDS AND FLOOR VOIDS.

ALL EQUIPMENT AND ACCESSORIES TO BE RECESSED IN WALLS IE. A FLUSH INSTALLATION. UNDER NO CIRCUMSTANCES WILL SURFACE WIRING BE ACCEPTED.

ALL FIRE ALARM CABLES SHALL BE PH120 ENHANCED GRADE CABLE; FIRE RETARDANT, SELF EXTINGUISHING.