

Application ref: 2017/4062/P
Contact: Gideon Whittingham
Tel: 020 7974 5180
Date: 19 July 2018

Development Management
Regeneration and Planning
London Borough of Camden
Town Hall
Judd Street
London
WC1H 9JE
Phone: 020 7974 4444
camden.gov.uk
planning@camden.gov.uk
www.camden.gov.uk

Contour Planning Services Ltd
Weltech Centre
Ridgeway
Welwyn Garden City
AL7 2AA

Dear Sir/Madam

DECISION

Town and Country Planning Act 1990 (as amended)

Full Planning Permission Granted Subject to a Section 106 Legal Agreement

Address:
10 Gate Street
London
WC2A 3HP

Proposal:

Erection of a seven storey rear extension on Little Turnstile and mansard roof extension in association with change of use of office (B1a) at second to fifth floor levels and restaurant (A3) at basement, ground and first floor levels to residential 2 x 1 bedroom unit and 2x2 bedroom unit (C3) and flexible A1/A3 use at lower ground and ground floor level.

Drawing Nos: (PL)001 /P1, (EX)099/P1, (EX)100/P1, (EX)101/P1, (EX)102/P1, (EX)103/P1, (EX)104/P1, (EX)105/P1, (EX)106/P1, (EX)200/P1, (EX)300/P1, (EX)301/P1, (EX)302/P1, (EX)303/P1, (PL)099/P1, (PL)100/P1 [showing 6 cycle spaces], (PL)101/P1, (PL)102/P1, (PL)103/P2, (PL)104/P2, (PL)105/P2, (PL)106/P2, (PL)107/P2, (PL)200/P3, (PL)302/P2, (PL)303/P2, Plant Noise Assessment Report 8146/PNA dated: 24 July 2017, prepared by RBA ACOUSTICS.

The Council has considered your application and decided to grant permission subject to the following condition(s):

Condition(s) and Reason(s):

- 1 The development hereby permitted must be begun not later than the end of three years from the date of this permission.

Reason: In order to comply with the provisions of Section 91 of the Town and Country Planning Act 1990 (as amended).

- 2 The development hereby permitted shall be carried out in accordance with the following approved plans [(PL)001 /P1, (EX)099/P1, (EX)100/P1, (EX)101/P1, (EX)102/P1, (EX)103/P1, (EX)104/P1, (EX)105/P1, (EX)106/P1, (EX)200/P1, (EX)300/P1, (EX)301/P1, (EX)302/P1, (EX)303/P1, (PL)099/P1,(PL)100/P1 [showing 6 cycle spaces], (PL)101/P1,(PL)102/P1, (PL)103/P2, (PL)104/P2, (PL)105/P2, (PL)106/P2, (PL)107/P2, (PL)200/P3, (PL)302/P2, (PL)303/P2, Plant Noise Assessment Report 8146/PNA dated: 24 July 2017, prepared by RBA ACOUSTICS]

Reason:For the avoidance of doubt and in the interest of proper planning.

- 3 Before the relevant part of the work is begun, detailed drawings, or samples of materials as appropriate, in respect of the following, shall be submitted to and approved in writing by the local planning authority:

a) Plan, elevation and section drawings, including jambs, head and cill, of all new window and door openings.

b) Samples and manufacturer's details of new facing materials including a sample panel of facing brickwork demonstrating the proposed colour, texture, face-bond and pointing.

c) Manufacturer's specification details of all facing materials (to be submitted to the Local Planning Authority) and samples of those materials (to be provided on site).

The relevant part of the works shall be carried out in accordance with the details thus approved and all approved samples shall be retained on site during the course of the works.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policy D1 and D2 of the London Borough of Camden Local Plan 2017.

- 4 Noise levels at a point 1 metre external to sensitive facades shall be at least 5dB(A) less than the existing background measurement (LA90), expressed in dB(A) when all plant/equipment (or any part of it) is in operation unless the plant/equipment hereby permitted will have a noise that has a distinguishable, discrete continuous note (whine, hiss, screech, hum) and/or if there are distinct impulses (bangs, clicks, clatters, thumps), then the noise levels from that piece of plant/equipment at any sensitive façade shall be at least 10dB(A) below the LA90, expressed in dB(A).

Reason: To safeguard the amenities of the adjoining premises [nd the area generally in accordance with the requirements of policies G1, CC1, D1, and A1 of the London Borough of Camden Local Plan 2017.

- 5 The development hereby approved shall achieve a maximum internal water use of

110litres/person/day. The dwelling/s shall not be occupied until the Building Regulation optional requirement has been complied with.

Reason: To ensure the development contributes to minimising the need for further water infrastructure in an area of water stress in accordance with Policies CC1, CC2, CC3 of the London Borough of Camden Local Plan 2017.

- 6 The secure and covered cycle storage area for 6 cycles hereby approved shall be provided in its entirety prior to the first occupation of any of the new residential units, and permanently retained thereafter.

Reason: To ensure the development provides adequate cycle parking facilities in accordance with the requirements of policy T1 of the London Borough of Camden Local Plan 2017.

- 7 Prior to occupation of any relevant part of the development, details of sound insulation measures for the residential units shall be submitted to and approved in writing by the Local Planning Authority. The approved sound insulation measures shall be installed prior to occupation of any of the residential units, and retained and maintained thereafter.

Reason: To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policies G1, CC1, D1, A1, and A4 of the London Borough of Camden Local Plan 2017.

Informative(s):

- 1 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts that cover aspects including fire and emergency escape, access and facilities for people with disabilities and sound insulation between dwellings. You are advised to consult the Council's Building Control Service, Camden Town Hall, Judd St, Kings Cross, London NW1 2QS (tel: 020-7974 6941).
- 2 Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You are advised to consult the Council's Noise and Licensing Enforcement Team, Camden Town Hall, Judd St, Kings Cross, London NW1 2QS (Tel. No. 020 7974 4444 or search for 'environmental health' on the Camden website or seek prior approval under Section 61 of the Act if you anticipate any difficulty in carrying out construction other than within the hours stated above.
- 3 You are reminded that this decision only grants permission for permanent residential accommodation (Class C3). Any alternative use of the residential units for temporary accommodation, i.e. for periods of less than 90 days for tourist or short term lets etc, would constitute a material change of use and would require a further grant of planning permission.
- 4 This permission is granted without prejudice to the necessity of obtaining consent under the Town and Country Planning (Control of Advertisements) (England) Regulations 2007. Application forms may be obtained from the Council's website,

www.camden.gov.uk/planning or the Camden Contact Centre on Tel: 020 7974 4444 or email env.devcon@camden.gov.uk).

- 5 If a revision to the postal address becomes necessary as a result of this development, application under Part 2 of the London Building Acts (Amendment) Act 1939 should be made to the Camden Contact Centre on Tel: 020 7974 4444 or Environment Department (Street Naming & Numbering) Camden Town Hall, Argyle Street, WC1H 8EQ.
- 6 Your attention is drawn to the fact that there is a separate legal agreement with the Council which relates to the development for which this permission is granted. Information/drawings relating to the discharge of matters covered by the Heads of Terms of the legal agreement should be marked for the attention of the Planning Obligations Officer, Sites Team, Camden Town Hall, Argyle Street, WC1H 8EQ.

In dealing with the application, the Council has sought to work with the applicant in a positive and proactive way in accordance with paragraphs 186 and 187 of the National Planning Policy Framework.

You can find advice about your rights of appeal at:

<http://www.planningportal.gov.uk/planning/appeals/guidance/guidancecontent>

Yours faithfully



David Joyce
Director of Regeneration and Planning