

1 UNIT 5 – GA PLAN

NOTES:

Ceilings within bathrooms coordinated with Air handling unit to allow suitable zone for the fixing of a 200kg hoist.

Bathroom walls constructed so as to allow for the installation of grab rails with imposed load of 1.5klVm2.

Bedrooms to allow for the fixing of a 200kg hoist to all ceilings

Guest shower is non-compliant as the minimum requirements for a 2 bedroom flat is for one accessible bathroom. Main bathroom constructed as a wet room to allow the future installation of a shower if required.

Prinicpal window handle at 700 – 1000mn All other window handles all within 450 – 1200mm range.

Door Handles between 850 - 1000mn

Boiler controls within 900 - 1200mm.

Power assisted door opening is provided where the opening force is more than 22.5N from 30deg to 60deg of the opening cycle.

Lift doors to have a time of five seconds before its doors begin to close after they are fully open.

REVISION: PURPOSE:

A ISSUED TO PLANNING

19,04,2018

A ISSUED TO PLANNING

A IS