

Important notes for electrical contractor

All directional light fittings to be angled by electrical contractor onto product/ displays/ artwork/ tables/ other in accordance with the lighting drawing/ any designer or client instructions. This must be carried out in advance of the final lighting commissioning/ any programming visit by the lighting consultant/ dimming engineer. Into Lighting do not carry out any works at high level.

Where DMX control is shown on the lighting layout the DMX control cabling should be wired in a daisy-chain using Belden 9841 cable, the maximum cable length from the source of the DMX output to the furthest DMX driver is 250m. A maximum of 32 DMX units can be connected to each DMX universe. If you have any questions about how to wire the DMX signal cable please contact Into on 0845 873 7013 or at technical@into.co.uk

Important note for emergency lighting design and specification

Where Into Lighting drawings show layouts for emergency lighting these are provisional layouts to help ensure sympathetic integration into the architecture and general lighting scheme. It is the responsibility of the mechanical and electrical consultant/ contractor to ensure that the emergency lighting scheme and specification meets with BSS266 and any local requirements. Where Into Lighting drawings do not show provisional layouts for emergency lighting it is the responsibility of the mechanical and electrical consultant/ contractor to provide the layout and specification.

It is the responsibility of the installing electrical contractor/ consultant to ensure the appropriate specification, supply and install of fire and/or acoustic hoods / down lights where required. The specification should meet with the specific site requirements, be fully compatible with any down lights specified and be installed in accordance with the manufacturers guidelines.



NOTE:
ALL LOCATIONS OF NON-FIXED FURNISHINGS SHOWN ARE INDICATIVE ONLY.

INTO LIGHTING LEGEND			
	SEMI RECESSED ADJUSTABLE SPOTLIGHT C/W 700MA 2.4W LED		RECESSED MOUNTING CHANNEL
	SUSPENDED FEATURE PENDANT C/W 6 X 230V 6W LED		SURFACE MOUNTED EMERGENCY EXIT SIGN C/W LED 3HOUR EMERGENCY BATTERY PACK – ARROW RIGHT
	SEMI RECESSED ADJUSTABLE SPOTLIGHT C/W 700MA 2.4W LED		SURFACE MOUNTED ADJUSTABLE SPOTLIGHT C/W 230V 14.9W LED
	SURFACE MOUNTED EMERGENCY ROUTE LIGHT C/W 2W LED 3HOUR EMERGENCY BATTERY PACK		

Symbols in key are not to scale

PROPOSED FOR PLANNING

Rev D NEW RCP / GENERAL REVISIONS

Rev C REVISIONS BUBBLED IN RED

Rev B REVISIONS BUBBLED IN RED

Project Title STREAT MARKETS LTD, CENTRE POINT, LINK BUILDING, W1			Into Lighting Ltd 4 O'Meara Street London SE1 1TE T: +44 (0) 845 873 7013 F: +44 (0) 845 873 7018 E: email@into.co.uk		
Drawing Title PROPOSED LIGHTING LAYOUT FOR PLANNING – MEZZANINE RCP			<small>This drawing and all associated documents issued for the purposes of design information remain the intellectual property of Into Lighting Limited. This drawing and all associated documents or information developed from their contents may not be reproduced or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or by any information storage and retrieval system, without prior consent from Into Lighting Limited. In the event that this occurs, Into Lighting Limited reserves the right to remove a design from the drawing. The positions shown on this drawing represent design intent, any queries should be checked with the design team.</small>		
Date 25.10.18	Drawn CM	Scale 1:50 @ A1			
Project 12561	Number C02	Revision D			
			All dimensions must be checked on site Do not scale from this drawing		

into