



**KEY**

Existing

**Notes:**

- 1- These drawings are to be read in conjunction with the M&E Engineers design and specification of the comfort cooling system.
- 2- Single lines mark out a route and comprise dual pipe runs. Refer to Drawing 815(PJ)910 for details.
- 3- All works to be carried out with minimum disturbance to the existing building fabric.
- 4- Pipe runs to use existing notches and former routes of central heating pipes wherever possible.
- 5- Drilling of joists to be kept to a minimum and to not exceed 25% of total depth of joists.
- 6- Drilling to be carried out within first quarter length of the span of joists taken from the nearest adjacent bearing.
- 7- All works to floor joists to be carried out to the approval of the Structural Engineer.

- Pipe Drop
- Dual pipe run within the existing build up (2no. pipes)
- Dual Pipe run concealed overhead
- Dual pipe run between outdoor unit and BC box
- Condensate route

01  
FIFTH FLOOR PLAN  
With Proposed Services

H I G H H O L B O R N

**General Notes**  
Do not scale. All written dimensions must be checked on site before work commences on site or in shop. Figured dimensions take preference over those scaled. Discrepancies, where identified, must be reported to the Architect immediately. Any areas indicated on drawings to be removed or altered must be carried out in accordance with the Building Regulations and to the satisfaction of the Local Authority.

**Drawing Status**

Job Number	Drawing Number	Rev	Scale
815	(01)617	K	1:100@A1 1:200@A3

Drawing Title: Fifth Floor Plan With Proposed Services

Project	Holborn Hall
Client	Mactoggart Inv Co Ltd
Date	21.06.2018
Drawn	drawn
Checked	checked

**Garnett & Partners LLP**  
5th Floor, 30 Abchurch Lane  
London EC4N 3DF  
London SE1 0LH

Architects and designers  
www.garnettpartners.com

SCALE 0 1 2 3 4 5 6 7 8 9 10 M

