

Our Ref.: pe/1635/nes/th/lbcpd/04a  
Planning Portal Ref.: PP-06593149  
Your Ref.: 2017/6787/NEW and  
2018/4041/P

E-mailed and posted:  
thomas.sild@camden.gov.uk

Mr. Thomas Sild  
Planning - Development Control  
Camden Council  
Camden Town Hall  
Judd Street  
London  
WC1H 8ND

*Producing your tomorrows, today*

24 October 2018  
1538hrs

Dear Mr. Sild,

**38 Constantine Road, Gospel Oak, London, NW3 2NG:**  
**Proposed Single-Storey Rear Extension and Main Roof Extension:**  
**Confirmation of Intended Features to Main Terraced Roof Slopes and Roof of Rear Extension**

Main terraced roof

Your requirement within your e-mail dated 24 April 2018 timed at 1144hrs is acknowledged for the front roof slope to incorporate 'conservation-type' skylight windows (which Velux do manufacture) in that they have a lower prominence above the roof slope.

Roof of rear extension

The slope-angle of the roof of the rear extension is 10° and the nominated tiles can be laid to a limit of 15° or greater.

We have explored whether commercially available tiles exist that can be laid to 10° according to the manufacturer's recommendations and there are none available. We would therefore confirm that to achieve a match with the roof of the rear dormer, the roof of the rear extension shall be finished with code 4 lead sheeting by Calder (www.calderlead.co.uk).

Kindly acknowledge this letter and that the corresponding materials' Conditions are thus discharged.

Yours sincerely,

**Terry Harriette**

BSc(Hons), MStructE, MICE, CEng, EurIng, MFPWS, IOSH(Aff)

**Director**

for and on behalf of **THE CONSULTANTS**

c.c. Mr. M. Whitfield e-mailed and posted